

PITC JIRA

[PITC JIRA](#)Displaying **1000** issues at **10/Oct/17 1:03 PM**.

Issue Type	Key	Summary	Status	Building	Description
Building Issue	FACREQ-68	Repair door handle	Done	West Wing	This is in the WW, rm 213. The latch will not stay engaged. The occupant would like it repaired out of hours. After 6pm today or over the weekend.
Facility Request	FACREQ-87	G1 cable work	Done	West Wing	Assist WHAC with cable pull
Facility Request	FACREQ-88	Paint Touch up	Done	West Wing	Touch up paint in WW G1 area to repair the damage caused by the cable pull
Building Issue	FACREQ-104	WW Building Inspection Requests	Done	West Wing	Replace damaged and dirty ceiling tile in the WW ground floor corridor outside G66 women's restroom. Tile are in poor condition and need replaced as soon as the schedule permits.
Building Issue	FACREQ-105	WW Building	Done	West Wing	Paint wall in G-F, below the drip pan.
Building Issue	FACREQ-106	WW and EW Building Inspection	Done	West Wing	Install a walk off mat to prevent dirt from being tracked onto the carpet.
Building Issue	FACREQ-107	WW and EW Building Inspection	Done	West Wing	Carpet needs cleaned in G43 and G33. There are lines in the carpet where the carpet machine cleaned and did not remove the dirt.
Building Issue	FACREQ-108	WW and EW Building Inspection	Done	West Wing	Stained tile around toilet in 1st stall in G65 restroom. Please clean or replace out tile.
Building Issue	FACREQ-109	WW and EW Building Inspection	Done	West Wing	Loose Carpet on stair riser on the stairs going up from G79
Building Issue	FACREQ-110	WW and EW Building Inspection	Done	West Wing	Replace ceiling return/supply vents in WW101. Vents are dirty and have been painted to a point of air flow is being restricted and causing excessive noise.
Building Issue	FACREQ-118	WW and EW Building Inspection	Done	East Wing	Replace damaged kick plated on the doors in the EW E101
Building Issue	FACREQ-119	WW and EW Building Inspection	Done	East Wing	Replace small piece of cracked glass in one of the half round windows. The location is the corridor/theater wall

Building Issue	FACREQ-120	WW and EW Building Inspection	Done	West Wing	Identify the small red light above the Cabinet room door. If the light is no longer used please remove and patch hole.
Facility Request	FACREQ-132	Door or Lock Sticking	Done	West Wing	The main door to the NSC's WW Lower Suite is sticking. The end users have had to force the door open on more than one occasion. Please send a carpenter to take a look - coordinate with Stephanie Raymond or Hansel Rodriguez.
Facility Request	FACREQ-160	Replace Fixtures and appliances in POTUS WW Pantry	Done	West Wing	<p>upgrades to WH Pantry</p> <p>14 JUN - ordering countertop, cabinets, plumbing etc (this ensures all the items will be here once work is set to begin); microwave etc List of RWAs that support (POCs for each RWA is....)</p> <p>30 JUN - Estimated arrival of all items</p> <p>1-10 JUL - Off site manufacturing of Cabinets</p> <p>6 AUG - Demo (POC is:.....)</p> <p>7 AUG - Plumbing (POC is:)</p> <p>8 AUG - Cabinet install (POC is:....)</p> <p>9 AUG - Appliances install (POC is...)</p> <p>10 AUG - QC, Turn over and acceptance of the final product</p> <p>(any other aspect I maybe missing)</p>

Facility Request	FACREQ-161	Replace cabinets in WW Pantry	Done	West Wing	<p>upgrades to WW pantry</p> <p>14 JUN - ordering countertop, cabinets, plumbing etc (this ensures all the items will be here once work is set to begin); microwave etc List of RWAs that support (POCs for each RWA is....)</p> <p>30 JUN - Estimated arrival of all items</p> <p>1-10 JUL - Off site manufacturing of Cabinets</p> <p>6 AUG - Demo (POC is:.....)</p> <p>7 AUG - Plumbing (POC is:)</p> <p>8 AUG - Cabinet install (POC is:....)</p> <p>9 AUG - Appliances install (POC is...)</p> <p>10 AUG - QC, Turn over and acceptance of the final product</p> <p>(any other aspect I maybe missing)</p>
Facility Request	FACREQ-174	Move Roosevelt Room Furniture	Done	West Wing	<p>The conference room table, chairs, side chairs, and coffee table need to be removed from the room at 8:30am on Wednesday, July 6. The return time has not been determined yet.</p>
Building Issue	FACREQ-176	West Wing, room 101 which is the Press Office.	Done	West Wing	<p>Need a total of seven supply and return air grills replaced. Five of the the grills are located just inside the reception area above the reception desk, these five are all in a row(see pic). The next grill is in the office directly behind the reception desk, this is a return grill that needs replacing. The next grill is in the office directly to the left of the first office and it also is the return air grill that needs replacing. SHEET METAL SHOP</p>

Building Issue	FACREQ-183	WW ground floor	Done	West Wing	carpenters to fix the loose swinging door. This is in the west wing ground floor navy mess. This work can be completed any time after 2 : 30 pm.
Building Issue	FACREQ-184	plumbers to replace the missing drain line, also	Done	East Wing	
Building Issue	FACREQ-190	To Lower the W.W. Roosevelt Room Temperature by 2	Done	West Wing	Assign to the 4 to 12 Shift Engineers
Building Issue	FACREQ-211	WW, Ground Floor/Electrical Shop;	Done	West Wing	Replace the missing plate.
Building Issue	FACREQ-213	WW Ground Floor & RR/Custodial Shop; see description	Done	West Wing	Please deep clean all the west wing ground floor space by the copier. Also dust clean the furniture in the Roosevelt room.
Building Issue	FACREQ-214	WW, Lower Press/Pest Shop; see description	Done	West Wing	Treat the entire Lower Press Suite for ants.
Building Issue	FACREQ-223	landscape shop to treat the entire Lower Press	Done	West Wing	ANTS
Building Issue	FACREQ-252	Trash Can Drawer Stuck Open	Done	East Wing	The pull out trash can in the copy room on the 2nd floor of the East Wing will not close. There are items stuck behind the trash can that need to be removed so that the drawer can close
Facility Request	FACREQ-254	Repair Storage Cabinet	Done	West Wing	<p>Please repair the doors and support leg on the storage cabinet located in the back copy room on the Ground Floor of the West Wing.</p> <p>The door hinges are in bad shape and may need to be replaced</p> <p>The support leg had been damaged by the paper boxes being stored next to the cabinet. We're working on getting that paper removed</p>

Building Issue	FACREQ-262	EW RM 211	Done	East Wing	PLEASE REMOVE DESK DRAWER TENANT DROPPED SOMETHING BEHIND IT
Building Issue	FACREQ-265	Please Clean Exterior Windows	Done	East Wing	The exterior windows on the East Side of the 2nd Floor of the East Wing are very dirty. Many of these windows do not have blinds or shades so it is very noticeable.
Building Issue	FACREQ-272	West Wing room 101 grills that need replacing.	Done	West Wing	Total of 7 grills in three areas need to be replaced. In the reception area 5 grills need to be replaced. Five grills are in a row just as you walk into the room. Second area, the office directly behind receptionist desk return Grill needs to be replaced. Next office to left return Grill needs replacing. SHEET METAL SHOP
Building Issue	FACREQ-279	Replace Missing Ceiling Grid	Done	West Wing	There is a missing section of ceiling grid outside of the Women's Room on the Ground Floor. It has also been requested that all of the ceiling tile in the area be replaced due to being very dirty.
Building Issue	FACREQ-280	Loose Carpet on Steps	Done	East Wing	There is caret coming loose on the stairs that lead from the 1st to 2nd floor in the East Wing. The loose carpet is on the riser section of the 4th step up from the 1st floor. This could potentially be a tripping hazard
Facility Request	FACREQ-281	Install New EV Charging Station (MAXIMO 16-2431)	Done	West Wing	This is to cover the installation costs for a new double head EV charging station on West Exec. This ticket replaces the original MAXIMO ticket that was created to fund the work
Building Issue	FACREQ-291	2W-51 TOO HOT	Done	West Wing	TURN UP 3 DEGREES
Facility Request	FACREQ-311	THE PEDESTRIAN GATE WILL NOT	Done	East Wing	POST A-14

Facility Request	FACREQ-313	Roosevelt Room Table Removal	Done	West Wing	On Monday, July 18, we would like to have the Roosevelt Room conference table, conference chairs, side table, and side chairs removed from the room at 11:00am. Everything can then be placed back into the room at 4:30pm on the same day.
Building Issue	FACREQ-328	raise the temperature by 2 degrees up. She says it's 69 degrees in	Done	West Wing	Cold 1W-39
Building Issue	FACREQ-333	TOO COLD	Done	West Wing	ZONE 2W-51 - Adjusted the Temperature and Checked the Operation.
Facility Request	FACREQ-353	Remove furniture from East Reception Room	Done	East Wing	Please remove all furniture from the East Reception Room to accommodate a FLOTUS taping. The furniture will need to be removed between 7:00 AM and 8:00 AM on Friday, July 15th. The furniture can be returned at 1:30 PM on July 15th. Kayla Daniels is the staff POC for this move.
Building Issue	FACREQ-356	WW/Elevator Shop; see description	Done	West Wing	Adjust the door it's making loud noise when opening / closing *THIS TICKET MAY HAVE BEEN COMPLETED, IF SO JUST CLOSE.
Building Issue	FACREQ-360	To Adjust (Lower) the Temperature in the W.W. Zone# 1W-39	Done	West Wing	Assign to the 4 to 12 Shift Engineers
Building Issue	FACREQ-379	plumber to the press area bathrooms. The men's room toilet is not	Done	West Wing	
Building Issue	FACREQ-387	Please Clean West Wing Ground Floor Entrance Area	Done	West Wing	There is a lot of dirt/dust build up visible under the fan coil unit cover. And there are cob webs with dead bugs stuck in them around the ceiling
Building Issue	FACREQ-406	W2-53 & W2-50	Done	West Wing	TOO COLD

Building Issue	FACREQ-423	Fix Door Stop	Done	East Wing	There is a door stop in the East Reception Room that is not working properly. The stopper may need replaced, or the door stop needs to be moved down.
Building Issue	FACREQ-428	EW/Engineering Shop; see description	Done	West Wing	Lower temperature in room; too warm (First Lady taping)
Building Issue	FACREQ-429	Touch Up Oval Entrance Door	Done	West Wing	Please touch up area on door opening that has been scraped
Facility Request	FACREQ-431	Space Upgrades in WHSR	Done	West Wing	Estimate required by COB, Monday July 25th. Scope of work provided to GSA and OA. NTE price of \$3,000 granted. Contact Stephanie Raymond or Hansel Rodriguez for additional details.
Facility Request	FACREQ-443	POST A-14	Done	East Wing	This is for the outer gate which has a hydraulic type floor closer. It is also slamming shut and needs to be repaired. The seals appear to be blown and the closer needs to be replaced.
Building Issue	FACREQ-454	Replace Burnt Out Light Bulb	Done	East Wing	There is a light out in one of the wall sconces in the East Wing Stairway
Facility Request	FACREQ-455	Purchase New Mat for Marine	Done	West Wing	Please provide a new mat for the West Wing, where the Marine stands.
Building Issue	FACREQ-456	Paint Touch Up in G48	Done	West Wing	The entrance door to G48 had to be opened by removing the slam strip on the door jamb due to a lock malfunction. The slam strip has been reattached, but needs to be re-caulked and touched up.
Facility Request	FACREQ-461	A/C NOT WORKING	Done	East Wing	THE AIR CONDITIONER IS BLOWING HOT AIR. EXTREMELY HOT
Building Issue	FACREQ-462	electricians to clean all the hallway light fixtures in the west wing 1st floor hallways inside	Done	West Wing	

Building Issue	FACREQ-477	WW/Move Shop; see descripton	Done	West Wing	Request an estimate to move furniture for various carpet replacement projects in support of August projects in the West Wing. Request to schedule a walk-through as soon as possible of required work.
Building Issue	FACREQ-478	EW LA Office	Done	East Wing	engineers to place the carpet floor fan this evening after hours and to remove it tomorrow morning by 6:30 am, and the carpenters to replace the damaged ceiling tile tomorrow morning at 6:30 am in the east wing Legislative Affairs, this is on the left as you enter the office.
Building Issue	FACREQ-497	To Check a Leak in the E.W. Zone# 1E-3. - Assign to the 4 to 12	Done	East Wing	
Building Issue	FACREQ-502	Spill	Done	West Wing	
Building Issue	FACREQ-503	Clogged Drains	Done	West Wing	Restroom in Post A-4- commode is stopped up.
Facility Request	FACREQ-504	Build New Base Section for Existing Cabinetry	Done	West Wing	We would like to modify the existing cabinet/counter in the Ground Floor copier area. The thought is to remove the bottom cabinet and support leg and replace that with a legs and shelf configuration. Reusing the counter top and upper cabinet Please contact me to discuss
Building Issue	FACREQ-507	West Wing: Investigate water leaking from ceiling in Press Office	Done	West Wing	
Building Issue	FACREQ-529	Clean glass at VIP lobby and outside RR.	Done	West Wing	Please have the Paint shop assist the custodial shop in removing the glass on the various desk in the VIP lobby and RR vestibule.

Building Issue	FACREQ-534	Please Clean Storage Cabinet with Fire Extinguisher	Done	West Wing	There is a storage cabinet right outside or the E-10 entrance to the West Wing. The cabinet contains a fire extinguisher and some other emergency items. the cabinet is very dirty and it looks like it has been a long time since the fire extinguisher has been inspected
Building Issue	FACREQ-535	PRESS AREA BOOTH AP LIGHTS OUT	Done	West Wing	
Building Issue	FACREQ-536	PRESS AREA BOTH RESTROOMS MEN'S AND LADIES	Done	West Wing	NO AIR FLOW VENTS MAY NEED TO BE CLEANED
Building Issue	FACREQ-548	Restroom in Post A-4-when commode is being flushed, water	Done	West Wing	The drain on the floor is stopped up and water is not going down.
Facility Request	FACREQ-551	Shoe Shiner Assistance	Done	West Wing	Requesting assistance with replacing some parts on the shoe shiners in the West Wing. I have new buffers and feet for the shiners, but need an Allen Wrench to install the buffers.
Building Issue	FACREQ-560	To Lower the Temperature by 2 Degrees in the W.W.	Done	West Wing	Assign to the 4 to 12 Shift (Billy)
Building Issue	FACREQ-561	To Lower the Temperature by 2 Degrees in the W.W.	Done	West Wing	Assign to the 4 to 12 Shift Engineers (Billy)
Building Issue	FACREQ-562	To Lower the Temperature by 2 Degrees in the W.W.	Done	West Wing	Assign to the 4 to 12 Shift Engineers (Billy)

Facility Request	FACREQ-565	Singapore State Visit	Done	West Wing	<p>This ticket is for the custodial shop to please clean all the exterior and interior windows east wing room 103, main entrance and the colonnade.</p> <p>Clean vacuum the outside and inside mats east and west wing.</p> <p>Clean all the brass door tracks, polish all kick plates east and west wing.</p> <p>Polish and buff the east wing colonnade on 7/31/2016</p> <p>Wipe down all the east wing main entrance and colonnade walls.</p> <p>Wipe all around the jumbo prints in the east and west wings.</p>
Building Issue	FACREQ-566	Touch up on door edge above the escutcheon plate OOO entry into	Done	West Wing	Left of patio door paint peeling.
Facility Request	FACREQ-582	Replace Maximo 16-2326 (WHSR)	Done	West Wing	Installation of laptop shelf
Building Issue	FACREQ-592	please check the zone 1E - 12 it's humid and has misty smell only in	Done	East Wing	
Building Issue	FACREQ-599	WW/Custodial Shop; see description	Done	West Wing	<p>Please not be leave the trash can in between the door. Look at the picture. I have taken care of this request.</p> <p>Also try not to pull and drag the trash bags because you can see the spots.</p> <p>Let me know if you have any questions about this request.</p>

Building Issue	FACREQ-601	EW/Engineer Shop; see description	Done	East Wing	Please check the zone 1E - 12 it's humid and has misty smell only in that office. Let me know what you find out? I have to
Facility Request	FACREQ-604	Deliver new desk chair to West Wing; remove broken desk chair	Done	West Wing	We need to deliver a chair to the West Wing this afternoon between 2:00 PM and 3:30 PM. The chair is coming on the RDS truck. We will then need to remove the broken chair currently in the office. Thanks for your help, Julia
Building Issue	FACREQ-605	EW/Custodial Shop; Singapore State Visit	Done	East Wing	Please clean all the exterior and interior windows east wing room 103, main entrance and the colonnade. Clean vacuum the outside and inside mats east and west wing. Clean all the brass door tracks, polish all kick plates east and west wing. Polish and buff the east wing colonnade on 7/31/2016 Wipe down all the east wing main entrance and colonnade walls. Wipe all around the jumbo prints in the east and west wings.
Building Issue	FACREQ-606	Repair broken handicap button	Done	West Wing	
Building Issue	FACREQ-614	carpenters to please refinish / touch up the entry way table, which	Done	West Wing	stripped top and refinished

Facility Request	FACREQ-625	Please hang two jumbos in Jen Psaki's office	Done	West Wing	Hello, Please hang two jumbos in Jen Psaki's Office in the West Wing Upper Press suite. If possible, she would like the jumbos hung at 2:00 PM today, Tuesday July 26th. Please let me know if you have any questions. Thanks, Julia
Facility Request	FACREQ-628	HYDRAULIC CLOSER ON EAST SIDE POST DOOR IS BROKEN.	Done	West Wing	
Building Issue	FACREQ-646	zone 2W-58	Done	West Wing	make 2 degrees cooler
Building Issue	FACREQ-647	zone 1W-39	Done	West Wing	turn up 1 degree
Building Issue	FACREQ-648	movers to move the table from the west wing ground floor by	Done	West Wing	to the carpenter shop and bring it back after the finish is completed tomorrow morning at 7:30 am.
Building Issue	FACREQ-659	Room Temperature	Done	West Wing	Zones G12W, 2W58 in the West Wing are too hot.
Building Issue	FACREQ-664	In the basement mechanical room at bottom of stairs. Need to pull and clean chill	Done	East Wing	
Building Issue	FACREQ-675	plumbers to replace all the tissue paper holders in the west wing ground floor men's	Done	West Wing	
Building Issue	FACREQ-676	electricians to replace the flickering light bulb	Done	West Wing	west wing ground floor by E -1 post.
Building Issue	FACREQ-687	WW/Engineer Shop; see description	Done	West Wing	Increase temperature in 1W-39.

Building Issue	FACREQ-692	To Assist the Sheet Shop in the W.W. on	Done	West Wing	
Facility Request	FACREQ-694	Hang Network Clock - WHSR	Done	West Wing	Request assistance from the carpentry shop with hanging a network clock in the WHSR; contact JD Fuchs for questions. Ideal day/time to complete this work is Friday, July 29th between 6:00 and 7:00am.
Building Issue	FACREQ-697	WW ground floor hallway	Done	West Wing	please check out the water leak coming above the ceiling in the west wing ground floor navy mess hallway by the steps.
Building Issue	FACREQ-715	Temperature Control	Done	West Wing	NBC Press Booth needs to be turned up 10 degrees
Building Issue	FACREQ-719	EW/WW;Plumbing Shop; see description	Done	West Wing	Fix the leaky FCU in the east wing 2nd floor room 206/208.
Building Issue	FACREQ-720	WW 1st floor CoS	Done	West Wing	Replace the burnt-out light bulbs in the west wing 1st floor CoS Office. This work can be completed after hours please.
Building Issue	FACREQ-740	EW/Fire Shop; see description	Done	East Wing	<p>Please remove or disable any detectors in the immediate area of the following locations and times due to dust or paint/solvent work.</p> <p>East Wing Entrance Lobby Area - Rooms E101 and E116 - Saturday 8/6 through Monday 8/22.</p>
Building Issue	FACREQ-741	WW/Fire Shop; see description	Done	West Wing	<p>Please remove or disable any detectors in the immediate area of the following locations and times due to dust or paint/solvent work.</p> <p>West Wing NSC Upper Suite - Rooms 132, 1-A, 1-B, and 1-C - Saturday 8/6 through Tuesday 8/9.</p>

Building Issue	FACREQ-742	WW/Fire Shop; see description	Done	West Wing	Please remove or disable any detectors in the immediate area of the following locations and times due to dust or paint/solvent work. West Wing Roosevelt Room Area - Rooms 150 and 109 - Friday 8/12 through Sunday 8/14.
Building Issue	FACREQ-743	EW/Engineer Shop; see description	Done	East Wing	Check the FCU which is leaking as you can see from the pictures. This is in the east wing 2nd floor between the ladies and gentlemen bathrooms hallway. This can be completed asap. Let me know what you find out?
Building Issue	FACREQ-744	EW/Electrical Shop; see description	Done	East Wing	Replace the burnt-out light bulbs in the east wing 1st floor landing.
Building Issue	FACREQ-754	WW/Pest Shop; see description	Done	West Wing	Several roach sighting.
Building Issue	FACREQ-761	EW/Move Shop; see description	Done	East Wing	Take the colonnade mats down to the east wing basement this evening.
Building Issue	FACREQ-780	WW 1st floor CoS Office	Done	West Wing	Treat for ants in the west wing 1st floor CoS Office, especially the main entrance and the small office
Building Issue	FACREQ-781	WW/Electrical Shop; see description	Done	West Wing	Place the special ladder by EEOB room 73 @ 5 : 00 pm tomorrow evening.
Building Issue	FACREQ-782	WW ground floor NSC	Done	West Wing	Custodian shop to deep clean the lower suite NSC Office starting at 6:30 am. Also to check and take care of the insects, ants issues this is for the lower suite NSA office west wing ground floor at 6:30 am. This work needs to be scheduled for August 15th

Building Issue	FACREQ-783	WW 1st floor Post E - 10	Done	West Wing	Turn the fan switch off which is in the west wing 1st floor by post E -10, the switch is above the ceiling by the door. Just talked to TSD and they're ready anytime after 10 : 00 pm tonight, and turn it back on tomorrow night Sametime. Here's the phone # TSD 202-406-9531. Let me know when you have completed this request.
Building Issue	FACREQ-787	WW Gr floor men's room	Done	West Wing	The Mason Shop is to fabricate and install a vanity to replace the stained one there now.
Building Issue	FACREQ-792	EW 1st floor double doors	Done	East Wing	Carpenters, fix the broken door stop This is by post G 4 and the part is on the floor next to the wall by the drinking water fountain.
Building Issue	FACREQ-794	WW NM	Done	West Wing	Paint shop to repair blistering ceiling at the stairway leading to Navy Mess. Work to be completed once engineers/ plumbers fix condensating pipe
Building Issue	FACREQ-795	Crack repair	Done	West Wing	Paint Shop to repair crack in wall near W 210.
Building Issue	FACREQ-796	EW tour route doors	Done	East Wing	Please have the Paint Shop touch up the entry doors at the EW tour route.
Facility Request	FACREQ-802	Move Cabinet Room Table	Done	West Wing	On Saturday, August 6, the Cabinet Room table needs to be removed from the Cabinet Room before 12pm and loaded onto a Kittinger truck.
Building Issue	FACREQ-835	WW OOO hallway; patch / touch up after the electricians replace the burnt-out light bulb	Done	West Wing	

Building Issue	FACREQ-836	WW NSA; deep clean the entire NSA lower suite, starting at 6:30	Done	West Wing	
Building Issue	FACREQ-837	WW Oval; replace the burnt-out light bulb in the west wing Oval	Done	West Wing	Please call TSD and they will support you. This is the number for TSD - 202-406-9531
Building Issue	FACREQ-838	EW 1st floor landing; replace the burnt-out light bulb in the east	Done	East Wing	
Building Issue	FACREQ-839	WW ground floor hallway; see description	Done	West Wing	Patch / touch up around couple of cans in the west wing ground floor hallway by the men's bathroom and by the NSA office
Building Issue	FACREQ-845	WW/Landscape Shop; see descriptions	Done	West Wing	Treat for flies in the west wing ground floor room G-H, G - 50 and DCoS . EEOB South Auditorium treat for bat.
Building Issue	FACREQ-854	WW/Carpenter Shop; August Projects Support	Done	West Wing	In support of August projects. Need the divider wall taken down in Navy Mess dining room G31 prior to Sunday, 7 August 2016 at 0630 and returned after 1830 or by Monday morning opening business. Need the fan coil cover and VRU cabinet removed from the wall prior to Saturday, August 20, 2016 at 0630 and returned after 1830 on Sunday, August 21, 2016 but before opening business on Monday
Building Issue	FACREQ-865	WW/Pest Shop; treat for ants in the west wing 2nd floor offices on your left from the	Done	West Wing	
Building Issue	FACREQ-866	WW/Custodial Shop; deep clean the entire	Done	West Wing	

Building Issue	FACREQ-867	WW/Plumbing Shop; ground floor ladies bathroom	Done	West Wing	Fix / secure the loose toilet tissue paper holder. This is in the west wing ground floor ladies bathroom
Building Issue	FACREQ-868	WW/Carpenter Shop; WW E-10 post	Done	West Wing	Have the Hand Railing Removed from the Wall so the USRO can Preform the PM on the FCU's in the Hallway of the W.W. by the USSS Post E-10 on 8-17-16. This work can be completed before 10:00 PM and put it back before 8:00 AM the next-day.
Facility Request	FACREQ-880	Install TV mount on desk	Done	West Wing	Please install TV mount that is connected to desk. In WW Press Area. Pick up two boxes from Taifa Coger's desk before install. POC Contact Chip Somodevilla to schedule the install. 202-468-3568
Building Issue	FACREQ-897	plumbing shop to snake a drain in the East Wing basement Water room.	Done	East Wing	The drain is draining to slow. The room is across from the steam station. see Quick or Scott for access
Facility Request	FACREQ-898	POST A-4 EXTERIOR PEDESTRIAN GATE ELECTRIC STRIKE	Done	West Wing	
Building Issue	FACREQ-899	E.W. AH# 2 Alarm	Done	East Wing	To Check the E.W. AH# 2 PDS-1 Alarm.
Building Issue	FACREQ-913	WW 1st floor NSA/Engineer Shop; see description	Done	West Wing	Clean all the supply and return vents in the west wing 1st floor NSA suite. We have access to the upper suite tomorrow morning from 6 : 30 am to 8 : 30 am. Thank you, Complete
Facility Request	FACREQ-916	THE OUTER PEDESTRIAN GATE	Done	East Wing	

Building Issue	FACREQ-920	The WHSR discovered mice in their space this	Done	West Wing	Please schedule the exterminator to stop by, when available, to set more traps.
Building Issue	FACREQ-922	WW LOBBY AREA WATER POURING	Done	West Wing	SEND SOMEONE ASAP, BY MECHANICAL ROOM
Facility Request	FACREQ-925	West Wing Desk Repairs	Done	West Wing	<p>Hello,</p> <p>Two senior staff desks on the WW 2nd floor need repair:</p> <p>There is a drawer jamming on Ms. Jarrett's desk in WW 208.</p> <p>Part of the front of Ms. Aniskoff's desk in WW 209 fell off.</p> <p>Is it possible to have both of these repaired before 9:00 AM on Wednesday, 8/10?</p> <p>Thanks, Julia</p>
Building Issue	FACREQ-936	sheetmetal shop to fabricate two new light pole flag brackets for	Done	West Wing	POC: TIM BUNKER
Building Issue	FACREQ-938	Please raise it 2 degrees.	Done	West Wing	<p>Can we have the set point raised in West Wing zone W2-51? Please raise it 2 degrees.</p> <p>POC: CLINT</p>
Building Issue	FACREQ-940	To Assist the Plumbers in the E.W. RO Room	Done	East Wing	Assign to the 4 to 12 Shift Engineers (Billy)
Building Issue	FACREQ-942	To Check the Temperature Alarm on	Done	East Wing	Assign to the 4 to 12 Shift Engineers (Billy)
Building Issue	FACREQ-966	Please check operation of the ventilator for the	Done	West Wing	
Building Issue	FACREQ-979	WW 1st floor men's bathroom by Roosevelt	Done	West Wing	fix the loose toilet handle. This is in the west wing 1st floor by Roosevelt room.

Facility Request	FACREQ-989	REPLACING 16-1840	Done	West Wing	FABRICATE AND INSTALL CLOSET CABINETS/CUBBIES
Facility Request	FACREQ-990	REPLACING 16-2805	Done	West Wing	INSTALLATION FOR PLEXI-GLASS IN W16 POC: JEFF HARRINGTON
Facility Request	FACREQ-991	REPLACING 16-3024	Done	West Wing	ORDER MATERIALS, FABRICATE AND INSTALL WORK STATION COUNTER
Facility Request	FACREQ-992	REPLACING 16-3025	Done	West Wing	ORDER, MODIFY AND INSTALL PLEXI GLASS FOR WALL PROTECTION
Building Issue	FACREQ-1007	EW/Move Shop; ,move fan coil covers to Carpenter Shop after	Done	East Wing	
Building Issue	FACREQ-1018	West Wing Temperature Change	Done	West Wing	Zone w242 needs to be 2 degrees colder.
Building Issue	FACREQ-1040	VP outer office please set mouse traps	Done	West Wing	In Anne Marie area please set all new mouse traps.
Building Issue	FACREQ-1049	WW ground floor	Done	West Wing	landscape shop to place more traps in the west wing ground floor by the main entrance and the hallway a d by the Navy mess hallway. They say mouse running around.
Building Issue	FACREQ-1057	WW Rooftop/Plumbing Shop; see description	Done	West Wing	Unclog the drain in the west wing rooftop.
Building Issue	FACREQ-1058	WW 2nd floor hallway	Done	West Wing	Patch / paint in the west wing 2nd floor hallway by men's bathroom
Facility Request	FACREQ-1079	please hang jumbo in WW2	Done	West Wing	Hello, We need to have one jumbo hung on the second floor of the West Wing. Cory Pollard will be the POC for this request, and she would like to be present for the work. Can a carpenter come by at 11:00 AM tomorrow to hang the jumbo? Thanks, Julia

Facility Request	FACREQ-1085	Electrical Issue in WW G74	Done	West Wing	Request support from the electrical shop to swap an outlet in room G74 so a new copier can be safely plugged in. Contact Stephanie Raymond in EEOB room 330 to coordinate
Building Issue	FACREQ-1086	WW NAVY MESS	Done	West Wing	Landscape shop to place/add more traps they spotted mice run in the small and big dinning rooms and by the Navy Mess by the carryout window hallway.
Facility Request	FACREQ-1089	Cabinet Room Table	Done	West Wing	On Saturday, August 20, we would like for the current conference room table located in the Cabinet Room to be returned to EEOB 428. Then, we would like for the Cabinet Room table itself, which is being returned to us that morning, brought back into the Cabinet Room and reassembled.
Building Issue	FACREQ-1111	EW tour route	Done	East Wing	Please have the Paint shop touch up the red areas before they replace the FCU's in the EW colonnade
Building Issue	FACREQ-1112	WW VIP lobby	Done	West Wing	Please have the Paint shop paint the wall and ceiling above the repaired plaster work.
Building Issue	FACREQ-1116	THE AUTOMATIC DOOR OPENER FOR GLASS DOORS IS	Done	West Wing	
Building Issue	FACREQ-1131	MOVE REQUEST	Done	East Wing	move shop to move the FCU covers from the carpenter shop to the EW colonnade Friday 8/19/16 between 12:00pm to 3:00pm The truck needs to go to the Kennedy garden entrance of the EW.
Building Issue	FACREQ-1136	ASSIST WILL AN BEEPING NOISE IN	Done	West Wing	

Building Issue	FACREQ-1141	This is to clean the glass top/underneath in the EW OLA on	Done	East Wing	
Building Issue	FACREQ-1146	elevator is stuck on the ground floor	Done	West Wing	
Building Issue	FACREQ-1147	To Check a Alarm in the W.W. Press	Done	West Wing	Assign to the 4 to 12 Shift Engineers (Billy)
Building Issue	FACREQ-1151	WW ground floor/Electrical Shop;	Done	West Wing	replace the burnt-out light bulb in the west wing ground floor big dinning room.
Building Issue	FACREQ-1158	WW 1st floor DCOS	Done	West Wing	This ticket is for the paint/custodian shop to please clean the glass from underneath and the topside. This work can be completed on Monday morning at 7 : 00 am. This is in the west wing 1st floor room 120.
Facility Request	FACREQ-1164	Removal of Roosevelt Room Table Wednesday, August 24	Done	West Wing	<p>We need to have the Roosevelt Room table removed at 11:30 am on Wednesday, August 24 for a POTUS interview. The side armchairs, coffee table, and the couch can remain in. We also need to bring 3 chairs in for the crew.</p> <p>We will need to put the Roosevelt Room table back in at 5:30 pm the same day.</p>
Building Issue	FACREQ-1186	engineers to raise the temperature by 2 degrees. Too cold. Let me know what the set	Done	West Wing	WW Oval Office
Building Issue	FACREQ-1187	WW ground floor	Done	West Wing	landscape shop to place more traps in the west wing ground floor, rooms 47, 49, 50 and G - H.
Building Issue	FACREQ-1188	WW VIP Lobby Door	Done	West Wing	carpenters that the door between the West Wing Lobby and the West Stairs in the WW has been getting stuck and not being able to be closed properly all morning.

Building Issue	FACREQ-1193	PLEASE HAVE SOMEONE PICK UP DEAD MOUSE WW VP	Done	West Wing	
Building Issue	FACREQ-1194	RESET MOUSE TRAP WW VP OFFICE	Done	West Wing	POC ANNE MARIE
Building Issue	FACREQ-1201	WW PRESS LOBBY KITCHEN NEED MOUSE TRAPS	Done	West Wing	PLEASE CHECK BASEMENT AND GROUND BOOTH FOR ANTS AND ROACHES
Building Issue	FACREQ-1216	Need service ticket to the engineers to check operation on the RO	Done	West Wing	
Building Issue	FACREQ-1217	Need service ticket to the engineers to check operation on the RO	Done	East Wing	
Facility Request	FACREQ-1222	Appointment Door Not Securing	Done	West Wing	POST A-4 Sgt. S. PAPE
Building Issue	FACREQ-1229	To Jump Start a Staff Member Car on West Exec as Requested by	Done	West Wing	- Assign to the 4 to 12 Shift Engineers (Billy)
Facility Request	FACREQ-1245	Removal of Roosevelt Room Table and Chairs Monday, August 29	Done	West Wing	We need to have the Roosevelt Room table and chairs removed at 11 am on Monday, August 29 for a POTUS interview. The side armchairs, coffee table, and the couch can remain in. Additionally, please bring 6 chairs and a table in for the crew. We will need to put the Roosevelt Room table and chairs back in at 5:30 pm the same day.

Building Issue	FACREQ-1246	Deliver and unload couch in the East Wing	Done	East Wing	Hello, RDS will deliver a couch to the East Wing on Wednesday, 8/24 at 2:00 PM. We will need at least 3 movers to help unload the truck and to set it up in Ellie Schafer's office in the East Wing 1st floor. Thank you so much for your help! Best, Julia
Building Issue	FACREQ-1250	Increase Temperature	Done	West Wing	West Wing second floor temperature to be increased by +3 warmer. Zone 2w-41.
Building Issue	FACREQ-1255	EW/Carpenter Shop; see description	Done	East Wing	Hang 4 jumbos in the EW main entrance.
Building Issue	FACREQ-1257	EW / WW, Custodial Shop; see description	Done	West Wing	custodian shop to please check / clean all the windows in the east and west wings.
Building Issue	FACREQ-1258	EW / WW, Custodial Shop; see description	Done	East Wing	custodian shop to please check / clean all the windows in the east and west wings. Look a
Building Issue	FACREQ-1259	WW Elevator/Elevator Shop; see description	Done	West Wing	Fix the loud humming noise coming from the motor.
Building Issue	FACREQ-1262	EW 1st floor/Carpenter Shop; see description	Done	East Wing	Replace the ceiling tile in the east wing 1st floor visitors office. This work can be completed first thing this morning before the movers move the furniture back in.
Building Issue	FACREQ-1263	EW Rm 102	Done	East Wing	Replace the burnout light bulbs in the the east wing room 102. This work can be completed asap. Their phone number is 202-757-1359 OR 202-814-9854.
Building Issue	FACREQ-1266	POST A-4 COMMODE PRESSURE IS EXTREMELY LOW	Done	West Wing	please send some to repair
Building Issue	FACREQ-1273	To Check the W.W. Elevator Operation. - Assign to the 4 to 12	Done	West Wing	

Facility Request	FACREQ-1283	URGENT: Desk drawer is jammed	Done	East Wing	<p>Hello,</p> <p>Deesha Dyer's desk drawer is currently jammed and will not open. She sits in EW 212 and her assistant, Kayla Daniels, will assist in showing which drawer is broken. Kayla can be reached at 202.456.7585.</p> <p>Due to the high profile nature of this request, this needs to be completed by 10AM tomorrow August 25th.</p> <p>Thank you in advance for your assistance and promptness in dealing with this matter.</p> <p>All the best, Michael deForest</p>
Building Issue	FACREQ-1293	WW 1st floor Oval; paint the entire pantry	Done	West Wing	
Building Issue	FACREQ-1295	WW/Engineer Shop; AH #1/check the alarm	Done	West Wing	To Check the Alarm on the W.W. AH# 1. - Assign to the 4 to 12 Engineers (Billy)
Facility Request	FACREQ-1296	Removal of Roosevelt Room Table and Chairs Friday, August 26	Done	West Wing	<p>We need to have the Roosevelt Room table and chairs removed at 8 am on Friday, August 26 for a POTUS interview. The side armchairs and coffee table will need to be removed as well. We are able to leave the couch.</p> <p>We will need to put all the furniture back in at 1 pm the same day.</p>
Facility Request	FACREQ-1301	West Wing Lobby Closet Hooks	Done	West Wing	We would like to have a a set of hooks installed in the West Wing lobby closet. They should match the hooks that are currently installed accross the hall from the closet in the small pantry.

Building Issue	FACREQ-1302	EW Colonnade mat; place the carpet in the east wing landing by	Done	East Wing	
Building Issue	FACREQ-1303	WW 1st floor Oval Pantry; remove all the chair slides from the west wing 1st floor by	Done	East Wing	
Facility Request	FACREQ-1306	Please glue pannel back on WW Desk	Done	West Wing	<p>Hi Team,</p> <p>One of the panels on a desk riser came off in a move this morning. It is David Seidman's desk on the second floor of the West Wing. Please send someone to EEOB Room 1 and I will walk them over to resolve.</p> <p>I appreciate it! Michael deForest</p>
Building Issue	FACREQ-1311	Out of Control Fan	Done	West Wing	An AC unit fan in the White House basement press area (Fox News) is operating very loud at high speeds.
Facility Request	FACREQ-1314	Glass Top on Staff Sec Desk Needs Replacement	Done	West Wing	<p>Hi Team,</p> <p>The glass top on one of the desks in the Staff Sec office has broken and needs to be replaced. As this is a high priority request, please let me know a timeline so I can let the staff know.</p> <p>As always, thank you for your help! Michael deForest</p>
Building Issue	FACREQ-1315	WW 2nd floor & 1st floor; replace the burnt-out light bulbs	Done	West Wing	Replace the burnt-out light bulbs in the west wing 1st floor and the 2nd floor : room 216, 217, 215 the entire suite and also the hallway by the OOO.
Building Issue	FACREQ-1318	WW Rm 138W; paint the entire WW VIP	Done	West Wing	

Building Issue	FACREQ-1319	WW 1st floor above the door between the ladies and gentlemen	Done	West Wing	patch / paint above the door between the ladies and gentlemen bathrooms on the 1st floor behind the Roosevelt room
Building Issue	FACREQ-1321	WW/Ground Floor/Handicap stall/tolite tissue holder	Done	West Wing	
Facility Request	FACREQ-1331	Remove TV mount that is connected to desk	Done	West Wing	<p>Please *REMOVE * TV mount that is connected to desk. In WW Press Area.</p> <p>POC Contact Chip Somodevilla -202-468-3568</p> <p>Chip said he does not need to be there. Come when ever you can. Please drop TV mount and items to Taifa Coger's desk- NEOB-4th floor room 4208</p>
Facility Request	FACREQ-1332	Ceiling Light Out	Done	West Wing	In the back of the press room area (eating section) a ceiling light has been out for two weeks.
Building Issue	FACREQ-1342	WW/Engineer Shop; AHU #4; see description	Done	West Wing	(AHU #4 OA Damper replacement (Will require 6-8 hours shut down of #4 AHU) Damper and related materials to be ordered .
Building Issue	FACREQ-1344	WW/Electrical Shop; replace light, see	Done	West Wing	Replace the burnt-out lights in the west wing Press Briefing Break Room.
Building Issue	FACREQ-1353	WW ground floor/Electrical Shop; replace light; see description	Done	West Wing	Replace the burnt-out light bulb in the west wing ground floor Press Briefing Break Room
Building Issue	FACREQ-1358	WW 2nd floor 2 W - 45 zone	Done	West Wing	Turn down 2 degrees. Can you please let me know what's the set point is?
Building Issue	FACREQ-1359	WW 1st floor CoS hallway/Electrical Shop; replace light	Done	West Wing	Replace the burnt-out light bulb in the west wing 1st floor by CoS Office hallway.

Building Issue	FACREQ-1362	EW 2nd floor; replace the burnt-out light bulb in the east wing 2nd	Done	East Wing	
Building Issue	FACREQ-1365	EW rm. 200/ abate ants in drawer	Done	East Wing	
Building Issue	FACREQ-1366	EW near Uniform Division; ice maker is over heating, smell of	Done	East Wing	
Building Issue	FACREQ-1368	WH Press Area, near vending machine;	Done	West Wing	
Building Issue	FACREQ-1398	To Check the Alarm on the W.W. AH# 1. - Assign to the 4 to 12	Done	West Wing	
Building Issue	FACREQ-1407	unclog / fix the water leak coming from above the ceiling in the east wing 1st floor	Done	East Wing	
Building Issue	FACREQ-1408	FCU is in room 209 east wing 2nd floor.	Done	East Wing	
Building Issue	FACREQ-1409	FCU is in room 209 east wing 2nd floor.	Done	East Wing	remove ceiling tile
Building Issue	FACREQ-1410	electricians to replace the burnt-out light bulb in the west wing ground	Done	West Wing	
Building Issue	FACREQ-1412	SIT ROOM	Done	West Wing	RODENT PROBLEM
Building Issue	FACREQ-1413	WW 2nd floor room 202 / 203/ 205	Done	West Wing	landscape shop to check all the traps in the west wing 2nd floor council's office because they're smelling something funky or dead mouse.
Building Issue	FACREQ-1416	STEAM TRAP WENT BAD ON STEAM LINE MECHANICAL ROOM	Done	East Wing	
Building Issue	FACREQ-1440	electricians to replace the burnt-out light bulb in the east wing 1st	Done	East Wing	

Building Issue	FACREQ-1441	electricians to replace the burnt-out light bulb in the west wing ground	Done	West Wing	
Building Issue	FACREQ-1454	ZONE COS 1.5 DEGREE TURN UP	Done	West Wing	made adjustment BAS
Building Issue	FACREQ-1474	paint shop to patch / paint the west wing 1st	Done	West Wing	
Building Issue	FACREQ-1486	EW/Plumbing Shop; repair leak	Done	East Wing	Unclog / fix the water leak coming from above the ceiling in the east wing 1st floor legislative affairs office, which is on your left.
Building Issue	FACREQ-1487	EW/Engineer Shop; repair leak	Done	East Wing	FCU is in room 209 east wing 2nd floor\ on going 209 suite is done
Building Issue	FACREQ-1493	EW/Electrical Shop; light out	Done	East Wing	Replace couple of bad light bulbs in the east wing room 107 on the ground floor.
Building Issue	FACREQ-1494	EW/Engineer Shop; change filter in room	Done	East Wing	COMPLETE
Building Issue	FACREQ-1498	ZONE GW-6 RAISE TEMP 3 DEGREE	Done	West Wing	to cold we had to raise the set point
Building Issue	FACREQ-1501	East Wing E-116 landing mat	Done	East Wing	movers to store the large mat in the franconia storage place. This work need to be completed tomorrow morning between 10:25 am to 10:45 am. If you have any questions please call/email me.
Building Issue	FACREQ-1529	WW 1st floor Oval Pantry	Done	West Wing	paint shop to do some touch up work in the west wing 1st floor Oval Pantry door and by the sink counter on your left wall. Also the main entrance wall as you walk thru the canopy around the seal.
Building Issue	FACREQ-1530	WW VIP Lobby and Roosevelt room	Done	West Wing	Hang coat Hangers in the VIP Lobby closet also take a look at this door thrush hold in the west wing 1st floor Roosevelt room.

Building Issue	FACREQ-1537	East Wing Tour Office Air Conditioning	Done	East Wing	East Wing Tour Office Air Conditioning is not working. CHANGE FILTERS AND CONDENSATE DRAIN LINE WAS CLOGGED
Building Issue	FACREQ-1551	Ms. Jarrett's Office Move	Done	West Wing	Hi Team, I need 2 movers in EEOB Room 1 at 2:00PM today. We will be bringing a credenza over to the West Wing for Ms. Jarrett. Thanks! Michael deForest
Building Issue	FACREQ-1557	Please turn temperature up 1.5 degrees higher - Zone	Done	West Wing	Complete
Building Issue	FACREQ-1560	East Wing for the Squad Room had a unit leak in the ceiling and need ceiling tie need to	Done	East Wing	
Building Issue	FACREQ-1564	To Clean up a Flood in the W1 Mechanical Space by the RO	Done	West Wing	Assign to the 4 to 12 Shift Engineers (Billy).
Building Issue	FACREQ-1568	EW Colonnade/Custodial Shop; clean EW Colonnade	Done	East Wing	Please clean the entire east wing colonnade. Let me know when you have completed this request? If you want you can do this job this morning because there are no tours this morning.
Building Issue	FACREQ-1569	EW 1st floor landing/Electrical Shop;	Done	East Wing	Replace the burnt-out light bulb in the east wing 1st floor landing.
Building Issue	FACREQ-1570	WW ground floor NM/Paint Shop; touch	Done	West Wing	Touch ups in the west wing ground floor by the entrance to the Navy mess kitchen.
Building Issue	FACREQ-1571	WW 1st floor Oval Hallway	Done	West Wing	Replace the burnt-out light bulb in the west wing 1st floor by Roosevelt room entrance and the Oval hallway.

Building Issue	FACREQ-1579	PRESS POOL BASEMENT DOOR	Done	West Wing	LOCK NOT FUNCTIONING PROPERLY
Building Issue	FACREQ-1580	carpenters to fix the loose door latch / hook which is in the west wing by the main	Done	West Wing	
Building Issue	FACREQ-1584	engineers to check and fix the FCU in the east wing 2nd floor room	Done	East Wing	DONE WE HAD TO REPLACE MOTOR
Building Issue	FACREQ-1599	To Check and Open the Door in the W.W. Press area that goes	Done	West Wing	Assign to the 4 to 12 Shift Engineers (Billy)
Building Issue	FACREQ-1600	please insulate the open chill water pipeline. This is in the east wing basement by	Done	East Wing	insulate chill water pipe
Building Issue	FACREQ-1624	WW 2nd floor room 208.	Done	West Wing	paint shop to do touch ups in the west wing 2nd floor room 208. This is between the two windows.
Building Issue	FACREQ-1635	Cabinet Room Drapes	Done	West Wing	The drape rod on the far right window covering has become disconnected. There is also in issue with one of the finials on the same window. Please have these issues repaired.
Facility Request	FACREQ-1636	Move Cabinet Part to Trash	Done	West Wing	Please move this spare cabinet part to the trash in the EEOB North Courtyard The piece is located on the Ground Floor of the West Wing, in the back copier area.

Building Issue	FACREQ-1643	desk drawers in OLA	Done	East Wing	<p>Hello,</p> <p>The left side and center drawers in Kimberly Young's desk are sticking / hard to open and close. Could a carpenter come by to loosen them up?</p> <p>Kimberly sits in the Office of Legislative Affairs suite on the first floor of the East Wing. Her desk is in the back right corner of the large common office on the right hand side of the suite. It is under a window that faces the south grounds. The phone will have extension 6-3149. We would love to have her desk working smoothly by the end of the week.</p> <p>Thanks for your help- please let me know if you have any questions.</p> <p>Julia</p>
Building Issue	FACREQ-1652	EW VENT DIRTY	Done	East Wing	DONE THIS JOB IS COMPLETE
Building Issue	FACREQ-1653	EW CLEAN VENTS	Done	East Wing	FIRST LADY OFFICE had to clean fan coil vents
Building Issue	FACREQ-1655	Removal of Roosevelt Room Table and Chairs Friday, September 16	Done	West Wing	<p>We need to have the Roosevelt Room table and chairs removed at 12:30 pm on Friday, September 16. The side armchairs and coffee table will need to be removed as well. We are able to leave the couch.</p> <p>We will need to put all the furniture back in at 5:30 pm the same day.</p>
Facility Request	FACREQ-1668	ROTUS Desk Retractable Monitor	Done	West Wing	

Facility Request	FACREQ-1676	Replace glass on the COS desk	Done	West Wing	<p>Hello, The glass in the COS desk has been cracked. Please tape the crack and measure for new glass on 9/16 at 6:30 AM. Please order new glass and replace the old once the new has been delivered. All work should take place either before 8:00 AM or after the COS has left for the day.</p> <p>Thank you, Julia</p>
Building Issue	FACREQ-1689	WW ground floor NM/Electrical Shop;	Done	West Wing	Replace the burnt-out light bulb in the west wing ground floor big dinning room.
Building Issue	FACREQ-1695	To Check and Monitor the W1 RO System Operations.	Done	West Wing	- Assign to the 4 to 12 Shift Engineers (Billy)
Building Issue	FACREQ-1700	To Look for / Catch a Mouse in the W.W. of Valerie Jarrett Office.	Done	West Wing	Assign to the 4 to 12 Shift Engineers (Billy)
Building Issue	FACREQ-1701	To Check the E.W. RO System from Bunker	Done	East Wing	Assign to the 4 to 12 Shift Engineers (Billy)
Building Issue	FACREQ-1736	Please replace light in OLA	Done	East Wing	<p>Hello, Two overhead fluorescent lights havestarted flickering in the big office on the left (East) side of the OLA suite on the first floor of the East Wing. Could these bulbs be replaced tonight or tomorrow morning?</p> <p>Thanks, Julia</p>
Facility Request	FACREQ-1744	Chairs in East Reception Room	Done	East Wing	East reception room meeting at 1030am needs 10 chairs
Building Issue	FACREQ-1750	EW 1st floor	Done	East Wing	carpenters to replace the damage ceiling tiles in the east wing 1st floor Visitors office.

Building Issue	FACREQ-1755	WW 2nd floor room 221 windows	Done	West Wing	paint shop to do some touch up work in the west wing 2nd floor room 221
Building Issue	FACREQ-1757	WW 2nd floor room 220	Done	East Wing	carpenters to cover the opening in room 220 west wing 2nd floor. This is underneath the window.
Building Issue	FACREQ-1758	WW 1st floor Oval Pantry hallway	Done	West Wing	paint shop to do touch ups in the west wing 1st floor by Oval pantry hallway.
Building Issue	FACREQ-1760	EW Lobby stairs	Done	East Wing	Please remove the residue from the stairs in the EW lobby
Building Issue	FACREQ-1761	Touch up paint	Done	West Wing	Paint needs touched up on the wall going up the steps in the WW due to scratches on the wall from the Jumbos.
Building Issue	FACREQ-1783	WW 2nd floor room 220	Done	West Wing	paint shop to patch the open hole in the west wing 2nd floor room 220. This is underneath the window.
Building Issue	FACREQ-1784	WW 1st floor VIP Lobby entrance	Done	West Wing	paint shop to do some touch up work in the west wing 1st floor by VIP Lobby door entrance from the NSA office hallway.
Building Issue	FACREQ-1785	WW 1st floor VIP Lobby	Done	West Wing	landscape shop to treat for Mosquitoes in the west wing 1st floor VIP Lobby Foyer
Building Issue	FACREQ-1791	WW 2nd floor	Done	West Wing	carpenters to fill the open hole in the west wing 2nd floor room 212.
Building Issue	FACREQ-1798	paint shop to do some touch up work in the west wing W - 16 steps hallway and up to the	Done	West Wing	
Building Issue	FACREQ-1799	To Swap 2 Air Vent Screen in the W.W. as Requested by	Done	West Wing	Assign to the 4 to 12 Shift Engineers (Billy)
Building Issue	FACREQ-1814	Light Bulb Out	Done	West Wing	light bulb replacement in booth CNN white house basement 202 898 7900 kevin
Building Issue	FACREQ-1820	To Check for a Mouse in the W.W. COS	Done	West Wing	Assign to the 4 to 12 Shift Engineers (Billy)

Building Issue	FACREQ-1835	Outlet and Light Bulbs White Press Basement	Done	West Wing	Jon Decker 202-628-0790 basement level white house press area, McClatchy News power outlet doesn't work. Light bulb in Fox News radio booth needs to be replaced for light switch above the computer monitor.
Building Issue	FACREQ-1838	EW/Electrical Shop; light out	Done	East Wing	Replace the burnt-out light bulbs in the east wing 2nd floor hallway.
Building Issue	FACREQ-1841	EW/Carpenter Shop/Visitor's Office	Done	East Wing	Replace the damage ceiling tiles in the east wing 1st floor Visitors office.
Facility Request	FACREQ-1846	USSS to have a cable pulled in W-16	Done	West Wing	
Building Issue	FACREQ-1852	Check is the Chill Water Valves for the W.W. Press Area HVAC Systems, for the	Done	West Wing	Assign to the 4 to 12 Shift Engineers (Billy)
Building Issue	FACREQ-1875	EW Colonnade/Move Shop; move mats	Done	East Wing	Place the mats down because it's going to rain tonight and tomorrow morning.
Building Issue	FACREQ-1876	EW/WW/Custodial Shop; clean hand sanitizers	Done	East Wing	Clean all the east and west wings hand sanitizer standards? Let me know when you have completed this request?
Building Issue	FACREQ-1877	EW/WW/Custodial Shop; clean hand sanitizers	Done	West Wing	Clean all the east and west wings hand sanitizer standards? Let me know when you have completed this request?
Building Issue	FACREQ-1878	WW/CNN Booth; light out	Done	West Wing	
Building Issue	FACREQ-1882	WW ground floor NM	Done	West Wing	Replace the burnt-out light bulb in the west wing ground floor wardrobe.
Building Issue	FACREQ-1885	WW/Elevator Shop; elevator inoperable	Done	West Wing	W-1 Fright Elevator is broken.

Building Issue	FACREQ-1887	WW/Engineer Shop; Contractor support	Done	West Wing	1st Work Order - To Support the Contractor for the W.W. Press Chill Water and the W.W. Domestic Hot Water Outages. - Assign to the 4 to 12 Shift Engineers (Billy)
Building Issue	FACREQ-1893	To Support the Contractor for the W.W. Press Chill Water	Done	West Wing	and the W.W. Domestic Hot Water Outages. - Assign to the 4 to 12 Shift Engineers (Billy)
Building Issue	FACREQ-1894	WW/Engineer Shop; 2W-50, raise	Done	West Wing	
Building Issue	FACREQ-1902	engineers to check and test RO treatment	Done	West Wing	
Building Issue	FACREQ-1905	engineers to check and test RO treatment	Done	East Wing	
Building Issue	FACREQ-1909	paint shop to do touch ups in the west wing ground and 1st floors,	Done	West Wing	
Building Issue	FACREQ-1910	paint shop to do touch ups in the west wing 1st floor by VIP Lobby	Done	West Wing	
Building Issue	FACREQ-1911	paint shop to do touch ups in the west wing ground floor all the	Done	West Wing	
Building Issue	FACREQ-1912	paint shop to do touch ups in the west wing 1st floor by Roosevelt	Done	West Wing	
Building Issue	FACREQ-1913	electricians to replace burnt-out light bulbs in the east wing driveway before entering the east	Done	East Wing	Also to clean all the chandeliers.EW / WW
Facility Request	FACREQ-1920	remove Armoire from office	Done	East Wing	Armoire has mold growing in it

Facility Request	FACREQ-1922	Roosevelt Room Table Removal 9/28/16	Done	West Wing	<p>Hi team,</p> <p>The Roosevelt Room table needs to be removed tomorrow, September 28 at 10:00am. Additionally, it will need to be replaced from 12:30pm to 1:00pm to allow for the next meeting.</p> <p>Please let me know if there is anything I can do to assist.</p> <p>Thanks!</p> <p>Michael deForest</p>
Building Issue	FACREQ-1931	WW LOWER LEVEL LADIES ROOM HANDICAP BUTTON	Done	West Wing	
Building Issue	FACREQ-1944	WW VIP Lobby Closet	Done	West Wing	<p>movers to move all the furniture from the VIP Lobby closet on Friday evening at 6:00 pm to the west wing wardrobe and return it back on Monday morning at 7:00 am.</p>

Building Issue	FACREQ-1956	WW/EW cleaning	Done	West Wing	<p>During our walk through on Monday we identified several areas where the cleaning is being neglected in the WW and EW. Can we please come up with a plan as to how these areas will be addressed moving forward.</p> <p>*Spider webs in corners and on chandeliers in EW lobby *Baseboards throughout both EW and WW have a thick layer of dust on them *Brass corner guards and kick plates are not being fully polished *Dust louvers on wooden doors *Carpet has a 2" line along the edge of the base board in the WW from the carpet cleaning.</p>
Building Issue	FACREQ-1972	Raise the Temperature up 2 Degrees in the W.W. Zone# GW-07	Done	West Wing	Assign to the 4 to 12 Shift Engineers (Billy)
Building Issue	FACREQ-1976	WW 1st floor hallway 155	Done	West Wing	paint shop to do some touch up work in the west wing 1st floor, this is just before you enter the VIP Lobby from the steps and the hallway 155.
Building Issue	FACREQ-1977	EW 2nd floor room 206	Done	East Wing	paint shop to patch / touch up around the window. This work can be completed after hours. This is in the east wing 2nd floor room 206.
Building Issue	FACREQ-1981	landscape shop to please place more traps in the east wing	Done	East Wing	
Building Issue	FACREQ-1983	EW 1st floor hallway/Electrical Shop;	Done	East Wing	Replace the burnt-out light bulb in the east wing 1st floor hallway by room 103
Building Issue	FACREQ-1989	WW 1st floor Press Secretary's office/Electrical Shop;	Done	West Wing	check / fix the chandeliers light switch is not working. This work can be completed after hours please.

Building Issue	FACREQ-1991	engineers to check and clean all the FCU covers, in the east and west wings, before it	Done	West Wing	
Building Issue	FACREQ-1992	Replace all of the Existing Drains in all of the 2nd Floor Fan Coils Units in the East Wing.	Done	East Wing	Assign to the 4 to 12 Shift Engineers (Billy) Note - This is a Ongoing Job that will take a Month or Longer.
Building Issue	FACREQ-1995	WW ZONE 2W-45 MAKE WARMER 1.5	Done	West Wing	
Building Issue	FACREQ-1997	carpenters to replace all the weather strip in the west wing ground	Done	West Wing	
Building Issue	FACREQ-2027	WW ground floor	Done	West Wing	landscape shop to treat for ants in the west wing ground floor navy mess kitchen office, storage shelf. Also please place more traps in all 3 dinning rooms.
Building Issue	FACREQ-2029	landscape shop to place more mouse traps in the west wing 2nd floor room 223 and	Done	West Wing	
Building Issue	FACREQ-2032	WW Domestic Water	Done	West Wing	To Post Signs on all of the Men and Women Room in the W.W. for the Domestic Water Outage, and to Notify the Sit Room of the Water Outage. -
Building Issue	FACREQ-2049	WW VP OFFICE	Done	West Wing	REST ROOM COMMODE CLOGGED
Building Issue	FACREQ-2060	WW ZONE W2-44 & W2-43 TOO COLD	Done	West Wing	
Building Issue	FACREQ-2063	In the downstairs West Wing bathroom,	Done	East Wing	"both the urinals are leaking so there's either water or piss everywhere on the floor."

Building Issue	FACREQ-2075	EW/WW/Custodial Shop/clean windows, chandelier	Done	West Wing	Clean all the east and west wings windows from inside and outside. Also we noticed cobwebs every window and chandelier. I took care of some of this cobwebs in our walk thru this morning.
Building Issue	FACREQ-2076	CLONE - EW/WW/Custodial Shop/clean windows, chandelier	Done	East Wing	Clean all the east and west wings windows from inside and outside. Also we noticed cobwebs every window and chandelier. I took care of some of this cobwebs in our walk thru this morning.
Building Issue	FACREQ-2112	To Raise the Temperature in the W.W. Zone# 43 and	Done	West Wing	- Assign to the 4 to 12 Shift Engineers
Building Issue	FACREQ-2113	To Check and Running Urinal in the W.W. on the Ground Floor as	Done	West Wing	Assign to the 4 to 12 Shift Engineers (Billy)
Building Issue	FACREQ-2115	To Check the Alarm on the E.W. ET-5	Done	East Wing	Assign to the 4 to 12 Shift Engineers (Billy)
Building Issue	FACREQ-2120	WW ground floor navy mess	Done	West Wing	plumbers to fix the leaky value in the west wing ground floor navy mess kitchen.
Facility Request	FACREQ-2129	Laptop Shelf	Done	West Wing	Completion of ticket 582 from FY16 - installation of laptop shelf constructed with FY16 funding; labor for installation remaining - contact JD Fuchs to coordinate installation date and time
Facility Request	FACREQ-2140	Metal Phone Bracket	Done	West Wing	A metal phone bracket is required to assist with the installation of a phone in the two phone booths within the WHSR; contact JD Fuchs to schedule a time to review the requirement and take measurements for the bracket
Building Issue	FACREQ-2147	paint shop to paint all the baseboards in the west wing ground floor	Done	West Wing	As you can see in some areas the paint is darker then the original paint

Building Issue	FACREQ-2157	WW/Carpenter Shop; repair/replace door stopper	Done	West Wing	take a look at a door stopper in the WW near Echo 1, its the door for the photographic room right past men's bathroom on the ground floor. Contact Robert Byrd for details. Stopper was getting stuck down.
Facility Request	FACREQ-2159	B14 ELECTRIC STRIKE NOT	Done	East Wing	
Building Issue	FACREQ-2166	paint the wall where the seal is just after you enter the west wing	Done	West Wing	
Building Issue	FACREQ-2167	paint the entire baseboards. Looks like	Done	West Wing	
Building Issue	FACREQ-2168	paint shop to do some touch up work in the west wing ground floor stairway by the elevator	Done	West Wing	
Building Issue	FACREQ-2181	EW/Move Shop; move mats	Done	East Wing	Move all the mats from the east wing colonnade to the basement.
Facility Request	FACREQ-2200	Door Hinge - WHSR	Done	West Wing	Replace broken hinge that was removed during the recent WHSR modifications; contact Stephanie Raymond to coordinate an installation date
Building Issue	FACREQ-2204	Touch Up Paint OVAL Office	Done	West Wing	Touch up paint on door jamb and door surround by post E6 This is the 3rd time on the walk through list!
Building Issue	FACREQ-2205	Touch Up Paint Oval Office	Done	West Wing	Touch up paint on door jamb and door surround by post E6 This is the 3rd time on the walk through list!
Building Issue	FACREQ-2206	WW/VIP Lobby/Custodial Shop; see description	Done	West Wing	Tuck plastic trash can liner in so not to be visible
Building Issue	FACREQ-2207	WW/EW/Custodial Shop; general clean	Done	West Wing	

Building Issue	FACREQ-2208	WW/EW-VIP Lobby; general clean all	Done	East Wing	
Building Issue	FACREQ-2209	WW/Ground/Oval; Custodial Shop; see description	Done	West Wing	Ground/OVAL Ante Room; There is paint on the door edge of door leading to the men's and ladies room complete by 10/14/16
Building Issue	FACREQ-2210	WW/Ground/Lower Entrance; see description	Done	West Wing	Polish all brass Daily and monitored several times throughout the day on 10/18/16
Building Issue	FACREQ-2211	Ground/West Wing Lower Entrance	Done	West Wing	Remove umbrella stand and bag stand morning of arrival 10/18/16 (weather permitting)
Building Issue	FACREQ-2212	Ground/West Wing Lower Entrance	Done	West Wing	Remove signs morning of arrival 10/18/16 (weather permitting)
Building Issue	FACREQ-2213	Ground/West Wing Lower Entrance	Done	West Wing	Polish brass hinges on doors monthly and complete by 10/17/16
Building Issue	FACREQ-2214	Shelf Installation Oval Office	Done	West Wing	Install corner shelves each side of sink area. Repair by 10/14/16 if possible.
Building Issue	FACREQ-2215	Ground/West Wing Lower Entrance	Done	West Wing	Clean speaker box (on marble post above the handicap push sign) monthly and complete by 10/17/16
Building Issue	FACREQ-2216	Light Switch Cover Oval Office	Done	West Wing	Wall light switch plate with 4 switches is missing a screw and consider replacing this panel.
Building Issue	FACREQ-2217	Ground/West Wing Lower Entrance/Custodial	Done	West Wing	Clean Globes monthly and complete by 10/17/16

Building Issue	FACREQ-2218	Ground/West Wing Lower Entrance/Custodial	Done	West Wing	Adjust rug at lower WW entrance. Shift North and West! ASAP
Building Issue	FACREQ-2219	Ground/Navy Mess Entrance/Custodial Shop	Done	West Wing	Clean the base of the purell stand at Navy Mess entrance Daily and monitored several times throughout the day on 10/18/16
Building Issue	FACREQ-2220	Corner Guard Oval Office Dining Room	Done	West Wing	Install wall corner guard in mess pantry. Coordinate with Navy Mess staff.
Building Issue	FACREQ-2221	Ground/Post E1/Custodial Shop	Done	West Wing	Clean ceiling black mark ASAP
Building Issue	FACREQ-2222	Corner Shelves Sink Area Oval Office Dining Room	Done	West Wing	Install corner shelves each side of sink area. Coordinate with Navy Mess staff.
Building Issue	FACREQ-2223	Ground/Lower Level/Custodial Shop	Done	West Wing	Clean carpet; Schedule no later than 10/16/16
Building Issue	FACREQ-2224	Touch Up Pantry Door Oval Office Dining	Done	West Wing	Touch up pantry door. Coordinate with Navy Mess staff.
Building Issue	FACREQ-2225	Plexiglas Kick Plate Oval Office Dining	Done	West Wing	Consider adding a Plexiglas kick plate to the pantry door. Coordinate with Navy Mess staff.
Building Issue	FACREQ-2226	Door Touch Ups Oval Roosevelt Room	Done	West Wing	Door surround left and right panels need touch ups (near E6).
Building Issue	FACREQ-2227	Blub Out on Sconce Near Roosevelt Room	Done	West Wing	Blub Out on Sconce Right of Roosevelt Room near post E6.
Building Issue	FACREQ-2228	Peeling Paint Oval Post E6 Door	Done	West Wing	the scalloped area above the doorway facing north has peeling paint on the right side

Building Issue	FACREQ-2229	Patching and Painting Electrical Box Upper Level WH	Done	West Wing	Electric panel box to the right of the ladies room needs patching and painting.
Building Issue	FACREQ-2230	Remove Umbrella Stand Upper Level WW	Done	West Wing	Day of 10/18/16 remove umbrella bag stands/umbrella stand.
Building Issue	FACREQ-2231	Disable Air Curtain Rose Garden Doors	Done	West Wing	Disable Air Curtain Rose Garden Doors 10/18/2016.
Building Issue	FACREQ-2232	WW/Lower Lever/Custodial Shop; clean carpet	Done	West Wing	Lower Level/Clean carpet Schedule no later than 10/16/16
Building Issue	FACREQ-2233	Clean Wall Sconce and Ceiling Globes	Done	West Wing	West Wing VIP Lobby Clean wall sconce and ceiling globes
Building Issue	FACREQ-2234	Clean Lamp Shade and Glass Tops Upper Level WW	Done	West Wing	Clean lamp shade interiors on credenza with Lincoln Bust. Also ensure glass tops are fingerprint free by 10/14/2016.
Building Issue	FACREQ-2235	WW/Ground FI/Lower Level; clean chair arm covers	Done	West Wing	Ground/Lower Level; have all chair arm covers dry cleaned by 10/17/16
Building Issue	FACREQ-2236	Clean Marks Upper Level WW	Done	West Wing	Clean marks between the Rockwell paintings ASAP.
Building Issue	FACREQ-2237	WW/Ground Lower Level/Custodial Shop	Done	West Wing	Ensure all brass corner guards are cleaned from top to bottom. Focus on the ends! Daily and monitored several times throughout the day on 10/18/16
Building Issue	FACREQ-2238	WW/Ground FI/Lower Level/Paint Shop; paint & patch	Done	West Wing	Patch and paint area between the 4 jumbos to the right of the photo office by 10/17/16

Building Issue	FACREQ-2251	CLONE - Peeling Paint Oval Post E6 Door	Done	West Wing	the scalloped area above the doorway facing north has peeling paint on the right side
Building Issue	FACREQ-2255	East Wing room 200 CoS Office	Done	East Wing	movers to move the safe and place it back after the engineers finish working on the FCU. This work is scheduled for 10/12/2016 to remove the FCU at 9:30 pm and to reinstall the FCU back on 10/14/2016 at 9:30 pm.
Building Issue	FACREQ-2257	WW 1st floor Oval Pantry	Done	West Wing	paint shop to please take a closer look at this picture and paint the entire door, also the Navy mess hallway baseboard.
Building Issue	FACREQ-2259	WW ground floor	Done	West Wing	landscape shop to treat for flies in the west wing ground floor suite. Check above the ceiling
Building Issue	FACREQ-2260	EW 1st floor landing/Paint Shop; see description	Done	East Wing	Take care of this painted over the wooden rail. This is by the elevator steps. Let me know when you have completed this request?
Building Issue	FACREQ-2261	West Wing all levels Clean all tops above	Done	West Wing	
Building Issue	FACREQ-2262	West Wing all levels clean and wipe down	Done	West Wing	
Building Issue	FACREQ-2263	West Wing Upper level replace or clean ceiling vents above staircase	Done	West Wing	
Building Issue	FACREQ-2264	West Wing all levels vacuum under all chair and couch cushions	Done	West Wing	
Building Issue	FACREQ-2265	West Wing Upper level Ante room near OOO touch up credenzas	Done	West Wing	
Building Issue	FACREQ-2267	West Wing all levels remove all wall marks/black marks (use	Done	West Wing	Daily and monitored several times throughout the day on 10/18/16

Building Issue	FACREQ-2268	Ground East Visitors Entrance Remove	Done	East Wing	Morning of 10/18/16 weather permitting
Building Issue	FACREQ-2269	Ground East Visitors Entrance Clean Exterior and Interior	Done	East Wing	Daily and monitored several times throughout the day on 10/18/16
Building Issue	FACREQ-2270	Ground East Visitors Entrance Clean brass	Done	East Wing	Should be done weekly!
Building Issue	FACREQ-2271	Ground East Visitors Entrance and landing Extract carpet at East Visitors entrance and	Done	East Wing	Clean overnight 10/16/16 and spot check through 10/18/16
Building Issue	FACREQ-2272	Ground East Visitors Entrance and East Garden landing Clean	Done	East Wing	Clean between 10/14/16 and 10/117/16
Building Issue	FACREQ-2273	Ground East Colonnade Clean glass	Done	East Wing	Clean between 10/14/16 and 10/117/16
Building Issue	FACREQ-2274	Ground East Colonnade Clean	Done	East Wing	Clean between 10/14/16 and 10/117/16
Building Issue	FACREQ-2275	Ground East Colonnade Polish and	Done	East Wing	Clean overnight 10/16/16 to 10/17/16
Building Issue	FACREQ-2276	Ground East Colonnade Polish kick plates on all East	Done	East Wing	Schedule date to clean and monitor until gates open for arrival ceremony
Building Issue	FACREQ-2277	Ground East Colonnade Wipe down and touch up all walls	Done	East Wing	daily and special attention 10/17/16 and 10/18/16
Building Issue	FACREQ-2278	West Wing all levels ensure that all brass push plates and kick	Done	West Wing	Daily and monitored several times throughout the day on 10/18/16
Building Issue	FACREQ-2279	Ground East Visitors Entrance and landing Extract carpet at East Visitors entrance and	Done	East Wing	Extract carpet at East Visitors entrance and East Landing Clean overnight 10/16/16 and spot check through 10/18/16
Building Issue	FACREQ-2291	WW/Carpenter Shop; repair door latch	Done	West Wing	

Building Issue	FACREQ-2296	EW 1st floor OLA Room E - 130	Done	East Wing	Replace the broken light switch. Let me know when you have completed this job? This work can be completed after hours please.
Building Issue	FACREQ-2297	WW ground floor	Done	West Wing	Clean all the light fixtures in the west wing ground floor by navy mess carry out window. Also the light fixtures behind the Oval hallway and east wing colonnade from inside and outside the main entrance. Let me know when you have completed this request?
Building Issue	FACREQ-2300	EW E1-11 & E1-12	Done	East Wing	Done
Building Issue	FACREQ-2301	West Wing Lobby Elevator	Done	West Wing	Malfunction: Lt. Williams advises that a passholder notified UD that the elevator is malfunctioning. She was stuck in the elevator for several minutes and when she pushed the alarm button nothing happened. After trying to replicate the problem, Lt. Williams advises that when the Alarm button is depressed it does not work. However, when the Help button is pushed it calls the JOC. Please fix the Alarm button.

Facility Request	FACREQ-2311	hang jumbo in Josh Earnest's Office	Done	West Wing	<p>Hello,</p> <p>Please hang a jumbo centered above the fire place in Josh Earnest's office. The jumbo and frame are in the office now. This work needs to be completed before 8:30 AM on Friday, 10/14/2016 so that the jumbo can be displayed during a special event that morning.</p> <p>F1581324/WHO</p> <p>Thanks, Julia</p>
Building Issue	FACREQ-2313	Elevator Door Malfunction WW Lower Level	Done	West Wing	Elevator doors have been opening and closing by themselves at West Wing lower level
Building Issue	FACREQ-2319	RO system in the east wing has a valve that	Done	East Wing	
Building Issue	FACREQ-2323	engineers to check RO system, contact Robert	Done	West Wing	Done
Building Issue	FACREQ-2326	Broken woman's toilet in WH press room	Done	West Wing	Toilet in the back room of the press room does not flush
Facility Request	FACREQ-2331	Estimate for CoS Office	Done	West Wing	<p>Along the south wall of room 122, request an estimate for the following work:</p> <ol style="list-style-type: none"> 1. Ground and wrap (insulate) pipe extending up from the floor 2. Add insulation into the baseboard cable tray 3. Secure the baseboard cable tray closed <p>Contact Stephanie Raymond to coordinate access for scope review; estimate requested by COB October 21st</p>

Building Issue	FACREQ-2340	paint shop to do touch ups in the west wing ground floor NSC	Done	West Wing	
Building Issue	FACREQ-2342	electricians to replace the burnt-out light bulb in the east wing 1st	Done	East Wing	
Building Issue	FACREQ-2343	engineers to please check and pick up if there's a mouse got in	Done	West Wing	done
Building Issue	FACREQ-2344	EW 1st floor OLA Room 130, 132	Done	East Wing	Please place more ant traps and be more aggressive. The ants are all over her desk, phone and computer. She is not happy and she might reach out to OA and WH. It's been going for long periods. Please keep me posted.
Building Issue	FACREQ-2345	EW 2nd floor	Done	East Wing	paint shop to do touch up work above FCU in the east wing 2nd floor rooms 208, 206, 209, 212 and 211, also above the FCU between the ladies and gentlemen bathrooms on the 2nd floor hallway in the east wing. Rooms 206 / 208 let me know the time when you want me to schedule this work?
Building Issue	FACREQ-2347	WW/Electrical Shop; fuse blown, lights out at Post Echo 1 Entrance	Done	West Wing	
Building Issue	FACREQ-2352	WW 1st Floor E - 10 Post/Engineer Shop; fan	Done	West Wing	Turn off the door fan by E - 10 post. This work can be completed after 9 : 30 pm tonight and turn it back on tomorrow night at 9 : 30 pm. The switch is above the door ceiling. DONE

Building Issue	FACREQ-2353	WW Ground Floor/1st Floor/Move Shop	Done	West Wing	Move all the umbrella standards from the ground floor and 1st floors VIP Lobby, to the ground floor by the copier machine. This work can be completed after 6 : 00 pm tonight and return it back Thursday evening after 6:00 pm
Building Issue	FACREQ-2378	replace the switch plates at the Oval and Roosevelt room by getting two (2) plates	Done	West Wing	
Building Issue	FACREQ-2407	EW 1st floor OLA Room 130, 132	Done	East Wing	Please place more ant traps and be more aggressive. The ants are all over her desk, phone and computer. She is not happy and she might reach out to OA and WH. It's been going for long periods. Please keep me posted.
Building Issue	FACREQ-2413	plumbers to schedule the clean out the underfloor sink trap this Saturday, morning	Done	West Wing	There is a noticeable odor developing.

Building Issue	FACREQ-2420	Add Removeable Pins on office windows to be able to open windows freely	Done	East Wing	<p>Can I please submit a request to add 5 sets of removable pins to the windows in Mr. Kern and Cap Walsh's offices?</p> <p>The offices are located in EW Suite 208. Pins must be removable in nature to allow for windows to be open and closed in an emergency situation.</p> <p>Please let me know if I provided sufficient justification or additional information is required.</p> <p>Thank you, Shirley</p> <p>Shirley Lopez Special Security Officer White House Military Office 202-757-1469 (O) 202-814-9414 (C)</p>
Building Issue	FACREQ-2426	WW 2nd floor	Done	West Wing	electricians to replace the burnt-out light bulb in the west wing 2nd floor hallway by the elevator.
Building Issue	FACREQ-2429	WW 1st floor E - 10 post	Done	West Wing	Please turn the west wing 1st floor E - 10 post overhead fan blower back on.
Building Issue	FACREQ-2452	Lower Temperature in WW Lower Press	Done	West Wing	Lower the temperature by two degrees in zones PR 1-4.
Building Issue	FACREQ-2454	WW-NM/Paint Shop; seal holes	Done	West Wing	Seal all the opening/holes in the west wing navy mess. Let me know when you have completed this request.

Building Issue	FACREQ-2455	EW 1st floor OLA/Custodial Shop & Pest Shop; clean & treat	Done	East Wing	Get rid of couple of spiders on top of the windows. Billy - treat for red ants and spiders. Let me know when you have completed this request?
Building Issue	FACREQ-2456	EW 1st floor OLA/Custodial Shop & Pest Shop; clean & treat	Done	East Wing	Get rid of couple of spiders on top of the windows. Billy - treat for red ants and spiders. Let me know when you have completed this request?
Building Issue	FACREQ-2458	EW/Carpenter Shop; repair molding	Done	East Wing	This ticket is for the carpenters to check / fix the loose molding in the east wing main entrance foyer. If you have any questions about this request please contact me. This work can be completed any time after hours or weekends. Saturday it will be after tours.
Building Issue	FACREQ-2460	movers to lay down all the east wing colonnade mats. This work can be completed	Done	East Wing	already 10/20/16
Building Issue	FACREQ-2461	WW 2nd Floor/Electrical Shop/replace light	Done	West Wing	Replace the burnt-out light bulb in the west wing 2nd floor hallway by the elevator. Let me know when you have completed this job?

Building Issue	FACREQ-2484	ESTIMATE ONLY Director Gym	Done	East Wing	<p>David,</p> <p>Can we link up today, with your projects people and do a walkthrough of the space we discussed last week in the east wing?</p> <p>Here is a quick rundown of what we want to do with the space.</p> <ul style="list-style-type: none"> - The doors, and possibly the frames replaced. (I don't have a warm fuzzy on what type or style of door the customer wants so let's just get a price on a solid wood door) - The ceiling grid raised to give the room as much height as possible. (this may require some suppression system work, we will have to take a look) - The walls painted. Ideally, they would be presidential blue with a white 4 inch cove base (alternative would be a painted four inch integral cove) - The HVAC control (thermostat) updated and user friendly as well. - We would also like the get a motion sensor installed for the room lights.
----------------	-----------------------------	-------------------------------	------	-----------	-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Facility Request	FACREQ-2488	RR Table Removal	Done	West Wing	Hi team, The Roosevelt Room table needs to be removed today, October 24 at 3:00PM. Additionally, it will need to be replaced at 5:15PM after POTUS' taping is complete. Please let me know if there is anything I can do to assist. Thanks! Michael deForest
Building Issue	FACREQ-2489	WW 1st floor ladies room commode keeps running and handle	Done	West Wing	
Building Issue	FACREQ-2543	WW/WHSR Conference Rooms/Electrical Shop; replace lights	Done	West Wing	Replace all the light bulbs which are the wrong color in the WHSR for tonight after hours please. Also please pickup all the boxes with the wrong color bulbs in it.
Building Issue	FACREQ-2556	Too Cold East Wing Rm 111	Done	East Wing	East Wing 111 zone E Louis Johnson 66401 adjust t stat raise temp
Building Issue	FACREQ-2573	To Check a Broken Tour Sign at the W.W. that was Reported by	Done	West Wing	Assign to the 4 to 12 Shift Engineer - (Billy)
Building Issue	FACREQ-2594	ZONE E1-12 INCREASE 2	Done	East Wing	
Building Issue	FACREQ-2604	WW NM NEED POWER RESET ON	Done	West Wing	
Facility Request	FACREQ-2610	Table Base for Storage Cabinet	Done	West Wing	Please complete FY16 request FACREQ-504. FY17 RWA included in this request

Facility Request	FACREQ-2613	RR Table Removal	Done	West Wing	<p>Hi team,</p> <p>The Roosevelt Room table needs to be removed on November 1 at 10:00AM. Additionally, it will need to be replaced at 5:00PM after the POTUS taping is complete.</p> <p>Please let me know if there is anything I can do to assist.</p> <p>Thanks! Michael deForest</p>
Building Issue	FACREQ-2618	WW/1st Floor/Paint Shop; close hole	Done	West Wing	Mud the open hole in the west wing 1st floor by the left side of the door entering the VIP Lobby by NSC Office.
Building Issue	FACREQ-2620	EW/1st Floor/Paint Shop; touch-up area	Done	East Wing	Touch up work in the east wing 1st floor landing
Building Issue	FACREQ-2621	EW/Electrical Shop; replace burnt out light	Done	East Wing	Replace the burnt-out light bulbs in the east wing 1st floor landing
Building Issue	FACREQ-2632	Roosevelt Room Too Hot	Done	East Wing	Roosevelt room Stephen Varos 65679 too hot
Building Issue	FACREQ-2644	Broken Window lock in the East Wing WH	Done	West Wing	
Facility Request	FACREQ-2663	Remove chairs from RR hallway	Done	West Wing	<p>Hello,</p> <p>We need to remove some chairs from the Roosevelt Room hallway, starting at 4:30 PM. Could two movers meet me in Rm 1 to start that work?</p> <p>Thanks, Julia</p>
Building Issue	FACREQ-2667	replace the chipped floor tile in the west wing ground floor just	Done	West Wing	

Facility Request	FACREQ-2698	Roosevelt Room Carpentry Work	Done	West Wing	Request the assistance from the carpentry shop with the installation of three locks on the front of cabinets and the construction of a custom switch box; contact JD Fuchs for further details
Building Issue	FACREQ-2706	Too Cold in West Wing	Done	West Wing	West Wing zones 2w41 and 2w45 need warmed up by two degrees per Julia Ross #62500.
Building Issue	FACREQ-2707	WW/Engineer Shop; lower temperature 2	Done	West Wing	
Building Issue	FACREQ-2716	paint shop to do some touch up work around	Done	West Wing	in the west wing 1st floor hallway by the elevator.
Building Issue	FACREQ-2729	Malfunctioning Skiff Room Door Handle West Wing	Done	West Wing	Malfunctioning Skiff Room Door Handle West Wing assistant to the president's office. It does not open at the handle making it unable to open.
Building Issue	FACREQ-2742	WW Oval pantry	Done	West Wing	paint shop to paint the two napkin holders same color as the wall is. The carpenters have painted them white color.
Facility Request	FACREQ-2772	Wood Refinishing Project - WHSR	Estimate Complete	West Wing	We request an estimate ASAP for the refinish of the woodwork in the open office area and all side chairs throughout the suite; the space was reviewed with GSA and the proposed contractor on October 11th; however, can be revisited, if needed; contact Stephanie Raymond to coordinate access
Building Issue	FACREQ-2774	WW/Electrical Shop; lights out	Done	West Wing	205, 208, 209, 210, 211, 212, 213, 215, 217, 218, 220, and 221
Building Issue	FACREQ-2775	EW/Carpenter Shop; loose door handle	Done	East Wing	Tighten the loose door handle. This is in the east wing main entrance doors going to the drinking water fountain
Building Issue	FACREQ-2776	WW/Paint Shop; ground floor stairway	Done	West Wing	Patch / paint and if you have to mud it and extra time please let me know that way I can put this on WAR

Building Issue	FACREQ-2782	WW LADIES ROOM COMMODE NOT	Done	West Wing	
Building Issue	FACREQ-2800	Navy Mess - Key Broke Off in Lock on Door to Kitchen	Done	West Wing	Navy Mess - Key Broke Off in Lock on Door to Kitchen Billy Jones reported this on Saturday 11/5/2016
Building Issue	FACREQ-2811	WW ground floor men's bathroom/Electrical	Done	West Wing	Replace the burnt-out light bulb in the west wing ground floor men's bathroom
Building Issue	FACREQ-2812	EW 1st floor/Electrical Shop	Done	East Wing	replace the burnt-out light bulb in the east wing room 103
Building Issue	FACREQ-2813	EW Colonnade	Done	East Wing	Take all the mats to the basement
Building Issue	FACREQ-2816	WW/Engineer Shop; Unit #1 Alarm	Done	West Wing	Check the W.W. Press Crac Unit# 1 Alarm tstat needs to be replace had to order
Facility Request	FACREQ-2848	Monitor Bracket Adjustment - WHSR	Done	West Wing	Request assistance from the carpentry shop with the adjustment of a monitor bracket in the WHSR; work to be completed by 7:00am; contact Moe Dunn to coordinate
Building Issue	FACREQ-2851	This ticket is for the movers to lay down all the east wing	Done	East Wing	
Building Issue	FACREQ-2854	EW Colonnade	Done	East Wing	paint shop to do some touch up work in the east wing colonnade. This is the 2nd column from the desk.
Facility Request	FACREQ-2860	Cabinet Table Removal	Done	West Wing	Hi team, We will need to remove the cabinet room table and chairs at 8:00 AM on Wednesday, November 9. Please let me know if you have any questions. Thank you, Michael deForest

Facility Request	FACREQ-2865	Cabinet Table Replacement	Done	West Wing	Hi team, We will need to replace the cabinet room table and chairs at 7:15 AM on Thursday, November 10. Please let me know if you have any questions. Thank you, Michael deForest
Building Issue	FACREQ-2875	WW VP OFFICE REQUEST FIRE WOOD TO BE	Done	West Wing	DONE
Building Issue	FACREQ-2879	To Raise the Temperature up 2 Degrees from the	Done	West Wing	Assign to the 4 to 12 Shift Engineers (Billy)
Building Issue	FACREQ-2886	RO system check	Done	West Wing	Need to check and test RO system for proper operation and chemical levels
Building Issue	FACREQ-2887	RO system check	Done	East Wing	Need to check and test RO system for proper operation and chemical levels
Facility Request	FACREQ-2892	RR Move at 12:00 PM	Done	West Wing	Hi team, We will be interchanging all of the RR chairs with the chairs in the cabinet room at 12:00 PM to 1:30 PM. Please let me know if you have any questions. Best, Michael
Building Issue	FACREQ-2905	WW Navy Mess	Done	West Wing	engineers to PM or replace the dirty filters for the kitchen.
Building Issue	FACREQ-2935	OLA Suite - Room 107-112	Done	East Wing	Adjust to 3 degrees higher/warmer DONE

Building Issue	FACREQ-3002	WW floor tiles	Done	West Wing	paint / mason shop to please replace the stained floor tiles in the west wing ground floor foyer, this is by the FCU and the swinging doors. This work can be completed any time after hours please.
Building Issue	FACREQ-3003	WW ground floor NM	Done	West Wing	plumbers to fix the leak in the west wing ground floor Navy Mess dining room. This work can be completed after hours please. Let me know what you find out?
Building Issue	FACREQ-3006	check COS flute to make sure it's open	Done	West Wing	done
Building Issue	FACREQ-3009	movers to take all the mats from the east wing colonnade to the basement of the east	Done	East Wing	
Building Issue	FACREQ-3024	WW/Paint/Mason Shop; replace stained	Done	West Wing	This is by the FCU and the swinging doors.
Building Issue	FACREQ-3026	WW NM/Electrical Shop; replace burnt out	Done	West Wing	
Building Issue	FACREQ-3028	WW NM/Plumbing Shop; repair leak on the ground floor of the	Done	West Wing	
Building Issue	FACREQ-3029	EW/Move Shop; remove mats	Done	East Wing	Take all the mats from the east wing colonnade to the basement of the east wing.
Building Issue	FACREQ-3063	ro system testing	Done	East Wing	check filters and test chemical levels in ro system
Building Issue	FACREQ-3065	ro system check	Done	West Wing	check filters and test chemical levels in ro system
Building Issue	FACREQ-3072	East Wing SOS office	Done	East Wing	Please remove the moldy section of drywall in this office and replace the drywall. The Masons will patch and paint. Schedule work with David. POC: WES BRUBAKER

Building Issue	FACREQ-3098	WW/Electrical Shop; replace the burnt-out light bulb in the west wing ground floor navy	Done	West Wing	
Building Issue	FACREQ-3099	EW/OLA State/Electrical Shop; replace light	Done	East Wing	Replace the burnt-out light bulbs in the east wing 1st floor OLA State side. It's in the big open space it is on the left.
Building Issue	FACREQ-3100	EW/Electrical Shop/1st Floor Landing; replace	Done	East Wing	Replace the burnt-out light bulb in the east wing 1st floor landing
Building Issue	FACREQ-3101	WW/Custodial Shop; clean up coffee spill in the WW Ground Floor	Done	West Wing	
Building Issue	FACREQ-3106	Light Fireplace Chief of Staff's Office 5th Floor	Done	West Wing	checked fan and damper, light fireplace
Building Issue	FACREQ-3119	EW RM E13 GROUND FLOOR	Done	East Wing	REMOVE ONE SECTION OF SYSTEMS FURNITURE @ 7:30AM FOR SUPPORT PAINT SHOP
Building Issue	FACREQ-3130	WW 1st floor Roosevelt room	Done	West Wing	paint shop to recaulk above around the fireplace mantle.
Building Issue	FACREQ-3131	WW 1st floor	Done	West Wing	paint shop to do some touch up work on the wall. This is in the west wing 1st floor front of Oval pantry.
Building Issue	FACREQ-3132	paint shop to do some touch up work in the west wing 1st floor baseboard by the	Done	West Wing	
Building Issue	FACREQ-3133	Please set the set point to 72 degrees for the	Done	West Wing	WHSR
Building Issue	FACREQ-3151	WW/Carpenter Shop; 1st Floor by E-10 Post; repair gap in ceiling	Done	West Wing	
Building Issue	FACREQ-3152	EW/Electrical Shop; replace brunt out light	Done	East Wing	
Building Issue	FACREQ-3178	elevator shop to fix the elevator which is very slow to open and close	Done	West Wing	

Building Issue	FACREQ-3180	Reset desk in EW EB13 on Friday morning	Done	East Wing	Please have the Move shop reset the desk in EB13 on Friday 11/25/16 at 8 AM. For any additional info please call Chris Alvarez @ 202-438-6134.
Building Issue	FACREQ-3182	Request walk-through for an estimate with Move shop of the West	Done	West Wing	and room 212 in support of carpet replacement work.
Building Issue	FACREQ-3188	WW 1st floor	Done	West Wing	paint shop to recaulk around the sink. this is in the west wing 1st floor men's bathroom by Roosevelt room
Building Issue	FACREQ-3193	VP West Wing Mouse	Done	West Wing	A mouse is caught alive underneath a reef.
Building Issue	FACREQ-3208	ZONE E1-2, E1-3, E1-11, E1-13 AND E1-14	Done	East Wing	TOO COLD Made temp change on BAS
Building Issue	FACREQ-3210	plumbers to investigate the hot water issue in the WW men's	Done	West Wing	TSD request has been submitted for tonight from 12:30 am to 2:30 am.
Building Issue	FACREQ-3216	EW Colonnade mats	Done	East Wing	movers to lay down all the east wing colonnade mats this evening
Building Issue	FACREQ-3219	WW ROOSEVELT ROOM 3 DEGRES UP	Done	West Wing	RAISE SET POINT
Building Issue	FACREQ-3225	VP West Wing Office Christmas Tree to be	Done	West Wing	Also their Christmas tree remote is not working.
Building Issue	FACREQ-3238	engineers to lower the temperature in the east wing colonnade. It's	Done	East Wing	DONE
Building Issue	FACREQ-3239	paint shop to remove the plastic protection.	Done	East Wing	

Building Issue	FACREQ-3244	carpenters to refinish/polish the west wing ground floor thrush holds.	Done	West Wing	The doors that are swinging a bit hard in the West Wing VIP Lobby and the Roosevelt room. Possible to check the hinges out so it can close more softly? In addition, with the holiday receptions starting in the Residence as well as tours, they will continue to use the Roosevelt Room in the West Wing for tapping. Please check all the doors adjacent around the Roosevelt Room being squeaky and noisy. Might it be possible to adjust the door arm so they close quietly?
Building Issue	FACREQ-3266	WW 1st floor CoS Office/Carpenter Shop	Done	West Wing	Fix the loose door stopper
Building Issue	FACREQ-3267	WW VIP/Roosevelt Room/Carpenter Shop; repair doors	Done	West Wing	Refinish/polish the west wing ground floor thrush holds. The doors that are swinging a bit hard in the West Wing VIP Lobby and the Roosevelt room. Possible to check the hinges out so it can close more softly? In addition, with the holiday receptions starting in the Residence as well as tours, they will continue to use the Roosevelt Room in the West Wing for tapping. Please check all the doors adjacent around the Roosevelt Room being squeaky and noisy. Might it be possible to adjust the door arm so they close quietly? This work can be completed after hours and before 7 am.
Building Issue	FACREQ-3270	WW room 151/Plumbing Shop; install outlet	Done	West Wing	Install an outlet in the men's bathroom by Roosevelt room. Plumbers to install new instahot water heater and the paint shop to do any touch up work.

Building Issue	FACREQ-3276	Light Fireplace Chief of Staff's Office	Done	West Wing	DONE
Building Issue	FACREQ-3279	WW 1st floor CoS Office	Done	West Wing	carpenters to fix the loose door stopper. This work needs to be completed tomorrow morning before 7 am.
Facility Request	FACREQ-3280	Cabinet Room Table Removal	Done	West Wing	<p>Hi team,</p> <p>We will need to remove the Cabinet Room table and chairs at 7:30 AM on Monday, December 5. We will need blankets and shrink wrap similarly to the move on November 9. Additionally, the table will be replaced at 7:30 AM on Tuesday, December 6.</p> <p>Please let me know if you have any questions.</p> <p>Thank you, Michael deForest</p>
Facility Request	FACREQ-3284	RR Table Removal	Done	West Wing	<p>Hi team,</p> <p>The Roosevelt Room table will need to be removed on December 2 at 2:00 PM. Additionally, it will need to be replaced at 6:00 PM after the POTUS taping is complete.</p> <p>Please let me know if there is anything I can do to assist.</p> <p>Thanks! Michael deForest</p>

Facility Request	FACREQ-3290	Move support- East Reception Room	Done	East Wing	The table needs to be moved to the side, and the rug needs to be taken out of the East Reception Room by 8:00 AM on 12/1/2016. The room will need to be reset at 4:00 PM. Thanks, Julia
Building Issue	FACREQ-3300	WW room 151	Done	West Wing	electricians to install an outlet in the men's bathroom by Roosevelt room.
Building Issue	FACREQ-3301	WW room 151	Done	West Wing	Plumbers to install new instahot water heater
Building Issue	FACREQ-3302	WW room 151	Done	West Wing	paint shop to do any touch up work.
Building Issue	FACREQ-3324	To Check for a Leak and Operation on the W1 RO System.	Done	West Wing	Assign to the 4 to 12 Shift Engineers
Building Issue	FACREQ-3341	WW ground floor	Done	West Wing	engineers to lower the temperature by 3 degrees in room G - 59. It's very hot in the office. This is in the back between the ladies bathroom and the copier or by the copier machine. DONE
Facility Request	FACREQ-3343	Sound Masking Machine Install - WHSR	Done	West Wing	Request assistance from the electrical shop with the installation of a white noise machine in the WHSR; contact Stephanie Raymond to coordinate
Building Issue	FACREQ-3348	WW/Electrical Shop; replace light	Done	West Wing	Replace the burnt-out light bulb in the west wing 1st floor by OOO hallway.
Building Issue	FACREQ-3358	EW Colonnade mats	Done	East Wing	movers to lay down all the east wing colonnade mats first thing in the morning at 7 : 00 am. 12/4/16
Building Issue	FACREQ-3359	Please raise the temperature by 6	Done	East Wing	DONE

Building Issue	FACREQ-3363	paint shop to paint the entire E - 10 post	Done	West Wing	
Building Issue	FACREQ-3364	plumbers to replace the toilet seat. This is in the east wing 1st floor	Done	East Wing	
Building Issue	FACREQ-3365	paint shop to recaulk around the toilet in the ladies bathroom 1st	Done	East Wing	
Building Issue	FACREQ-3366	plumbers to take care of this fire extinguisher which is in the east wing 1st floor by the main entrance door	Done	East Wing	
Building Issue	FACREQ-3372	WW lower press kitchen counter/Electrical Shop;	Done	West Wing	Replace the burnt-out light bulb in the west wing lower press above the kitchen counter.
Building Issue	FACREQ-3373	Turn up 2 degrees in Zone PR-4	Done	West Wing	DONE
Building Issue	FACREQ-3375	EW basement ladies locker custodial shop	Done	East Wing	
Building Issue	FACREQ-3377	paint shop to do touch ups in the west wing 1st floor landing	Done	West Wing	from W - 16 steps
Facility Request	FACREQ-3382	CNN Booth Counter Tops	Done	West Wing	Please fabricate and install 2 laminate counter tops for the CNN booth in the PBR See Clint for details
Building Issue	FACREQ-3386	E10 (WW Colonnade and Press Lobby Doors)	Done	West Wing	"The press lobby doors magnetically lock and they can be locked with the key, the only thing I could find is that the top latch on the door is unable to secure
Building Issue	FACREQ-3387	E10 (WW Colonnade and Press Lobby Doors)	Done	West Wing	In addition, E10 Colonnade doors are not operating properly due to the malfunctioning fan that is keeping the doors propped and doesn't allow them to fully close."

Building Issue	FACREQ-3400	ZONE PR-4 MAKE 1 DEGREE WARMER	Done	West Wing	done
Building Issue	FACREQ-3406	EW OLA	Done	East Wing	electricians to replace some light bulbs in the east wing. It will be on your left as you enter OLA.
Building Issue	FACREQ-3415	sheet metal shop to replace / fix the damaged window well	Done	East Wing	This is at the east tradesman drive. Outside of room 100 / Visitor's office.
Building Issue	FACREQ-3417	EW 2nd floor ladies bathroom	Done	East Wing	plumbers to fix the leaky water faucet in the east wing 2nd floor ladies bathroom. Also to replace the missing curtain hook which is in the east wing 2nd floor ladies bathroom. Let me know when you have completed this request .
Building Issue	FACREQ-3422	Request to have room W2-42 vacumm	Done	West Wing	POC: Cory Pollard x65677
Building Issue	FACREQ-3423	movers to please take all the mats up to the basement after the	Done	East Wing	
Building Issue	FACREQ-3430	EW / WW; refill the umbrella bags	Done	West Wing	
Building Issue	FACREQ-3431	EW / WW; refill the umbrella bags.	Done	East Wing	
Building Issue	FACREQ-3432	WW NM; fix the swinging door it's not	Done	West Wing	
Building Issue	FACREQ-3452	WW/Plumbing Shop; men's restroom	Done	West Wing	

Facility Request	FACREQ-3466	RR Table Removal	Done	West Wing	<p>Hi team,</p> <p>The Roosevelt Room table will need to be removed on December 12 at 10:30 AM. Additionally, it will need to be replaced at 4:30 PM after the POTUS taping is complete.</p> <p>Please let me know if there is anything I can do to assist.</p> <p>Thanks! Michael deforest</p> <p>Also, please supply 2 tables and 6 chairs</p>
Building Issue	FACREQ-3475	WW/NM SINK NEXT TO CARRY OUT WINDOW NOT HOT	Done	West Wing	
Building Issue	FACREQ-3489	EW/WW/Custodial Shop; deep clean all	Done	West Wing	
Building Issue	FACREQ-3490	CLONE - EW/WW/Custodial Shop; deep clean all	Done	East Wing	
Building Issue	FACREQ-3510	WW ground floor	Done	West Wing	<p>sheet metal shop to replace the 3 brass corner plates which are by W - 16</p> <p>This ticket is for Mike Grice</p>
Building Issue	FACREQ-3511	EW Colonnade mats	Done	East Wing	<p>movers to lay down all the east wing colonnade mats first thing tomorrow morning before 7 : 15 am</p> <p>Last Sunday night 12/11/16</p>

Building Issue	FACREQ-3512	WW 1st floor CoS suite	Done	West Wing	engineers to raise temperature by 2 degrees up in the west wing 1st floor CoS Office and also Zone 1 W - 37. Ticket from Sunday night/Monday morning
Building Issue	FACREQ-3514	engineers to check/fix the FCUs in the WW E - 10 Post they are not	Done	West Wing	
Building Issue	FACREQ-3529	WW Lower Press/Electrical & Custodial Shops, clean fixture, ceilings and furniture	Done	West Wing	Electricians and custodial shop to please clean all the light fixtures , ceilings and furniture . This is in the entire lower press and the break room and the bathrooms. This needs to be completed ASAP.
Building Issue	FACREQ-3530	WW Lower Press/Electrical & Custodial Shops; clean fixtures, ceilings and furniture	Done	West Wing	Electricians and custodial shop to please clean all the light fixtures , ceilings and furniture . This is in the entire lower press and the break room and the bathrooms. This needs to be completed ASAP
Building Issue	FACREQ-3535	EW 2nd floor men's bathroom/Paint Shop; re-caulk sink	Done	East Wing	Recaulk around the sink in the east wing 2nd floor men's bathroom.
Building Issue	FACREQ-3536	WW Ground Floor/Sheet Metal Shop; reconstruct 3 brass plates	Done	West Wing	Replace the 3 brass corner plates which are by W - 16. *SHEET METAL SHOP*
Building Issue	FACREQ-3554	WW 2ND FLOOR MEN'S ROOM WATER	Done	West Wing	
Facility Request	FACREQ-3563	Cabinet Room Move	Done	West Wing	Hi team, We will need to flip the cabinet room table over and move it to the back left of the room for a taping on Thursday, December 15. Additionally, the chairs will need to be moved to the EEOB. Thanks! Michael deForest

Facility Request	FACREQ-3573	Deliver 20 Cabinet Chairs to the EEOB	Done	West Wing	<p>Good morning,</p> <p>This ticket is for the delivery of 20 cabinet chairs to the West Wing at 7:00 AM on Monday, 12/19. The POC for this is Julia Ross-- I can be reached at the numbers below with any questions.</p> <p>Many thanks!</p> <p>desk: 202-456-1275 BB: 202-881-7115</p>
Facility Request	FACREQ-3583	Repair Press Breifing Room Chair	Done	West Wing	<p>Please repair a broken arm on a PBR chair</p> <p>Contact Clint for details</p>
Building Issue	FACREQ-3587	WW lower press	Done	West Wing	<p>electricians to replace the burnt-out light bulbs in the west wing ground floor men's bathroom and in the lower press</p>
Building Issue	FACREQ-3594	Check for Cold Air Blowing Out of the Air Vents in the W.W. COS	Done	West Wing	
Building Issue	FACREQ-3595	Check for a Noise coming from a FCU in the W.W. of the COS	Done	West Wing	
Facility Request	FACREQ-3599	Cabinet Room Chair Swap	Done	West Wing	<p>Hi team,</p> <p>At 7:00 AM Monday morning we will be removing all of the cabinet chairs around the table and taking them to EEOB 083A to be refurbished. Please let me know if you have any questions.</p> <p>Thanks! Michael deForest</p>
Building Issue	FACREQ-3603	EW/Carpenter Shop; rm. 221, window of	Done	East Wing	

Building Issue	FACREQ-3607	EW/Carpenter Shop; window broken in rm.	Done	East Wing	
Facility Request	FACREQ-3610	POST A-4 THE PEDESTRIAN GATE STICKS, VERY HARD	Done	West Wing	
Building Issue	FACREQ-3627	WW/Engineer Shop; turn on heat	Done	West Wing	Turn on the heat to the Rose Garden door air curtain in hallway 103 (Post E-10) if they haven't already done so.
Building Issue	FACREQ-3629	EW 2nd floor room 212//Carpenter Shop; repair window	Done	East Wing	Look / fix the window in the east wing 2nd floor room 212. This work needs to be completed asap.
Building Issue	FACREQ-3640	EW Colonnade mats	Done	East Wing	movers to lay down all the east wing colonnade mats. The mats are in the east wing basement. This work needs to be completed between 7 : 00 am to 7 : 15 am tomorrow morning.
Building Issue	FACREQ-3661	toilet leaking	Done	West Wing	found a toilet leaking in the press lunch area men's room, engineers turned off
Building Issue	FACREQ-3674	WW 1st floor	Done	West Wing	elevator shop to fix the E - 10 post door which doesn't seem to properly close, also the automatic door switch is not working.
Facility Request	FACREQ-3684	Cabinet Chair Swap	Done	West Wing	Hi team, We will be bringing the 5 remaining cabinet chairs from the EEOB to the Cabinet Room this evening at 6:30 PM. Please make sure the move shop and TSD are both tracking. Thanks! Michael deForest
Building Issue	FACREQ-3686	To Check and Adjust the Temperature on the W.W. Air Curtain by	Done	West Wing	Assign to the 4 to 12 Shift Engineers (Billy)

Building Issue	FACREQ-3687	To Check the W.W. USSS Post E-10 Air	Done	West Wing	Assign to the 4 to 12 Shift Engineers (Billy)
Building Issue	FACREQ-3694	WW 1st floor Cabinet room/Custodial Shop; clean cabinet room	Done	West Wing	Clean all the chairs and the table in the west wing Cabinet room. This work needs to be completed asap.
Building Issue	FACREQ-3695	WW 1st floor/Paint Shop; patch and touch-	Done	West Wing	Patch the cracks in the wall across from the elevator on the WW 1st floor.
Building Issue	FACREQ-3699	EW rm. 221/Carpenter Shop; repair window off	Done	East Wing	
Building Issue	FACREQ-3704	EW/WW/Custodial Shop; refer to cleaning instructions below	Done	West Wing	<p>Please deep vacuum all the stairs / steps because dust is accumulating in the corners. This is in the west wing and the east wing.</p> <p>Polish all the brass handles, door plates and the wall corners. This is in the west wing and the east wing.</p> <p>Cobwebs in the east wing 2nd floor room 212. This is in the east wing. Also in the main entrance hallway in the west wing. And the corners of the east wing stairs.</p>
Building Issue	FACREQ-3705	EW/WW/Custodial Shop; refer to cleaning	Done	East Wing	
Building Issue	FACREQ-3707	WW SIT Room/Engineer Shop; check and fix AHU	Done	West Wing	Check and fix the issue at all the AHU which is service the SIT room west wing. Can someone go over to the SIT room and talk to JD, he is in charge of WHSR. Let me know what you find out? It is in the 60 degrees and they're not able to raise any high.
Building Issue	FACREQ-3711	EW landing/Paint Shop; replace the damaged film over the glass in the swinging	Done	East Wing	

Building Issue	FACREQ-3714	carpenters to tighten the loose door hinges in the west wing navy	Done	West Wing	This work can be completed tomorrow morning before 11 : 30 am.
Building Issue	FACREQ-3715	WW Wall Crack	Done	West Wing	Per our discussion, please find 1 of 2 cracks on the 1st floor of the West Wing pictured below. The cracks can be found to the right of the elevator as you face the elevator. One is located in the corner of the corridor wall and cased opening as pictured. The other is much thinner and located in the drywall of the cased opening as well
Building Issue	FACREQ-3716	WW 1st floor	Done	West Wing	paint shop to patch the cracks in the wall across from the elevator on the WW 1st floor.
Building Issue	FACREQ-3717	EW landing	Done	East Wing	paint shop to replace the damaged film over the glass in the swinging doors by the first family theater.
Building Issue	FACREQ-3719	WW Navy Mess/Carpenter Shop; repair door	Done	West Wing	Tighten the loose door hinges in the west wing navy mess dining room 2. This work can be completed tomorrow morning before 11 : 30 am.
Facility Request	FACREQ-3737	Counter Top for AP Booth	Done	West Wing	Please fabricate and install a new counter top for the AP booth on the PBR. The new top will also need a wall cleat. See Clint for details
Building Issue	FACREQ-3741	COS OFFICE REQUEST TO HAVE	Done	West Wing	lite fireplace
Building Issue	FACREQ-3752	WW Navy Mess/Electrical Shop;	Done	West Wing	Replace the burnt-out light bulb in the west wing ground floor navy mess dining room.
Building Issue	FACREQ-3763	EW Colonnade mats	Done	East Wing	DO NOT PLACE ANY OF THE EAST WING MATS AGAINST THE ELECTRICAL PANEL OR THE STEAM PIPELINE.

Building Issue	FACREQ-3766	electricians to replace the burnt-out light bulbs in the west wing ground floor by E - 1 post,	Done	West Wing	in the small dining room and on the 2nd floor hallway. East wing by the 1st floor landing and the ladies bathroom 2nd floor. Please let me know when you have completed this request.
Building Issue	FACREQ-3779	electricians to reset the trip circuit breaker in the west wing navy	Done	West Wing	
Building Issue	FACREQ-3803	Too Cold East Wing	Done	East Wing	DONE
Facility Request	FACREQ-3822	RR Table Removal	Done	West Wing	Hi Clint, The table in the Roosevelt room needs to be removed at 1:30 PM and replaced at 5:30 PM on Tuesday, January 3. Please notify TSD and the move shop and let me know if you need anything additional from me. Thanks! Michael deForest
Building Issue	FACREQ-3823	WW AUTOMATIC DOORS TO THE COLLNNADE ARE	Done	West Wing	ESPECIALLY THE ONE ON THE RIGHT
Building Issue	FACREQ-3835	ro system	Done	West Wing	check system operation
Building Issue	FACREQ-3836	ro system	Done	East Wing	check system operation
Building Issue	FACREQ-3838	Post E-1 Needs Lights Turned on at Canopy	Done	West Wing	
Building Issue	FACREQ-3841	WW/Electrical Shop; replace burnt out lights	Done	West Wing	This ticket is for the electricians to replace the burnt-out lights in the west wing ground floor men's bathroom and on the 2nd floor hallway. Please let me know when you have completed this request.

Building Issue	FACREQ-3842	WW 1st floor Oval; replace burnt out light	Done	West Wing	This ticket is for the electricians to replace the burnt-out light bulb in the west wing 1st floor by Oval hallway. This work needs to be completed ASAP.
Building Issue	FACREQ-3843	WW/Electrical Shop; replace burnt out light	Done	West Wing	This ticket is for the electricians to replace the burnt-out lights in the west wing ground floor Navy Mess dining room and the VIP Lobby Foyer. Please let me know when you have completed this request?
Building Issue	FACREQ-3844	WW/EW- Electrical Shop; replace burnt out lights	Done	West Wing	This ticket is for the electricians to replace the burnt-out lights in the west staircase in the west and east wings and the main entrance hallway. Please let me know when you have completed this request?
Building Issue	FACREQ-3845	WW/EW - Electrical Shop; replace burnt out lights	Done	East Wing	This ticket is for the electricians to replace the burnt-out lights in the west staircase in the west and east wings and the main entrance hallway. Please let me know when you have completed this request?
Building Issue	FACREQ-3865	Name Plate Replacement WH Press Area	Done	West Wing	Jon Deckor inquiring about press area white house name plates on press seats. White house briefing room for national public radio second row 4th seat.
Building Issue	FACREQ-3870	EW/WW; Custodial Shop, refill hand sanitizer asap	Done	West Wing	This ticket is for the custodian shop to please refill all the Hand Sanitizers asap. Please let me know when you have completed this request?
Building Issue	FACREQ-3871	EW/WW; Custodial Shop, refill hand sanitizer asap	Done	East Wing	This ticket is for the custodian shop to please refill all the Hand Sanitizers asap. Please let me know when you have completed this request?
Building Issue	FACREQ-3872	EW 2nd floor; replace missing light bulb fixture holders	Done	East Wing	This ticket is for the electricians to replace the missing light bulb fixture holders. This is in the east wing 2nd floor room 202. Let me know when you have completed this request.

Building Issue	FACREQ-3873	EW/Move Shop; move umbrella stand	Done	East Wing	This ticket is for the movers to move the umbrella standard for the east wing by room 103 hallway to the EEOB. Please let me know when you have completed this request?
Facility Request	FACREQ-3922	RR Table Removal	Done	West Wing	Hello, The Roosevelt Room table will need to be removed at 10:45 AM and replaced at 5:45 PM on Friday, January 6. Please let me know if you have any questions. Best, Michael deForest
Building Issue	FACREQ-3934	EW/Electrical Shop; replace burnt out light in EW	Done	East Wing	This ticket is for the electricians to replace the burnt-out light bulb in the east wing main entrance lobby. Let me know when you have completed this request.
Building Issue	FACREQ-3939	custodian shop to please deep clean all the furniture and carpet in the east wing 2nd	Done	West Wing	custodian shop to please deep clean all the furniture and carpet in the east wing 2nd floor room 204.
Building Issue	FACREQ-3968	PLEASE LITE COS FIREPLACE	Done	West Wing	
Building Issue	FACREQ-3969	EW Mechanical rm 3	Done	East Wing	EW Mechanical Rm. #3; cylinder/deadbolt inoperable-Dale Jensen or Mark @ ext. 71185
Building Issue	FACREQ-3978	EW Mechanical Rm. #3; cylinder/deadbolt inoperable-Dale Jensen	Done	East Wing	
Building Issue	FACREQ-3979	To Raise the W.W. Press Secretary Office	Done	West Wing	
Building Issue	FACREQ-3980	To Check and Adjust the W.W. Upper Press	Done	West Wing	
Building Issue	FACREQ-3982	To take Wood to the VP Fireplace as	Done	West Wing	

Building Issue	FACREQ-3984	EW/WW	Done	West Wing	<p>custodian shop to please clean all the bathrooms in the east and west wings. Also to clean /dust all the main entrance and the entire east wing colonnade and the hallways for cobwebs and dirt. Angella Reid and Alan had a walk thru.</p> <p>Sorry forgot to include the wall mirror which is in the east wing by the ladies bathroom and the handicap ramp.</p>
Building Issue	FACREQ-3986	WW BPR	Done	West Wing	<p>paint shop to replace the broken / missing step stripes which is in the west wing ground floor by the west wing Press Briefing suite going down the steps on both sides. This work needs to be completed asap.</p>
Building Issue	FACREQ-3987	plumbers to fix the leaky toilet in the west wing Press Briefing	Done	West Wing	
Building Issue	FACREQ-3989	electricians to polish / clean all the light fixtures in the east wing colonnade and main	Done	East Wing	
Building Issue	FACREQ-3990	engineers to please clean and check all the air vents in the east wing main entrance	Done	East Wing	<p>Also to check out for any vents that are loose.</p>
Building Issue	FACREQ-3991	carpenters to check / fix the issue with the double doors leading to room 103 and the	Done	East Wing	<p>This doors are in the east wing main entrance by the USSS Post</p>

Facility Request	FACREQ-3999	RR Table Removal	Done	West Wing	<p>Hi team,</p> <p>We will need to remove the Roosevelt Room table at 3pm and replace it at 6:30 PM on Monday, January 9. The wing back chairs and coffee table will also need to be removed. Please let me know if you have any questions.</p> <p>Thanks! Michael deForest</p>
Facility Request	FACREQ-4014	THE HEATER DOES NOT WORK. A TEMPORARY SPACE HEATER HAS BEEN	Done	East Wing	
Facility Request	FACREQ-4015	EAST ENTRY DOOR MOTOR ENCASEMENT HAS	Done	East Wing	SGT. J. COCHRAN
Facility Request	FACREQ-4017	THE OUTER PEDESTRIAN GATE IS NOT RELEASING	Done	West Wing	
Building Issue	FACREQ-4019	To Lower the Temperature 2 Degrees in the E.W. Theater from the	Done	East Wing	
Building Issue	FACREQ-4040	EW/Colonnade/Move Shop; lay down all the east wing colonnade mats tomorrow evening at 6 : 00 pm. The mats	Done	East Wing	
Building Issue	FACREQ-4077	electricians to replace the burnt-out light bulb in the west wing 1st	Done	West Wing	

Building Issue	FACREQ-4078	paint shop to to replace the two broken wall tiles. This is in the west wing navy mess kitchen	Done	West Wing	
Building Issue	FACREQ-4079	EW / WW	Done	West Wing	landscape shop to please pick up all the bug lights.
Building Issue	FACREQ-4096	WW/Plumbing Shop; supply water supply line	Done	West Wing	Need a water supply line ran to AHU #2 humidifier that is located under the floor. See Thomas.
Building Issue	FACREQ-4107	electricians to replace the cracked can	Done	East Wing	
Facility Request	FACREQ-4110	Remove Cabinet From Bress Breifing Room	Done	West Wing	Please remove one closet cabinet from the PBR Probably need 2 or 3 guys and a dolley. We'll take it to the EEOB North Carriageway for RDS to retrieve
Facility Request	FACREQ-4111	Deliver Moving Boxes to VP's Suite	Done	West Wing	Please deliver 12 moving boxes to the VP's Suite n the West Wing (1st Floor) And bubble wrap if you have any available
Building Issue	FACREQ-4121	To Check a Water Leak on West Exec.	Done	West Wing	
Facility Request	FACREQ-4125	Professional Cleaning - Saturday, January 14th	Done	West Wing	Please provide professional cleaning services to clean the carpets in the WHSR on Saturday, January 14th; contact Stephanie Raymond to coordinate
Building Issue	FACREQ-4145	paint shop to remove all the broken glass in the east wing rooms 132 and 133.	Done	East Wing	This needs to be completed before 6 : 00 am Monday morning. GSA can work in these rooms as schedule only. Please let me know when you have completed this request?

Facility Request	FACREQ-4147	THE DOOR FRAME IS BENT CAUSING THE DOOR TO GET STUCK IN THE	Done	East Wing	
Facility Request	FACREQ-4159	deliver couch to WW	Done	West Wing	deliver couch from 083A to DCOS in the WW
Building Issue	FACREQ-4165	Move Desk from East Wing to West Wing	Done	West Wing	Please meet me at 6:30 PM on Wednesday, January 18 to move one desk from the East Wing to West Wing
Facility Request	FACREQ-4166	2 Movers for 1/18 at 10:00 PM	Done	West Wing	Requesting assistance from 2 movers on the night of 1/18 Please have them meet Clint at 10pm this event was cancelled
Building Issue	FACREQ-4167	PLEASE LOWER THE TEMP IN PRESS BRIEFING	Done	West Wing	
Building Issue	FACREQ-4172	EW 2ND FLOOR MILITARY OFFICE	Done	East Wing	
Building Issue	FACREQ-4194	electricians to replace the burnt-out light bulb in the west wing ground	Done	West Wing	
Facility Request	FACREQ-4205	PBR Booth Requests	Done	West Wing	We have a few requests from some of the booths in the PBR - Build and install a self in the booth with the recently installed counter top - Remove small under counter cabinets in the NPR booth. This may require and additional support for the counter top. A wall mounted support would be preferred - Create keys and/or install new lock core in the first booth behind the press camera areas. I can provide details

Building Issue	FACREQ-4210	Press Secretary's Office Temp	Done	West Wing	Could we lower the set point by at least 3 degrees? I believe the zone# is PRESS-SEC
Building Issue	FACREQ-4211	WW 1st floor Oval	Done	West Wing	plumbers to replace the toilet seat tonight after hours please
Building Issue	FACREQ-4214	paint shop to do touch ups in the west wing lower press wall on	Done	West Wing	
Building Issue	FACREQ-4277	Turn Off and On the W.W. AH# 4 as	Done	West Wing	
Facility Request	FACREQ-4285	Wardrobe Assembly	Done	West Wing	Request assistance from the carpentry shop with the assembly of three wardrobes for the West Wing (currently stored in EEOB); contact Stephanie Raymond to coordinate
Building Issue	FACREQ-4289	WW/Lower Press CNN; too cold in section	Done	West Wing	
Facility Request	FACREQ-4296	Off Hours Move Support	Done	West Wing	Requesting 4 movers to assist me at 4:30am on 1/26
Facility Request	FACREQ-4306	Move Support - 1/25	Done	West Wing	Move support requested to relocate furniture from the West Wing to the EEOB - task completed 1/25
Facility Request	FACREQ-4313	2 Cardboard Boxes	Done	East Wing	A member of the Military office has departed and their office will need 2 cardboard boxes to pack her belongings.

Building Issue	FACREQ-4315	EW Carpet Cleaning/Custodial Shop; clean the carpet areas below.	Done	East Wing	<p>White House Staffers would like to request some additional thorough cleaning in the OLA offices. In the offices that did not receive carpet replacement or stretching, there is a lot of dirt and debris built up between the desks and walls. The desks may need to be slid out a little to clean the area properly.</p> <p>The specific offices would be:</p> <ul style="list-style-type: none"> - E123 - E124 - E126 - E127 - E132 - E133
Building Issue	FACREQ-4316	W2-50/Engineer Shop; maintain temperature at	Done	West Wing	
Building Issue	FACREQ-4326	To Turn the Roosevelt Room AH# 4 ON and OFF, to Check for a Air Noise and to Check the	Done	West Wing	
Building Issue	FACREQ-4341	Lights Out - G74	Done	West Wing	There are three lights out in the NSC's Lower Suite; please send an electrician this morning to replace the bulbs.
Facility Request	FACREQ-4345	Post A-4 and A-5	Done	West Wing	<p>Malfunction: BOTH POSTS HAVE MOLD GROWING OUT OF THE AIR FILTERS.</p> <p>Special instructions/explanation: PLEASE HAVE THE AIR FILTERS CHANGED ASAP.</p>
Facility Request	FACREQ-4357	Move support for COS table swap	Done	West Wing	<p>This was from 5:30a-7:00a.</p> <p>This was for the Chief of Staff table swap in the West Wing.</p>

Building Issue	FACREQ-4359	West Wing Upper Press Freezing cold	Done	West Wing	
Building Issue	FACREQ-4363	Temperature Increase	Done	West Wing	Please increase the temperature in Zone 1W-21 of the West Wing by two degrees; contact Stephanie Raymond with questions
Facility Request	FACREQ-4368	Need desk	Done	West Wing	Need to move this desk in furniture hold room in EEOB to Lower press
Building Issue	FACREQ-4371	WW Oval Bathroom/Plumbing Shop; fix the leaky	Done	West Wing	
Building Issue	FACREQ-4372	WW ground floor room G - 74/Electrical Shop; replace the burnt-out lights in the west wing	Done	West Wing	
Building Issue	FACREQ-4373	EW/Custodial Shop; keep an eye on the east wing colonnade	Done	East Wing	They have special event and watching movie at 3 : 00 pm this afternoon.
Building Issue	FACREQ-4374	WW E - 10 post hallway/Custodial Shop; deep clean the coffee stain in the west	Done	West Wing	
Building Issue	FACREQ-4385	Clean the Air Vents in the Ceiling of the W.W.	Done	West Wing	Assign to the 4 to 12 Shift Engineers (Billy)
Facility Request	FACREQ-4387	Work in WW 215	Done	West Wing	Requesting two tasks in West Wing 215 1. Touch up coffee table. Just a quick touch up of the surface 2. Replace existing shelves in shelving unit. They would like them to look "nicer". Something with a front edge. White lacquer finish (not brushed or rolled)
Facility Request	FACREQ-4388	Movers for Sunday 1/29	Done	West Wing	Funding mover support for Sunday, January 29 2 movers for 4 hours
Building Issue	FACREQ-4395	ZONE E1-2 TOO	Done	East Wing	

Building Issue	FACREQ-4399	plumbers to unclog the drain which is in the west wing ground floor	Done	West Wing	
Building Issue	FACREQ-4400	electricians to please shine all the chandeliers in the east	Done	East Wing	
Facility Request	FACREQ-4410	Hang White Board in WW 223	Done	West Wing	<p>Please hang a White Board for Marc Short in Room 223.</p> <p>The white board is in the office. They would also like the tray removed from the white board, because they would like to have it hung in a vertical orientation. As opposed to the typical horizontal layout.</p>
Facility Request	FACREQ-4412	Fabricate and Install "Man Bars"	Done	West Wing	We need to have "man bars" installed in the duct work that supplies air services to West Wing room 152 to meet security standards. 6" by 6" openings (or smaller) in the bar layout is required
Facility Request	FACREQ-4414	Door Modifications for Security	Done	West Wing	<p>We need the following modifications done to the entrance door on WW 152</p> <ul style="list-style-type: none"> - Drop seal on the bottom - Brass trilogy installed (can use dark bronze temporarily) - Sound gaskets around door - mortise style dead bolt
Facility Request	FACREQ-4419	Hang Artwork on 1/3	Done	West Wing	<p>Requesting assistance hanging a large piece of artwork on Friday 1/3, at 8:30am</p> <p>Estimated weight is 50lbs. They said it was previously hung by 2 hooks</p>

Facility Request	FACREQ-4420	Help Move Artwork on 1/3	Done	West Wing	Requesting help moving a large piece of artwork on Friday at 8:30am. Please meet on West Exec
Facility Request	FACREQ-4425	Move Support for Transition	Done	West Wing	After hours support (Completed)
Facility Request	FACREQ-4427	Desk Risers for Upper Press	Done	West Wing	Please fabricate and install 2 desk risers for the Upper Press Reception area. Jim Little has taken measurements
Facility Request	FACREQ-4429	West Wing Modifications	Done	West Wing	This is to fund Carpenter support for the new doorway in 120, and the removal of the existing built-ins
Facility Request	FACREQ-4430	West Wing Modifications	Done	West Wing	This is to fund Electrician support for the new doorway in 120, and the removal of the existing built-ins
Facility Request	FACREQ-4431	West Wing Modifications	Done	West Wing	This is to fund Paint/Mason support for the new doorway in 120, and the removal of the existing built-ins
Facility Request	FACREQ-4432	Relocate Large White Board	Done	West Wing	Please remove a large white board from EEOB 547 and rehang in the West Wing. Scheduled for 2/1/17 at 7:15am
Facility Request	FACREQ-4435	Trilogy Lock Combo Change	Done	West Wing	Request assistance from the lock shop with changing the combination of two trilogy locks in the West Wing; contact Mary Feinstein to coordinate access
Building Issue	FACREQ-4441	West Wing Room 120 move support	Done	West Wing	Need to have the furniture removed from WW room 120 on Saturday 2/4/17 at 6:00 am and stored in the adjoining room 121. Reset the furniture after the new carpet has been installed Sunday 2/5/17 at 4:00 pm. I have attached the move estimate 020517
Building Issue	FACREQ-4446	VP request to light fire place	Done	West Wing	

Building Issue	FACREQ-4448	VP's Office in the West Wing has noted that some of their lights bulbs are out and the	Done	West Wing	after 10:00pm
Building Issue	FACREQ-4453	engineers be scheduled to light the	Done	West Wing	tomorrow morning @ 8:15 am
Building Issue	FACREQ-4465	Check the W.W. Navy Mess Ice Cream and	Done	West Wing	
Building Issue	FACREQ-4466	Check and Adjust the Temperature in the E.W. Zone#'s 1E-11	Done	East Wing	
Building Issue	FACREQ-4468	service the ward room for roaches	Done	West Wing	already complete Billy please close out
Facility Request	FACREQ-4469	Hang Phones	Done	West Wing	Request assistance from the carpentry shop with hanging two wall phone mounts on February 2nd; contact Stephanie Raymond to coordinate
Facility Request	FACREQ-4473	Deliver Boxes to West Wing	Done	West Wing	Please deliver 4 moving boxes to West Wing Room 120. We would like to have them delivered on Thursday, February 2 at 1:00pm.
Facility Request	FACREQ-4474	New Chair Slide in Upper Press	Done	West Wing	Please fabricate a new chair slide for the Press Secretary's desk. Jim Little has taken measurements
Building Issue	FACREQ-4480	WW 2nd floor room 225; clean door handle	Done	West Wing	
Building Issue	FACREQ-4482	Please pick up Obama things and wrap up and move to Secret Service	Done	West Wing	POC: Bruce Rink
Building Issue	FACREQ-4483	electricians to please shine all the chandeliers in the east	Done	East Wing	
Building Issue	FACREQ-4491	engineers to check the chill water at the west	Done	West Wing	
Building Issue	FACREQ-4492	zone W2-41 too cold	Done	West Wing	

Building Issue	FACREQ-4501	Check the Temperature in the E.W. Military area Zone# 1E-1, 1E-2	Done	East Wing	
Building Issue	FACREQ-4502	Relight the VP Fireplace in the W.W.	Done	West Wing	
Building Issue	FACREQ-4503	Check and Adjust the Temperature up for being to Cold in the	Done	West Wing	
Building Issue	FACREQ-4504	Check and Adjust the Temperature up for being to Cold in the W.W. Room# 221	Done	West Wing	
Building Issue	FACREQ-4505	Lower the Temperature in the W.W. Oval Office	Done	West Wing	
Building Issue	FACREQ-4519	WW/Carpenter Shop; replace all the step	Done	West Wing	
Building Issue	FACREQ-4527	To Check and Reset the W.W. Navy Mess Ice Machine and	Done	West Wing	
Building Issue	FACREQ-4528	To Raise the Temperature Up in the	Done	East Wing	
Facility Request	FACREQ-4532	Wallpaper Oval Office Study and Dining Room	Done	West Wing	Purchase and install paper as requested in these areas
Facility Request	FACREQ-4541	New Power and Cable Outlets	Done	West Wing	Please install power and cable outlets behind the TVs in West Wing 121. Work will need to be performed off hours. Derrick is familiar with the layout.
Building Issue	FACREQ-4553	ZONE W2-46 TOO COLD	Done	West Wing	
Building Issue	FACREQ-4556	West Wing zone GW-5A raised by 2 degrees	Done	West Wing	

Building Issue	FACREQ-4557	EW Colonnade mats today	Done	East Wing	movers to bring up all the mats from the east wing basement and lay them down. This work needs to be completed between 6:00 pm and 7 :00 pm. Please let know when you have completed this request.
Building Issue	FACREQ-4568	To Raise the Temperature up in the	Done	West Wing	
Facility Request	FACREQ-4569	Mover Asstance on Tuesday 2/7	Done	West Wing	Requesting Mover assistance on 2/7 at 7:15am. Would like to do the following: - Move 1 couch from EEOB 412 to the West Wing - Move 1 smaller couch from the West Wing to the EEOB - Relocate 1 L shaped desk in the East Wing - Move 1 desk from the East Wing to the EEOB
Building Issue	FACREQ-4570	To Raise the Temperature up in the	Done	West Wing	
Facility Request	FACREQ-4581	Coat Hook	Done	West Wing	Request support from the carpentry shop with constructing a wall mounted coat rack with three hooks; contact Stephanie Raymond for additional details
Building Issue	FACREQ-4589	Adjust Pantry door	Done	West Wing	
Facility Request	FACREQ-4592	Electrical Support for COS's Office	Done	West Wing	This is to channel the wall in the COS office to hide electrical wires and cable.
Facility Request	FACREQ-4593	Paint Shop Support for COS's Office	Done	West Wing	This is to channel the wall in the COS office to hide electrical wires and cable.
Facility Request	FACREQ-4594	Hang White Board in G37	Done	West Wing	Please hang a white board in Room G37. We have some extra white boards in EEOB 60. But they will need mounting hardware.

Facility Request	FACREQ-4597	West Wing Desk Move	Done	West Wing	Please move one desk from EEOB 60 to the West Wing. And then one desk from the West Wing to EEOB 60 Please meet Clint at EEOB 60 on Wednesday 2/8 at 7:15 AM
Facility Request	FACREQ-4601	Light out WW 212	Done	West Wing	
Building Issue	FACREQ-4610	EW Colonnade	Done	East Wing	This is for the paint shop as you enter the colonnade, the wall on the left has a large blackened area. The wall surface may need to be sanded and then painted. Also above the pillars and between the two pillars on the surface.
Building Issue	FACREQ-4611	movers to bring back the BIG MAT which has been stored in Franconia.	Done	East Wing	This mat need to be placed down in the east wing landing tomorrow afternoon after 1 : 00 pm. Please let me know when you have completed this request.
Building Issue	FACREQ-4612	custodian shop to please clean all the FCU covers and the George Washington bust stand at the	Done	East Wing	
Building Issue	FACREQ-4613	WW Oval	Done	West Wing	locksmith shop to fix the loose door handle which is in the Oval leading to the rose garden. This work needs to be completed first thing tomorrow morning. Please let me know when you have completed this request.
Building Issue	FACREQ-4621	To Adjust the Temperature up in the	Done	West Wing	
Building Issue	FACREQ-4625	EW 2nd floor women's restroom	Done	East Wing	GSA Mason shop to repair tile around drain in shower.

Building Issue	FACREQ-4629	WW/EW/Electrical Shop; replace burnt out light bulbs	Done	West Wing	Replace the burnt-out light bulb in the west wing by Oval hallway, and wall sconce in the EW stairwell that has a bulb burn out as well.
Facility Request	FACREQ-4633	Chair Slides for East Wing	Done	East Wing	Please fabricate and install 2 custom chair slides for the desks in EW room E126. There are 2 there currently, but they are both cracked.
Building Issue	FACREQ-4635	EW OLA/Paint Shop; remove glass top	Done	East Wing	Paint shop to get this broken glass top removed? It's in the Leg Affairs area in the East Wing
Building Issue	FACREQ-4648	WW VIP Lobby	Done	West Wing	carpenters to adjust the door closer. The door leading to men's and women's bathrooms. It's shuts to fast.
Facility Request	FACREQ-4651	Desk Risers	Done	West Wing	1. The Staff Secretary requires a bigger desk. 2. Barring that, the Staff Secretary needs his desk to be lifted. 3. The Deputy Staff Secretary needs his desk to be lifted.
Building Issue	FACREQ-4657	EW Colonnade mats	Done	East Wing	movers to bring the mats up from the basement and lay them down in the east wing colonnade. This work can be completed any time after 6 : 00 pm.
Building Issue	FACREQ-4658	WW Oval Office	Done	West Wing	engineers to place the bug zapper in the Oval Office after 8 : 30 pm. The bug zapper is in the box and the box is sitting on the floor by the Oval pantry hallway. Billy Jones - please check for a big fly.
Building Issue	FACREQ-4660	To Check and Adjust the Temperature in the W.W. Upper Press	Done	West Wing	

Facility Request	FACREQ-4667	Thursday Morning Picture Hanging	Done	West Wing	Hang picture and mirror for Sean in Room G-37 POC is Lara in G36
Facility Request	FACREQ-4682	basement gym	Done	East Wing	Good Morning Tamatha, GSA would like to proceed with this project, we need separate tickets for the carpenter shop, electric shop, plumbing shop, engineers, fire alarm shop, and the paint/mason shop. The ticket that was submitted was only for an estimate, since you have accepted the estimate. We need JIRA tickets to keep track of the labor being charge to the N#. Sorry for any inconvenience, Wendy R. Anderson Executive Assistant II General Service Administration (WPMH-C) 725 17th Street, NW Suite 2020 Washington, DC 20503 Office:(202) 395-3236 Fax:(202) 395-3027
Facility Request	FACREQ-4696	5 Jumbos Need to be Mounted on WW 2nd Floor	Done	West Wing	The brackets are not lined up with the jumbo frame. It's on the north side of the 2nd floor. PLEASE DO NOT MOUNT ANYTHING WITHOUT CALLING Joy Paluska (call 66658).
Facility Request	FACREQ-4710	Construct Tech Tower - WW	Done	West Wing	Request support from the carpentry shop with constructing a tower to support two printers and technical equipment; contact Stephanie Raymond to discuss scope in more detail

Building Issue	FACREQ-4712	WW ground floor men's room paper towel	Done	West Wing	
Building Issue	FACREQ-4717	WW ground floor	Done	West Wing	electricians to reset the time. This is in the west wing ground floor Staff Secretary's suite.
Facility Request	FACREQ-4733	east wing basement gym	Done	East Wing	<p>Good Morning Tamatha,</p> <p>GSA would like to proceed with this project, we need separate tickets for the carpenter shop, electric shop, plumbing shop, engineers, fire alarm shop, and the paint/mason shop. The ticket that was submitted was only for an estimate, since you have accepted the estimate. We need JIRA tickets to keep track of the labor being charge to the N#. Sorry for any inconvenience,</p> <p>N1630602</p> <p>Wendy R. Anderson Executive Assistant II General Service Administration (WPMH-C) 725 17th Street, NW Suite 2020 Washington, DC 20503 Office:(202) 395-3236 Fax:(202) 395-3027</p>

Facility Request	FACREQ-4734	east wing basement gym	Done	East Wing	<p>Good Morning Tamatha,</p> <p>GSA would like to proceed with this project, we need separate tickets for the carpenter shop, electric shop, plumbing shop, engineers, fire alarm shop, and the paint/mason shop. The ticket that was submitted was only for an estimate, since you have accepted the estimate. We need JIRA tickets to keep track of the labor being charge to the N#. Sorry for any inconvenience,</p> <p>N1630602</p> <p>Wendy R. Anderson Executive Assistant II General Service Administration (WPMH-C) 725 17th Street, NW Suite 2020 Washington, DC 20503 Office:(202) 395-3236 Fax:(202) 395-3027</p>
------------------	-----------------------------	------------------------	------	-----------	-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Facility Request	FACREQ-4735	east wing basement gym	Done	East Wing	<p>Good Morning Tamatha,</p> <p>GSA would like to proceed with this project, we need separate tickets for the carpenter shop, electric shop, plumbing shop, engineers, fire alarm shop, and the paint/mason shop. The ticket that was submitted was only for an estimate, since you have accepted the estimate. We need JIRA tickets to keep track of the labor being charge to the N#. Sorry for any inconvenience,</p> <p>N1630602</p> <p>Wendy R. Anderson Executive Assistant II General Service Administration (WPMH-C) 725 17th Street, NW Suite 2020 Washington, DC 20503 Office:(202) 395-3236 Fax:(202) 395-3027</p>
------------------	-----------------------------	------------------------	------	-----------	-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Facility Request	FACREQ-4736	east wing basement gym	Done	East Wing	<p>Good Morning Tamatha,</p> <p>GSA would like to proceed with this project, we need separate tickets for the carpenter shop, electric shop, plumbing shop, engineers, fire alarm shop, and the paint/mason shop. The ticket that was submitted was only for an estimate, since you have accepted the estimate. We need JIRA tickets to keep track of the labor being charge to the N#. Sorry for any inconvenience,</p> <p>N1630602</p> <p>Wendy R. Anderson Executive Assistant II General Service Administration (WPMH-C) 725 17th Street, NW Suite 2020 Washington, DC 20503 Office:(202) 395-3236 Fax:(202) 395-3027</p>
------------------	-----------------------------	------------------------	------	-----------	-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Facility Request	FACREQ-4737	east wing basement gym	Done	East Wing	<p>Good Morning Tamatha,</p> <p>GSA would like to proceed with this project, we need separate tickets for the carpenter shop, electric shop, plumbing shop, engineers, fire alarm shop, and the paint/mason shop. The ticket that was submitted was only for an estimate, since you have accepted the estimate. We need JIRA tickets to keep track of the labor being charge to the N#. Sorry for any inconvenience,</p> <p>N1630602</p> <p>Wendy R. Anderson Executive Assistant II General Service Administration (WPMH-C) 725 17th Street, NW Suite 2020 Washington, DC 20503 Office:(202) 395-3236 Fax:(202) 395-3027</p>
Building Issue	FACREQ-4739	East Wing RM E126 is Blowing Cold Air	Done	East Wing	
Building Issue	FACREQ-4747	Need light in office...NSC Lower Suite - back office	Done	West Wing	Half of the lights are out in the NSC Lower Suite, back office, Deputy Homeland Security Advisor. Any help you can provide to provide more lighting would be appreciated. Thanks
Facility Request	FACREQ-4751	Move Desk Out of WW 153 at 4:30pm	Done	West Wing	Please move the existing desk out of Katie Walsh's office at 4:30pm today.
Building Issue	FACREQ-4771	Could we get the set point in the VP's office	Done	West Wing	
Facility Request	FACREQ-4776	Delivery small end table from eeob room	Done	West Wing	Delivery small end table from eeob room 60 to ww VP office.

Building Issue	FACREQ-4784	Mover requested to move desk around and remove extra chair from the VP office and	Done	West Wing	per Alan Zawatsky request.
Facility Request	FACREQ-4786	Relocate Door Stop	Done	West Wing	<p>There is a floor mounted door stop behind the door that connects West Wing rooms 122 and 121. The door stop was placed so that the door didn't hit a safe that was behind the door. The safe is gone now, so they would like the door to swing open as far as possible.</p> <p>They realize that there will be a hole where the old location was.</p>
Facility Request	FACREQ-4794	Move Items to COS Suite	Done	West Wing	<p>Please assist with moving the following items from Room 60 to the COS Suite:</p> <ul style="list-style-type: none"> - 1 large white board - 1 small desk - 1 chair <p>1 small lateral file cabinet will need to be brought back also.</p> <p>Still awaiting a time to do the move</p>
Building Issue	FACREQ-4795	WW Council's Office Fly Reproduction	Done	West Wing	Please come by around 8am, because the door may be locked.
Facility Request	FACREQ-4796	Remove Desk Riser in WW 212	Done	West Wing	There is a riser under my desk in WW 212 that needs to be please be removed. It makes the desk far too tall for me and I can't raise my chair any higher. Sitting at it for 14 hours a day is starting to cause shoulder pain. Can it please be removed today or tomorrow? Thank you!
Facility Request	FACREQ-4806	Hang Photos in WW 208	Done	West Wing	Kellyanne Conway would like some photos she brought in hung on her wall ASAP.

Facility Request	FACREQ-4813	Move furniture from EW to EEOB and around office --	Done	East Wing	Move furniture from EW to EEOB and around office --COMPLETE 2/14
Facility Request	FACREQ-4816	Deliver chairs from NEOB to EEOB/WW	Done	West Wing	Taifa will call to arrange. Need Charles truck to deliver (4) chairs from Neob to WW/ eeob
Building Issue	FACREQ-4818	WW 2nd floor 217/Pest Shop; treat for insects	Done	West Wing	Treat for ants and flies in the west wing 2nd floor room 217 suite.
Building Issue	FACREQ-4819	EW 2nd floor/Electrical Shop; replace burnt out	Done	East Wing	Replace the burnt-out light bulb in the east wing 2nd floor FLOTUS Office
Facility Request	FACREQ-4824	Covert Outlet to a 4 gang	Done	West Wing	<p>There is a 2 gang outlet in West Wing room 152 that we would like to have converted to a 4 gang. The extra outlets will be used to power a TSD alarm panel.</p> <p>The outlet is the first one on the left as you walk into the room.</p>
Facility Request	FACREQ-4826	Paint Support in room 152	Done	West Wing	<p>TSD and GSA will be doing work in room 152 to install security measures. This work may require some paint touch up after completion.</p> <p>This is to fund that work if necessary.</p>
Facility Request	FACREQ-4828	Phone Relocation - WW	Done	West Wing	<p>Request support from the carpentry shop and the paint shop for the following tasks in room 121:</p> <ol style="list-style-type: none"> 1. Relocate phone on wall to opposite side of new door and add new wall mount for second phone 2. Assist with the concealment of the phone cable over the doorway 3. Patch and repaint wall were phone removed <p>Please contact Shawn Piers at 202-456-9325 to coordinate</p>

Building Issue	FACREQ-4832	WW Roosevelt Room	Done	West Wing	Malfunction: Door will not stay open
Facility Request	FACREQ-4838	Swap Desk From Room 49 to the West Wing	Done	West Wing	We would like to move an L desk from room 49 in the EEOB to Steve Miller's Office. Requesting to do this first thing Thursday morning
Facility Request	FACREQ-4839	Panduit Request	Done	West Wing	Please place Panduit in Jarred Kushner's office to cover the wires going to his TV West Wing Room 120
Facility Request	FACREQ-4857	Roosevelt Room Removal and Reset	Done	West Wing	Please assist with removing the table and chairs from the Roosevelt Room on 3/16 at 2:00pm Reset will at 4:00pm
Building Issue	FACREQ-4859	Remove TV from WW 217	Done	West Wing	There is a tv on the floor of WW 217 that needs to be removed.
Facility Request	FACREQ-4860	Remove TV from WW 217	Done	West Wing	There is a tv on the floor of WW 217 that needs to be removed.
Building Issue	FACREQ-4862	EW/Electrical Shop; inspect and clean light fixtures in FLOTUS	Done	East Wing	Check and clean all the light fixtures starting in the FLOTUS Office. This work can be completed asap
Building Issue	FACREQ-4863	EW/Paint-Mason Shop; repair cover base breaking away from	Done	East Wing	
Building Issue	FACREQ-4879	WW/Plumbing Shop, 2nd floor men's restroom, replace/repair soap	Done	West Wing	
Building Issue	FACREQ-4882	WW room 66	Done	West Wing	paint shop to replace the broken glass in the west wing ground floor room G - 66. This work can be completed tomorrow morning before 7 : 00 am

Building Issue	FACREQ-4886	run domestic water to Humidification system that services AHU # 4 WW Old Mechanical	Done	West Wing	see Mark thomas
Facility Request	FACREQ-4891	Tangled mess of wires	Done	East Wing	In the far left corner of the room - there are tons of wires and cables that are in a jumbled mess plugged into the wall. Some of the cable/wire boxes are detached from the wall. Could someone please come and reattach the boxes to the wall and try to make the wires/cables a little bit more descreet? Thank you!
Building Issue	FACREQ-4904	Check a Loose Door Knob on the Oval	Done	West Wing	
Facility Request	FACREQ-4905	Hang White Board	Done	West Wing	Please hang a white board for Austin Ramirez in West Wing Room 212. There are extra 2' by 3' white boards in EEOB 60, but they will need hardware
Building Issue	FACREQ-4918	electricians to replace the chandelier in the Oval Dining on Tuesday night anytime after 9 : 00 pm.	Done	West Wing	George has the chandelier. Painters will support if needed only.
Facility Request	FACREQ-4940	Lights out replace them, LED would now be used instead of Halogen so they would	Done	West Wing	SP6 – Light above door A4 – Vehicle Gate West Pole Light SP15 – Lights on the North side of the booth (Facing Treasury)
Facility Request	FACREQ-4943	Move 3 Varidesks	Done	West Wing	Please move 3 varidesk units from 083 to the West Wing Ground Floor. Meet Clint at 083 on Wednesday, 2/22 at 8:40am
Facility Request	FACREQ-4945	Swap desks in West Wing	Done	West Wing	Please assist with moving 2 desks from EEOB 49 to the West Wing. One L desk will be removed from the West Wing. We would like to do this first thing Wednesday morning. 7:15am

Building Issue	FACREQ-4948	WW Oval Pantry Peep Hole and Coat Hook	Done	West Wing	carpenters to install a pip-hole in the Oval Pantry.
Building Issue	FACREQ-4950	EW/Engineer Shop; too cold in office	Done	East Wing	E1-13
Building Issue	FACREQ-4959	WW G - 42; replace all the ceiling tiles in room G - 42 its a small closet	Done	West Wing	Also please add rooms G - 66 & 67 to this request
Building Issue	FACREQ-4962	WW 1st fl hallway	Done	West Wing	electricians to replace the burnt-out light bulb in the west wing 1st floor by the elevator and the NSC Office
Building Issue	FACREQ-4964	electricians to replace the burnt-out light bulb in the west wing 1st	Done	West Wing	
Building Issue	FACREQ-4965	carpenters to fix the loose thrush hold by the main entrance door	Done	East Wing	
Building Issue	FACREQ-4969	carpenters to install a pip-hole in the Oval	Done	West Wing	
Building Issue	FACREQ-4975	EW rm 222 Paint	Done	East Wing	GSA Paint shop to paint all surfaces in room 222. This will include bookcase, trim and FCU covers.
Building Issue	FACREQ-4989	WW/Carpenter-Lock Shop; repair or replace door lock	Done	West Wing	Carpenter shop for the locksmith to check the lock on the door leading into the COS office itself. Secret Service had problems just getting their key inserted into the lock to open the door this morning. They said the tumblers were real tight
Building Issue	FACREQ-4990	EW/Electrical Shop; replace burnt out light	Done	East Wing	Replace the burnt-out light bulbs in the east wing 2nd floor and 1st floor landing
Building Issue	FACREQ-5005	WW ground floor entrance is missing a	Done	West Wing	Door Opener
Building Issue	FACREQ-5009	Move 2 Veridesks	Done	West Wing	Please assist with moving 2 veridesk units from 083 to the West Wing. We would like to do this on 2/23 at 7:30am

Building Issue	FACREQ-5019	Engineer Shop for West Wing Press break room bathroom exhaust fan.	Done	West Wing	<p>Check motor functions, check and replace belt as necessary, increase hours of operation (currently tied to AHU-3 in the BAS system).</p> <p>Complaint is insufficient air movement. If the above do not remedy the issue, Shop should look to replace sheave on fan to increase RPMs, or replace motor with higher RPM motor (least favorable option).</p> <p>Basic information to assist Shop: Registers (3) are Titus model 23R 8" X 6" balanced to 100 CFM each. Fan is Cook Model 80-ACEB designed for 320 CFM at 0.25" Static at 1225 RPM.</p> <p>POC: Paul Ostazeski</p>
Facility Request	FACREQ-5040	Hang Bulletin Board in WW 142	Done	West Wing	Please hang a bulletin board that is in West Wing Office 142.
Building Issue	FACREQ-5043	WW LOWER PRESS OUTLET NOT	Done	West Wing	
Facility Request	FACREQ-5044	Desk Drawer Locked in WW 121	Done	West Wing	There is a desk drawer in WW 121 that need to be unlocked.
Facility Request	FACREQ-5047	Change white double doors fom the EW 2nd FLOTUS reception / FLO-Stephanie's office	Done	East Wing	Change white double doosr fom the EW 2nd FLOTUS reception / FLO-Stephanie Winston Wolkoff's office to wood door.
Facility Request	FACREQ-5057	Hang TV in E229	Done	East Wing	Please hang a TV in Room E229. The TV and mount are already in the room
Facility Request	FACREQ-5059	Assist with Desk Risers	Done	West Wing	Please assist the carpenter shop with placing 2 desk risers in Upper Press
Building Issue	FACREQ-5060	Replace door in First Lady's Outer Office	Done	West Wing	Please replace the 2 flat panel white doors that separate rooms E223 and E224 with a door that matches the hardwood doors throughout the East Wing
Facility Request	FACREQ-5061	Hang TV in Upper Press	Done	West Wing	Please help hang a TV in West Wing Room 140

Facility Request	FACREQ-5063	Hang TV in WW 140	Done	West Wing	Please hang the tv in the Press Secretary anteroom in WW 140
Building Issue	FACREQ-5074	electricians to replace the large chandelier in the west wing 1st floor	Done	West Wing	
Building Issue	FACREQ-5078	WW E-10 Post; replace the burnt-out light bulb in the west wing 1st	Done	West Wing	
Building Issue	FACREQ-5080	WW/Electrical Shop; replace the large chandelier in the west	Done	West Wing	
Building Issue	FACREQ-5081	EW OLA Office/Engineer Shop; check and fix the filter	Done	East Wing	
Building Issue	FACREQ-5082	EW OLA/Plumbing Shop; remove the fire extinguisher from the	Done	East Wing	
Building Issue	FACREQ-5083	EW FLOTUS OFFICE/Move Shop; move furniture	Done	East Wing	Move all the furniture back in the east wing 2nd floor FLOTUS Office. This work needs to be completed asap before 8 : 00 am this morning
Building Issue	FACREQ-5084	WW Oval pantry hallway	Done	West Wing	paint shop to caulk around the light fixture. This is the hallway between the Roosevelt room and the Oval pantry.
Building Issue	FACREQ-5085	WW by E -10 post	Done	West Wing	paint shop to caulk around the FCU which is in the west wing 1st floor by E -10 post.
Building Issue	FACREQ-5087	To Check and Adjust the W.W. O.O. Study Temperature as	Done	West Wing	
Facility Request	FACREQ-5091	Mount Whiteboard in WW 120	Done	West Wing	There is a very large whiteboard in WW 120 that needs to be mounted on the wall.
Facility Request	FACREQ-5132	Need Estimate to remove wall on 2nd floor EW	Done	East Wing	M. Sedlock has completed

Facility Request	FACREQ-5136	Provide estimate to install cabinetry on 2nd flr EW	Done	East Wing	<p>Install upper and lower cabinetry in the EW pantry - RM E213</p> <ul style="list-style-type: none"> - 45" wide double door lower cabinet and - 36" wide double door upper - countertop - Microwave shelf <p>See attached photos. Looking to expedite. We can purchase materials if needed.</p>
Building Issue	FACREQ-5140	WW Lower Press/Custodial Shop; add garbage bag to	Done	West Wing	This is in the west wing ground floor lower press suite.
Facility Request	FACREQ-5141	Provide dedicated outlet for new refridgerator & Microwave in room E213	Done	East Wing	<p>Provide dedicated outlet for new refridgerator & Microwave in room E213 2nd floor East WIng</p> <p>Need to expedite if possible.</p> <p>See attached document for location</p>
Building Issue	FACREQ-5150	Press cubicle key	Done	West Wing	I'm taking over as senior White House correspondent for Voice of America. Over the years, keys to the VOA booth in lower press have fallen by the wayside as correspondents change. We're now down to one. Since there are three correspondents, we would appreciate having two duplicates made. Can you help us get that done?
Facility Request	FACREQ-5166	Help Erin Move Fruniture to WW 120 on 3/2	Done	West Wing	<p>There is a credenza and 4 chairs that need to be moved from EEOB 083 to WW 120. This move needs to be done at 12:30 when the principal is out of the office.</p> <p>Thank you.</p>

Facility Request	FACREQ-5174	Remove Wall 2nd floor EW	Done	East Wing	<p>FACREQ- 5132 estimate approved. Please proceed to complete the work in EW 2nd floor - rooms E224 & E226 CARPENTERS</p> <p>Demo wall between FLO Comms room and FLO Press office (roughly 11 ft in length and roughly 8 ft high) Save base trim to re-use upon demolition of wall Leave a portion of the wall- bulkhead – roughly 4-6” below the ceiling grid Ensure wall removed is flush with wall that is perpendicular (near door way) Cap and finish bulkhead and wall ending at perpendicular wall Demo – remove bi-fold doors and associated trim work Install studs and drywall where bi-fold doors were Install base mold that was removed from 11 ft wall on closed in area where bi-fold doors were located</p>
Facility Request	FACREQ-5187	(2) TV Brackets For Upper Press Office & Wiring For them to Function	Done	West Wing	<p>Have two flat screen televisions in office that need brackets to hang on the wall. Once items are hung on wall, will need wiring set up for televisions to be functional.</p>
Building Issue	FACREQ-5189	PLEASE SEND SOMEONE TO LIGHT	Done	West Wing	
Building Issue	FACREQ-5191	To Locate a Temperature Sensor in the W.W. First Floor	Done	West Wing	
Building Issue	FACREQ-5192	W.W. Roosevelt Room.	Done	West Wing	To Lower the Temperature as Requested and then Return it to the Normal Settings when Notified.

Building Issue	FACREQ-5206	We are in the WH briefing room ABC News booth.	Done	West Wing	Our overhead florescent light is out.. flickering constantly.. making it virtually impossible to work. Is there someone available to come and change the bulb?
Building Issue	FACREQ-5214	REQUESTED CUSTODIAL SERVICE	Done	West Wing	Refrigerator/ items has frozen and exploded and needs cleaning out; they would like it cleaned out
Building Issue	FACREQ-5226	EW Colonnade mats	Done	East Wing	movers to take all the east wing colonnade mats down to the basement this evening at 6 : 00 pm
Building Issue	FACREQ-5230	WW Roosevelt room	Done	West Wing	movers to move 6 chairs to the hallway because of the news broadcast live in the west wing Roosevelt room.
Building Issue	FACREQ-5232	To Check the W.W. 1st Floor Dining Room FCU Operation. - Assign to the 4 to 12	Done	West Wing	
Building Issue	FACREQ-5233	To Check the W.W. Women's Room Toilet Operation by the Roosevelt Room. -	Done	West Wing	
Facility Request	FACREQ-5261	Pictures need to be hung in room G40/G41	Done	West Wing	There are some pictures, a mirror, and a clock that need to be hung. Contact Caroline Cole to coordinate - work cell - 202-881-8245.
Facility Request	FACREQ-5268	Remove Wall 2nd flr EW (Project FACREQ-	Done	East Wing	Remove Wall 2nd flr EW (Project FACREQ-5174) Carpentry
Facility Request	FACREQ-5269	Remove Wall 2nd flr EW (Project FACREQ-5174) Move shop	Done	East Wing	MOVE SHOP credit card if needed - no RWA * remove furniture before project starts - re-install furniture upon project completion
Facility Request	FACREQ-5270	Remove Wall 2nd flr EW (Project FACREQ-	Done	East Wing	Remove Wall 2nd flr EW (Project FACREQ-5174) Electric shop

Facility Request	FACREQ-5271	Remove Wall 2nd flr EW (Project FACREQ-5174) Paint shop	Done	East Wing	PAINT / MASON Tape, mud and sand new drywall - including bulk head and side wall areas Prime and Paint wall areas affected Prime and Paint new drywall Prime and Paint new trim work Caulk, seal wall where it meets the other walls/ceiling and trim work associated Repair any drywall (as needed)
Facility Request	FACREQ-5275	Remove Wall 2nd flr EW (Project FACREQ-	Assigned to Shop	East Wing	Remove Wall 2nd flr EW (Project FACREQ-5174) Admin ticket for carpet
Facility Request	FACREQ-5277	EW First Lady's office suites in rooms E 224 and E 226. (East Wing, 2nd floor)	Done	East Wing	Engineer shop - secure and cover fan coil units with plastic at the start of the job - remove and PM units at end of the job
Building Issue	FACREQ-5279	EW First Lady's office suites in rooms E 224 and E 226. (East Wing, 2nd floor)	Done	East Wing	Fire alarm shop- Cover fire / smoke devices with safety bonnets upon start of job Remove at end of job
Building Issue	FACREQ-5282	WW SIT Room	Done	West Wing	carpenters to check and fix the SIT room door which doesn't close properly. This door is facing the Navy mess
Building Issue	FACREQ-5289	Broken door	Done	West Wing	My name is Shannon Augustus and I'm the C-SPAN/AP producer in the booth in the basement. My door for the last couple of months has been really difficult to open- I think it might be broken or off one of the hinges. Is this the correct contact for this kind of issue?
Building Issue	FACREQ-5290	A console needs to be moved from room 330 of the EEOB to the	Done	West Wing	Contact Caroline Cole (69303) or Laura Gohlke (69302) to coordinate.

Facility Request	FACREQ-5291	Hang Wall Mount for Phone	Done	West Wing	Please hang a wall mount for a secure phone for Abe in West Wing Room 120.
Building Issue	FACREQ-5294	custodian shop to dust and clean all the furniture in the west wing ground floor	Done	West Wing	
Building Issue	FACREQ-5299	WW/Electrical Shop; flickering lights in rm.	Done	West Wing	
Building Issue	FACREQ-5302	EW Colonnade mats	Done	East Wing	movers to lay down all the east wing colonnade mats. This work can be completed this evening at 5 : 00 pm.
Building Issue	FACREQ-5307	Fluorescent bulb replacement	Done	West Wing	It appears that three tube lamps are out on the VP's ceiling. This is high priority for the following time window. The office will be available between 12PM and 3PM today.
Facility Request	FACREQ-5309	Furniture Moves in Press Secretary's Office	Done	West Wing	<p>1) Press Secretary Spicer would like the safe removed from his office today. ***In it's place, he would like a skinny 3-4ft banquet table.</p> <p>2) A printer is being installed this afternoon at 1:45pm in Secretary Spicer's office. ***He would like a small side table (large enough to set a printer on) delivered.</p> <p>thanks</p>
Building Issue	FACREQ-5316	electricians to replace the burnout light bulb on east portico out for a	Done	West Wing	

Facility Request	FACREQ-5321	Safe Moves	Done	West Wing	<p>Please move 1 safe from EEOB 49 to the 2nd floor of the West Wing.</p> <p>Then 2 safes from the 2nd floor of the West Wing will need to be moved to the Lock Shop in the NEOB.</p> <p>See Clint for details</p>
Building Issue	FACREQ-5333	Project in West Wing 210 & 211	Done	West Wing	Painters -- Prime and paint WW 210 & 211 to tenant's desired color. Remove shelves from cabinet unit, and temporarily remove and replace curtain rods. Paint existing bookshelf and any additional pieces produced by the carpenters to match.
Building Issue	FACREQ-5334	Project in West Wing 210 & 211	Done	West Wing	Electric -- Replace all receptacles, light switches, and cover plates to bright white. Pull electrical to the back of the bookshelf. Possibly also TV cable, to be determined by WHCA
Building Issue	FACREQ-5335	Project in West Wing 210 & 211	Done	West Wing	<p>Carpenters -- Fabricate and install a panel to cover bottom half of bookshelf (to chair rail height), removable if possible. Fabricate and install a countertop. Cut center divider, remove adjustable shelf standards, and patch the impacted areas as needed.</p> <p>Furnish and install a plywood backing to cover the existing back of the bookshelf. Mount TV, to be provided by tenant.</p>

Facility Request	FACREQ-5336	Press Secretaries Office - Glass Top for Round Table, Coin Display Case for Office Wall	Done	West Wing	<p>1) Secretary Spicer mentioned that David from GSA could provide a glass top for the round table in his office. Please let me know how to go about getting this placed.</p> <p>2) He is also requesting a coin display case for his challenge coins. This will need to be hung on the wall.</p> <p>thanks</p>
Facility Request	FACREQ-5345	Remove Mounted Wall Map Out of WW G47	Done	West Wing	There is a mounted wall map in G47 in the West Wing that needs to be taken off the wall.
Building Issue	FACREQ-5353	Knobs on Cabinets Missing	Done	West Wing	<p>Upper Press Office cabinets are missing knobs. Could someone please fix so they are all matching?</p> <p>thanks</p>
Building Issue	FACREQ-5361	EW Colonnade/Move Shop; remove mats	Done	East Wing	Take all the mats down to the basement asap.
Building Issue	FACREQ-5368	Please pick up dead mouse WW rm 205	Done	West Wing	
Building Issue	FACREQ-5370	WW ZONE W2-59 TOO COLD	Done	West Wing	
Facility Request	FACREQ-5375	West Wing Office Moves	Done	West Wing	<p>Requesting assistance on the morning of Thursday, March 9 at 7:15am.</p> <p>We have a few things that need to be moved:</p> <ul style="list-style-type: none"> - L desk from West Wing to 60 - Chair from West Wing to 60 - Small sofa from 60 to West Wing - Chairs from 60 to West Wing - Small table from 60 to West Wing

Facility Request	FACREQ-5379	Please move sofa and cabinets for Bethany Scully WW 221. Thanks,	Done	West Wing	Please move sofa from EEOB Room 207 and cabinet around in office for Bethany Scully WW 221. This is the same ticket as WHO ticket WFR-263. RDS delivered sofa on 3.8.2017 and the move shop will deliver it this week. Thanks, please let me know if you have any questions or concerns.
Building Issue	FACREQ-5380	Install 2 Bug Lights in the W.W. Kelli Anne Conway Office (Zone#	Done	West Wing	
Building Issue	FACREQ-5381	electricians to replace the burnt-out light bulb in the west wing by	Done	West Wing	
Building Issue	FACREQ-5382	West Wing Room 210 & 211 and move it to G-62 on Thursday, March 9 at 5 PM, and put furniture back on	Done	West Wing	I can walk through the work with them tomorrow morning.
Building Issue	FACREQ-5387	plumbers to unclog the drain in the east wing 2nd floor office of	Done	East Wing	
Facility Request	FACREQ-5392	Furniture touch up	Done	West Wing	The legs of the 2 Martha Washington chairs in front of the VP WW office fireplace need refinished. The tops of the two side tables also need refinished. It would be best to complete this in the April 16-23 time window.
Facility Request	FACREQ-5396	Help hang pictures in WW203	Done	West Wing	There are a few photos in West Wing 203 that they are requesting be hung on the walls.
Building Issue	FACREQ-5409	elevator shop to fix the loose door closer	Done	West Wing	This is at the main entrance door to the Press Briefing Room. Can someone please take a look at this first thing tomorrow morning.

Building Issue	FACREQ-5413	electricians to check/fix the flickering light bulb/bulbs in the west wing OOO. Let me	Done	West Wing	
Facility Request	FACREQ-5415	Install draperies in the FLOTUS office EW 2nd floor	Done	East Wing	<p>* Update*</p> <p>Please proceed with the drapery steaming.</p> <p>Install draperies in the FLOTUS office EW 2nd floor.</p> <p>Please reference the designers photo and instructions. See attached</p> <p>*+Designers Instructions+*</p> <p>The ceiling is 103" from floor to ceiling, I ordered 96" to give the overall effect of the room being taller. I would like the drapery to break the floor, touching but not puddling. The rod ordered should extend to 48" , I want the rod to be installed where the drapery when stationary to be just breaking the window line, allowing the FL to open and close the shutter easily.</p>
Building Issue	FACREQ-5420	To Check a Loose Door in the W.W. Press	Done	West Wing	
Building Issue	FACREQ-5424	EW Colonnade mats	Done	East Wing	movers to lay down all the east wing colonnade mats. The mats are in the east wing basement. This work can be completed at 5:00 PM.
Building Issue	FACREQ-5433	Door release button in the Situation Room needs to be replaced	Done	West Wing	J.D. Fuchs is the point of contact

Facility Request	FACREQ-5441	Move Assistance on Friday	Done	West Wing	<p>Requesting help doing a few moves on 3/10 at 1:30pm. We would like to do the following:</p> <ul style="list-style-type: none"> - Move 1 table desk from room 51 to the West Wing - Move 1 L desk from the West Wing to EEOB room 158 - Move chairs from room 60 to the West Wing
Building Issue	FACREQ-5444	DESK DRAWER IS JAMMED UPPER	Done	West Wing	
Building Issue	FACREQ-5446	WW 2ND FLOOR MEN'S ROOM	Done	West Wing	handicapped interior door closer on the West Wing 2nd floor Men's Room is stuck in the open position. Could you please put in a service request to have it reset or repaired?
Facility Request	FACREQ-5447	Hang Pics in Counsel's Office	Done	West Wing	<p>Please assist Greg Katsas with hanging his pictures in WW 203</p> <p>I spoke to Jim about doing this on Friday, March 10.</p>
Building Issue	FACREQ-5455	Place a Bug Light Today and to Remove it on Sunday at 10:00 PM in the E.W. Zone#	Done	East Wing	
Building Issue	FACREQ-5458	WW COS PLEASE REPLACE BUZZING	Done	West Wing	

Facility Request	FACREQ-5469	Need Levelers	Done	West Wing	<p>Michael Dubke has a desk in West Wing room 141. It's a table style desk that he would like to raise a little.</p> <p>The desk has 1/4-20 inserts in the legs but there are no levelers screwed into them.</p> <p>Please install new levelers and raise the desk as much as the levelers will safely permit.</p>
Facility Request	FACREQ-5472	Hang Pictures in WW 210	Done	West Wing	Please hang pictures in WW 210 ASAP. This is a request from a VIP. Please reach out to Rachel Baitel with any questions.
Facility Request	FACREQ-5475	Please take coat rack to WW Room 221. Thanks	Done	West Wing	Please pull used coat rack from EEOB Rooms 60, 53-58 and take to WW Room 221. POC: Catherine Curry 6.7878. Thanks, please let me know if you have any additional questions or concerns. Kimberly Pope 5.2646.
Facility Request	FACREQ-5476	3 VP hangings	Done	West Wing	The VP would like three things hung in the West Wing office. Best time for this today is at 3 PM. POC Mary Wells 61250
Facility Request	FACREQ-5477	VP globe	Done	West Wing	Two screws need tightened/replaced on the globe in the VP's office. POC Mary Wells 61250. Best time for this would be 3:00 PM today.
Building Issue	FACREQ-5480	EW/Electrical Shop; replace burnt out light bulb in the following	Done	East Wing	FLOTUS reception room on the 1st floor EW 1st Floor Landing
Building Issue	FACREQ-5487	WW/Plumbing Shop; repair dysfunctional toilet	Done	West Wing	The women's bathroom outside the RR is not flushing easily and is constantly "singing"/making a running water noise.
Building Issue	FACREQ-5488	EW/Carpenter Shop; repair window in FLOTUS office; window	Done	East Wing	

Facility Request	FACREQ-5495	Hang TV in WW 215	Done	West Wing	Please mount a tv on the wall in WW 215 for an AP. This request needs to be completed on Wednesday, March 15, as he will be out of the office at that time.
Building Issue	FACREQ-5497	WW NM pest control to treat for cockroaches in the dining rooms,	Done	West Wing	
Building Issue	FACREQ-5498	To Raise the COS Office Temperature as Requested. - Assign to	Done	West Wing	
Building Issue	FACREQ-5499	To bring the VP more Firewood. - Assign to	Done	West Wing	
Facility Request	FACREQ-5504	Hang TV in WW 225	Done	West Wing	Please mount a tv on the wall of WW 225. The tv mount is already in the office.
Facility Request	FACREQ-5508	Pack and move 2 boxes from COS office	Done	West Wing	
Building Issue	FACREQ-5511	WW/Landscape Shop; place a bug light bulb in rm. 221 Zone - 56	Done	West Wing	
Building Issue	FACREQ-5515	electricians put a cover plate over the now exposed outlet in WW Chief of Staff's Office	Done	West Wing	
Building Issue	FACREQ-5523	Move (6) chairs and coffee table to WW press office	Done	West Wing	Move (6) chairs and coffee table to WW press office on Wednesday - March 15th Kimberly Pope will call with time. Move from EEOB rm 60 to WW 1st floor
Facility Request	FACREQ-5525	Hang TV in WW 223	Done	West Wing	There is a television that needs to be mounted in WW 223. The mount has already been provided.

Facility Request	FACREQ-5526	Move small credenza to WW122	Done	West Wing	Laura Nasim in WW122 would like a small credenza moved near her desk. It will be inside of room 51 marked. She would like this done "first thing" in the morning and she arrives before 8am.
Facility Request	FACREQ-5529	Estimate Request for Work in West Wing Room G47	Estimate Complete	West Wing	<p>Requesting an estimate for doing the following work in G47:</p> <ul style="list-style-type: none"> * Place an X10 (or X09) at the G47 primary door; and, reset the access control (reset keypad) that require access to G47 * Gaskets and sweeps at the primary door * Blind or curtains on the windows * We also need the conduit penetrations in the ceiling filled with acoustic sealant; and, a concrete punch-out in the ceiling filled with masonry (toward the back corner of the space).
Building Issue	FACREQ-5535	Hang picture in room 1A of the West Wing	Done	West Wing	This task was completed earlier since it was a rush job.
Facility Request	FACREQ-5554	Hang 3x5 whiteboard in G-50	Done	West Wing	<p>Reed Cordish's office has a 3x5 white board they would like to hang up.</p> <p>Call Quellie Moorhead to coordinate.</p>
Building Issue	FACREQ-5556	WW PS NEED FIREWOOD	Done	West Wing	
Building Issue	FACREQ-5565	To Check the Alarm on the E.W. Colonnade	Done	East Wing	
Facility Request	FACREQ-5568	VP's WW bookshelf	Done	West Wing	The VP would like one of his WW bookshelves repaired. Believe the need to be minor. Best time would be tomorrow, Thursday, 3/16, between 12-4 PM. POC: Mary Wells, 6-1250

Facility Request	FACREQ-5570	Move Small Table to West Wing	Done	West Wing	<p>Please complete at 2:30 Thursday March 16th</p> <p>Please assist with moving a racetrack table from outside room 49 (see attached pic) Take to West Wing- 1st flr Press Secretary office(Spicer) POC: Vanessa Morrone</p> <p>Then take the press secretary's old round table to the ground floor room G39 West Wing Ground Floor. Room G38 - POC: Jessica Ditto</p>
Facility Request	FACREQ-5576	Move Bookcase in East Wing	Done	East Wing	<p>Please assist with moving a glass front bookcase in the East Wing</p> <p>ALREADY COMPLETED on 3/16</p>
Facility Request	FACREQ-5577	Hang Mirror	Done	East Wing	Please hang a mirror in East Wing Room E126. The mirror is in the room and has wire on the back.
Facility Request	FACREQ-5579	Remove Cabinet and Map from West Wing	Done	West Wing	<p>Please remove 1 dresser(?) and a large framed map from the West Wing Ground floor.</p> <p>I spoke to Bushrod about these items, and they were removed on 3/16</p>
Building Issue	FACREQ-5584	engineers to raise the temperature zones 2 E - 10 and E - 2F.	Done	West Wing	
Building Issue	FACREQ-5586	Ants in the window sill Chief of Staff office. I , Removed a lot by killing them, can someone tell	Done	West Wing	

Building Issue	FACREQ-5589	move shop move the paper cabinet in the West Wing basement	Done	West Wing	
Building Issue	FACREQ-5591	Remove/Reinstall door from broom closet in west wing	Done	West Wing	Remove door from broom closet in west wing before Saturday at 9 am Put back in after Saturday at 5 pm
Building Issue	FACREQ-5593	FIRE ALARM SHOP RESPONDED TO A BEEPING NOISE IN	Done	West Wing	
Building Issue	FACREQ-5595	To adjust the Temperature in the W.W. Sit Room Box#	Done	West Wing	
Building Issue	FACREQ-5601	electricians to reset the beaker for the stove	Done	West Wing	
Facility Request	FACREQ-5603	Please move coffee table from 083 to Spicer's office. WW Room 145. Thanks,	Done	West Wing	Please assigned this ticket to Mr. Bushrod or Charles. Can you please take a new oval coffee table from outside of Basement 083 and replace it with the coffee table in Spicer's WW Office. WW Room 145. POC: Taifa Coger 5.2984 Thanks,
Facility Request	FACREQ-5626	40-44inch Flatscreen TV and Wall Mount	Done	West Wing	Communications Director Dubke would like a 40-44inch flatscreen mounted to wall in his office. Wall mount will need to be supplied.
Facility Request	FACREQ-5628	Work in CNN Booth	Done	West Wing	Requesting the following work in the CNN Booth: - Hang a new IT equipment rack in the wall. They are providing the new rack - Fabricate and install a new section of C-top where the old rack was
Building Issue	FACREQ-5630	Please adjust temp in ladies room in the WW near the Roosevelt	Done	West Wing	

Building Issue	FACREQ-5632	West Wing Lower Press office raised by a	Done	West Wing	
Building Issue	FACREQ-5635	To Lower the Temperature in the	Done	West Wing	
Facility Request	FACREQ-5647	New Paint and Carpet for broom closet in suite 1C of West Wing	Done	West Wing	Weekend project if possible. Small space but furniture will need to be moved out. Contact Resource Management to coordinate - 69301
Facility Request	FACREQ-5655	Seeking design/decorating advice for Gen McMaster	Done	West Wing	General McMaster met with "the decorator" a couple of weeks ago and would like to hire additional help/guidance. I initially thought Gen McMaster's staff was asking about Taifa Coger, but she believes it would have been George Kanellos, GSA Historian. I'm seeking an estimate of the hourly rate for Mr. Kanellos' expertise. Thank you. Wendy Gray
Building Issue	FACREQ-5659	Place large glass on tabletop	Done	West Wing	Please place large glass on NSA's table in the West Wing, Upper Suite on Wednesday the 22nd at 0615AM. Also, please move the smaller glass from room 330 to the EEOB basement outside of room 51. POC: Caroline Cole - 69303
Building Issue	FACREQ-5662	To Clean Ink Up from a Pen that Exploded in the W.W. Room# 217A	Done	West Wing	
Facility Request	FACREQ-5665	Hang Two Pictures in Press Secretary's	Done	West Wing	There are two pictures in Sean Spicer's office that he would like to have mounted.
Building Issue	FACREQ-5672	Toilet in men's room in WH press area is	Done	West Wing	

Building Issue	FACREQ-5679	paint shop to do some touch up work in the west wing 2nd floor room 217 (you will see	Done	West Wing	The main entrance door and also the door leading to OOO.
Building Issue	FACREQ-5700	WW RR/Move Shop; remove/return furniture	Done	West Wing	from the RR room at 9 am and return at 12:30 pm.
Facility Request	FACREQ-5701	Arrange Office in West WIng	Done	West Wing	Requesting assistance arranging an office on the 2nd floor of the West Wing. Nothing needs to be brought in or removed. But several items will need to be moved within the space. Requesting 2 or 3 guys and a dolly on 3/22 at 7:30 AM
Building Issue	FACREQ-5702	WW LP/Engineer Shop; raise the temperature at zone	Done	West Wing	
Facility Request	FACREQ-5709	Hang pictures	Done	West Wing	We need these pictures hung on Wed. March 22 between 9:15 am and 1:30 pm.

Facility Request	FACREQ-5710	Direct TV/DVR in the West Wing	Done	West Wing	<p>We received word from Mary Wells that the VPOTUS would like to have Direct TV DVR set up in his office in the WW.</p> <p>We would need GSA electricians to run (RG-6 quad shield) cable from WW WT-8 to the location where the DirecTV DVR/TV will be located in the VP's office. We have the DirecTV DVR on hand. Once the cable is run we need to do about an hour's worth of work in WW WT-8 and then connect DVR/TV and test.</p> <p>POC coordination Erin Mew 202-456-3712</p> <p>POC technical aspects Roger Sparks Broadcast Systems Supervisor Visual Information Command White House Communications Agency w: 202-757-2626 c: 202-814-8130</p>
Facility Request	FACREQ-5720	Hallway Jumbo Hardware	Done	East Wing	<p>East Wing staff would like the jumbos hung on the hallway wall on 3/27</p> <p>New hardware will need to be installed for the jumbo frames</p>
Facility Request	FACREQ-5721	Power and Cable drop in FLOTUS's Office	Done	East Wing	FLOTUS is requesting a new 60" TV in her office. We'll need to have power and cable installed behind where the TV is being mounted.
Building Issue	FACREQ-5724	Please light the PS fireplace	Done	West Wing	

Building Issue	FACREQ-5730	WW RR	Done	West Wing	plumbers the sink in the women's bathroom by the Roosevelt seems to be leaking. When the hot water faucet is turned on, a steady stream of water leaks on the surface of the counter. Please let me know when you have completed.
Building Issue	FACREQ-5731	WW ground floor	Done	West Wing	paint shop to patch / paint the hole. This is in the west wing ground floor main entrance foyer
Building Issue	FACREQ-5732	WW 1st floor Oval hallway	Done	West Wing	electricians to replace the burnt-out light bulb in the west wing 1st floor by Oval pantry hallway.
Building Issue	FACREQ-5745	Press Secretary Office Trying to light the	Done	West Wing	
Building Issue	FACREQ-5752	RR Medal of Honors Recipients	Done	West Wing	movers to move/return the furniture in the RR on Friday 3/24/2017 at 3 pm and 5 pm.
Facility Request	FACREQ-5757	Please Hang a Whiteboard in EW 100	Done	East Wing	A whiteboard needs to be hung on the wall in EW 100.
Building Issue	FACREQ-5759	movers support some painting in the East Wing.	Done	East Wing	Will will need to have the table and chairs in E212 removed tomorrow at 7 AM. I will also have a few pieces that need to be disassembled and moved around 5 pm on Friday. Reassembly and moves will be needed at 7 AM on Monday, and on Monday at 4 pm. I will give the move shop a call if/when the schedule changes.
Building Issue	FACREQ-5770	WW 210	Done	West Wing	Paint shop fill any gaps/cracks in the woodwork in WW 210. There are a few that are visible because of the white paint. Also paint the air grates in the ceiling white in WW 210.

Building Issue	FACREQ-5775	To Check the W.W. Press Secretary Office for Smoke in the Office.	Done	West Wing	
Facility Request	FACREQ-5776	Remove 1 desk	Done	West Wing	Please remove 1 desk from the West Wing 2nd Floor on 3/24
Facility Request	FACREQ-5777	Cut File Rails	Done	West Wing	Please cut eight 12" file rails
Facility Request	FACREQ-5779	Move furniture in FLO-Offices in EW	Done	East Wing	Meet Taifa at step to go over to EW at 9:20 am Friday March 24th 2-3 guys to move furniture around in FLO - offices.
Building Issue	FACREQ-5784	EW Halls	Done	East Wing	Paint shop to prep and paint common area halls to new colors for EW. Work to include all ceilings, walls and all trim and doors (where applicable)
Building Issue	FACREQ-5787	WW VIP Lobby/Carpenter Shop; fix door	Done	West Wing	Fix the door by adding stop at head needs to be taller and the right door needs to be shimmed.
Building Issue	FACREQ-5789	WW NM	Done	West Wing	plumbers to unclog the drain by the garbage disposal (dishwasher) let me know what you find out? This work can be completed before 5 : 00 am Friday.
Building Issue	FACREQ-5794	To Take More Firewood to the W.W.	Done	West Wing	
Facility Request	FACREQ-5795	Please patch and paint hole above white board	Done	East Wing	A whiteboard needs to be hung on the wall in EW 100.
Building Issue	FACREQ-5800	PS NEED MORE FIREWOOD	Done	West Wing	
Facility Request	FACREQ-5801	Hang photo in West Wing	Done	West Wing	Photo needs to be placed in jumbo frame and hung on wall in room G40. POC: Caroline Cole

Building Issue	FACREQ-5804	Engineer shop and the Sheet Metal shop	Done	West Wing	look at the feasibility and pricing if necessary to provide adequate air supply and return in West Wing rooms 120, 121, 152, and 153. The rooms have dividing walls in them that were built in 2009 that currently do not go all the way up to the ceiling. The customer is asking to have the walls extended all the way up to the ceiling completely dividing the offices. We are concerned about air flow in the divided offices and if what is existing is adequate or will we have to be split the supply and return to support the now divided rooms, etc. A TSD escort will be required when you go into the rooms or up above the ceiling
Building Issue	FACREQ-5805	CLONE - Engineer shop and the Sheet Metal shop	Done	West Wing	look at the feasibility and pricing if necessary to provide adequate air supply and return in West Wing rooms 120, 121, 152, and 153. The rooms have dividing walls in them that were built in 2009 that currently do not go all the way up to the ceiling. The customer is asking to have the walls extended all the way up to the ceiling completely dividing the offices. We are concerned about air flow in the divided offices and if what is existing is adequate or will we have to be split the supply and return to support the now divided rooms, etc. A TSD escort will be required when you go into the rooms or up above the ceiling
Building Issue	FACREQ-5812	EW Stairwell	Done	East Wing	Mason shop to scrape and patch wall on lower stair of the EW. Wall is loose and needs to be popped off, skimmed and painted.

Building Issue	FACREQ-5815	West Wing Women's Restroom Near Press Secretaries Office	Done	West Wing	Toilet overflowing in Women's Restroom outside Press Secretary's Office
Building Issue	FACREQ-5818	EW/Flotus Suite/Carpenter Shop; rehang a rod; fallen and	Done	East Wing	
Building Issue	FACREQ-5819	EW Social Office/Carpenter Shop;	Done	East Wing	
Building Issue	FACREQ-5820	WW RR/Plumbing Shop; toilet overflowing	Done	West Wing	
Building Issue	FACREQ-5821	WW RR/Move Shop; remove table, see below	Done	West Wing	Date/Time: Monday, 3/27 @ 3PM Event: Bill Signing Table removal start time: 1:30 PM Table re-installation: Approx. 4/4:30 PM
Building Issue	FACREQ-5832	WW VIP Lobby	Done	West Wing	electricians to replace the burnt-out light bulb in the west wing by VIP Lobby entrance
Building Issue	FACREQ-5835	East Wing OLA Room 129 could you please remove the fire extinguisher from this	Done	East Wing	
Building Issue	FACREQ-5837	WW ZONE 1W-20 TOO WARM CHANGE	Done	West Wing	
Building Issue	FACREQ-5845	EW/Electrical Shop;	Done	East Wing	Replace the burnt-out light bulb in the east wing 1st floor landing.
Facility Request	FACREQ-5855	Remove Hanging Mirror from Andrew Bremburg	Done	West Wing	Small hanging mirror he would like to remove.
Building Issue	FACREQ-5862	carpenters fabricate blocks to be installed and secure windows in the East and West	Done	West Wing	
Building Issue	FACREQ-5863	carpenters install the blocks to securely close the windows in the East	Done	West Wing	

Building Issue	FACREQ-5875	Obstructed Outlets w/ Paint	Done	East Wing	There is an individual who is VIP who is in need of assistance in the 2nd floor East Wing Corridor. The outlets that he needs to use are obstructed by paint. He is requesting immediate assistance. John 202-814-5770
Building Issue	FACREQ-5886	Change lightbulb in WW 227B.	Done	West Wing	One of the lights in the inner office of 227B is flickering like a strobe light. Call Richard if needing any clarification
Building Issue	FACREQ-5889	WW Cabinet Room/Electrical Shop; replace burnt out light	Done	West Wing	*CEREMONY BEGINS @ 10:30 AM.
Facility Request	FACREQ-5890	Hang Photos in WW 221	Done	West Wing	Marc Short has two presidential photos that need to be hung in his office.
Facility Request	FACREQ-5895	Hang Pictures in the Press Secretary's	Done	West Wing	Please hang a few pictures on the wall in the press secretary's office.
Facility Request	FACREQ-5908	Fix Drawer on Credenza in Chief of	Done	West Wing	Please fix the drawer on the credenza of the COS's office in the WW.
Facility Request	FACREQ-5913	Take chairs to WW - Completed March 29th	Done	West Wing	Take chairs to WW - Completed March 29th
Facility Request	FACREQ-5927	Security Upgrades in 209	Done	West Wing	Please perform the following work to West Wing Room 209 <ul style="list-style-type: none"> - Replace door with solid core flat panel door - Install X-10 lock (we can supply) - Install trilogy lock - install sound gaskets - install door closer - install blinds on windows Installing the new door and X-10 lock should happen ASAP.

Facility Request	FACREQ-5942	A-2 INTERIOR LIGHTS INOPERABLE	Done	West Wing	SGT. HILLIARD/GSA EMAILED SGT. DONATO Per Tim Bunker email order the new light fixture
Facility Request	FACREQ-5947	SP-4 EXTERIOR OUTLET COVER	Done	East Wing	LT. TYLER/GSA E-MAILED BY SGT. COSGROVE
Facility Request	FACREQ-5948	SP-4 NORTH AND EAST WINDOW BLINDS ARE BROKEN	Done	East Wing	SGT. KELLS/GSA E-MAILED BY LT. MILLER
Facility Request	FACREQ-5949	SP15 WEST AND SOUTH FLOOD	Done	East Wing	LT. GENOVESE/GSA E-MAILED BY SGT. MOORE
Facility Request	FACREQ-5951	E1 HANDICAP ASSIST BUTTON NOT	Done	West Wing	VARNER/GSA EMAILED BY LT. STANTON
Facility Request	FACREQ-5959	Requesting 2 Estimates for Press Breifing Room Door	Estimate Complete	West Wing	The Bloomberg radio booth in the basement of the PBR has a solid core wood door with no windows. They would like to have a window of some kind like all of the other doors in the PBR. Requesting estimates for 2 scenarios: - Replace current door with a door that is consistent with all of the other doors. Metal clad, sound proof door - Install a window in the current door. It can be in the upper section only. The window should be insulated, double pane, and tempered
Facility Request	FACREQ-5968	POST SP4 NORTH EXTERIOR LIGHT IS	Done	East Wing	
Facility Request	FACREQ-5971	Hang picture in Suite 1B of West Wing	Done	West Wing	Large heavy picture - coordinate with Caroline and I can show you where to hang it. Thanks!

Facility Request	FACREQ-5978	Paint touch-up in VP WW office	Done	West Wing	There is a large spot of chipped paint on the west door jamb of the doorway between the VP's WW office and the office's anteroom. See the attached photo. Could this be touched-up over the weekend?
Facility Request	FACREQ-5983	Couch Cleaning	Done	West Wing	Please clean couch in West Wing room 213
Facility Request	FACREQ-5990	Hang up TV in Upper Press WW	Done	West Wing	Michael Dubke would like his TV hung on the wall in the upper press pen of the West Wing.
Facility Request	FACREQ-5991	Hang Pic in PBR Booth	Done	West Wing	Please hang a picture for Jon Decker in the Fox News Radio booth on 4/4 at 10:00am.
Building Issue	FACREQ-5998	movers to move one chair from the EEOB room 1 to the east wing FOTUS office. This is	Done	East Wing	
Building Issue	FACREQ-6001	To Adjust the Temperature Up as Requested in the W.W.	Done	West Wing	
Building Issue	FACREQ-6003	plumbers Not be power wash Navy Mess this weekend (Sunday).	Done	West Wing	
Building Issue	FACREQ-6014	WW/Electrical Shop; replace burnt out light bulb in WW 1st floor	Done	West Wing	
Facility Request	FACREQ-6034	SP4-DOOR STICKS, ISSUES WITH THE LOCKING	Done	East Wing	
Facility Request	FACREQ-6035	SP15B-DOOR WILL NOT SECURE, IT CAN BE PULLED OPEN	Done	East Wing	
Facility Request	FACREQ-6038	B14-DOOR HAS A CONE HOLDING THE DOOR OPEN SO THE OFFICER DOESN'T	Done	East Wing	

Facility Request	FACREQ-6039	B14-PEDESTRIAN GATE WILL NOT	Done	East Wing	
Facility Request	FACREQ-6048	Help relocate furniture within WW - 9pm tonight	Done	West Wing	Joe Hagin moving furniture to Katie Walsh old office outside of CoS Office WW153. Erin Mew, Erin Harmon, David Jaghdane are working on this. Ticket submitted for billing.

Generated at Tue Oct 10 13:03:02 EDT 2017 by Wendy Anderson(GSA) using JIRA 6.4.8#64023-sha1:bab67909c2db06635b1b75f73ed75eedd9fa1015.

GSA Shop	RWA	Created
Carpentry Shop, Lock Shop		6/17/2016 17:32
Electrical Shop	OA - OCLO	6/22/2016 6:37
Paint Shop	OA - OCLO	6/22/2016 6:43
Carpentry Shop		6/24/2016 14:45
Paint Shop		6/24/2016 14:51
Custodial Shop		6/24/2016 14:56
		6/24/2016 15:05
Paint Shop		6/24/2016 15:09
Building Manager		6/24/2016 15:12
Engineering Shop		6/24/2016 15:17
Elevator Shop		6/27/2016 13:48
Building Manager		6/27/2016 13:52

Paint Shop		6/27/2016 13:59
Carpentry Shop	NSC - F1589148 FY17 Misc Services	6/29/2016 11:37
Electrical Shop, Plumbing Shop	WHMO - F1593671 FY17 Conference Room	7/5/2016 8:06

Carpentry Shop	WHMO - F1593671 FY17 Conference Room	7/5/2016 8:08
Move Shop	WHO - F1581324 FY17 Misc Services	7/5/2016 18:00
Elevator Shop		7/6/2016 10:46

Carpentry Shop		7/6/2016 12:48
Plumbing Shop		7/6/2016 12:50
Engineering Shop		7/6/2016 13:08
Electrical Shop		7/7/2016 9:28
Custodial Shop		7/7/2016 9:35
Pest Shop		7/7/2016 9:43
Pest Shop		7/7/2016 12:48
Carpentry Shop		7/8/2016 8:36
Carpentry Shop	OA - WW Rm	7/8/2016 8:45

Carpentry Shop		7/8/2016 11:53
Custodial Shop		7/8/2016 13:45
Elevator Shop		7/8/2016 15:45
Carpentry Shop, Building Manager		7/11/2016 8:18
Building Manager		7/11/2016 8:22
Electrical Shop	OA - OCLO	7/11/2016 8:27
Engineering Shop		7/11/2016 12:22
Carpentry Shop, Lock Shop	USSS - F1616451 FY17	7/11/2016 16:49

Move Shop	WHO - F1581324 FY17 Misc Services	7/11/2016 16:51
Engineering Shop		7/12/2016 13:11
Engineering Shop		7/12/2016 16:01
Move Shop	WHO - F1581324 FY17 Misc Services	7/13/2016 10:37
Elevator Shop		7/13/2016 11:36
Engineering Shop		7/13/2016 12:17
Plumbing Shop		7/13/2016 15:35
Custodial Shop		7/14/2016 8:41
Engineering Shop		7/14/2016 14:01

Carpentry Shop		7/15/2016 8:37
Engineering Shop		7/15/2016 11:50
Paint Shop		7/15/2016 12:18
Carpentry Shop	NSC - F1616561 FY17 Miscellaneous Services for White House	7/15/2016 12:44
Carpentry Shop	USSS - F1619843 FY17 Guard Booth Misc Services	7/18/2016 11:02
Electrical Shop		7/18/2016 12:43
Carpentry Shop	OA - OCLO	7/18/2016 12:45
Paint Shop		7/18/2016 13:17
Engineering Shop	USSS - F1619843 FY17	7/18/2016 15:56
Electrical Shop		7/18/2016 15:57

Move Shop		7/19/2016 12:06
Engineering Shop		7/19/2016 13:25
Engineering Shop		7/19/2016 16:42
Custodial Shop		7/20/2016 10:23
Plumbing Shop		7/20/2016 10:24
Carpentry Shop	OA - OCLO	7/20/2016 10:30
Engineering Shop		7/20/2016 10:41
Paint Shop		7/21/2016 7:01

Custodial Shop		7/21/2016 9:32
Electrical Shop		7/21/2016 10:34
Engineering Shop		7/21/2016 10:35
Plumbing Shop		7/21/2016 16:05
Carpentry Shop	OA - OCLO	7/22/2016 6:49
Engineering Shop		7/22/2016 15:23
Engineering Shop		7/22/2016 15:28
Engineering Shop		7/22/2016 15:28

Custodial Shop		7/22/2016 15:33
Paint Shop		7/22/2016 16:20
Carpentry Shop	NSC - F1616561 FY17 Miscellaneous	7/25/2016 8:25
Engineering Shop		7/25/2016 11:30
		7/25/2016 13:08

Engineering Shop		7/25/2016 13:18
Move Shop	WHO - F1581324 FY17 Misc Services	7/25/2016 13:27
Custodial Shop		7/25/2016 13:29
Elevator Shop		7/25/2016 13:33
Carpentry Shop		7/25/2016 14:56

Carpentry Shop	WHO - F1581324 FY17 Misc Services	7/26/2016 11:19
Carpentry Shop	USSS - F1619843 FY17 Guard Booth	7/26/2016 12:08
Engineering Shop		7/26/2016 15:55
Engineering Shop		7/26/2016 15:56
Move Shop		7/26/2016 17:24
Engineering Shop		7/27/2016 10:02
Plumbing Shop		7/27/2016 13:05
Plumbing Shop		7/27/2016 13:29
Electrical Shop		7/27/2016 13:29
Engineering Shop		7/28/2016 10:20

Engineering Shop		7/28/2016 12:26
Carpentry Shop	NSC - F1616561 FY17 Miscellaneous Services for White House Situation	7/28/2016 12:37
Paint Shop, Plumbing Shop, Engineering Shop		7/28/2016 14:13
Engineering Shop		7/29/2016 11:09
Plumbing Shop		7/29/2016 11:22
Electrical Shop		7/29/2016 11:41
Fire Alarm Shop		8/1/2016 9:42
Fire Alarm Shop		8/1/2016 9:44

Fire Alarm Shop		8/1/2016 9:45
Engineering Shop		8/1/2016 9:50
Electrical Shop		8/1/2016 10:02
Pest Shop		8/1/2016 14:29
Move Shop		8/1/2016 15:21
Pest Shop		8/2/2016 10:37
Electrical Shop		8/2/2016 10:42
Custodial Shop		8/2/2016 10:48

Engineering Shop		8/2/2016 11:02
Paint Shop		8/2/2016 11:28
Carpentry Shop		8/2/2016 11:37
Paint Shop		8/2/2016 11:39
Paint Shop		8/2/2016 11:41
Paint Shop		8/2/2016 11:43
Move Shop	WHO - F1581324 FY17 Misc Services	8/2/2016 12:41
Paint Shop		8/4/2016 9:30

Custodial Shop		8/4/2016 9:33
Electrical Shop		8/4/2016 9:37
Electrical Shop		8/4/2016 9:42
Paint Shop		8/4/2016 9:46
Pest Shop		8/4/2016 13:58
Carpentry Shop		8/4/2016 15:02
Pest Shop		8/5/2016 9:51
Custodial Shop		8/5/2016 9:59

Plumbing Shop		8/5/2016 10:04
Carpentry Shop		8/5/2016 10:11
Carpentry Shop	OA - OCLO	8/8/2016 8:26
Plumbing Shop		8/8/2016 16:02
Lock Shop	USSS - F1619843 FY17 Guard Booth	8/8/2016 16:05
Engineering Shop		8/8/2016 21:03
Engineering Shop		8/9/2016 12:02
Lock Shop	USSS - F1619843 FY17	8/9/2016 12:10

Pest Shop		8/9/2016 12:22
Plumbing Shop		8/9/2016 12:52
Carpentry Shop	WHO - F1581324 FY17 Misc Services	8/9/2016 13:46
Elevator Shop		8/10/2016 10:25
Engineering Shop		8/10/2016 10:26
Engineering Shop		8/10/2016 10:29
Engineering Shop		8/10/2016 10:30
Engineering Shop		8/11/2016 10:32
Plumbing Shop		8/11/2016 15:43

Carpentry Shop	USSS - F1616451 FY17	8/12/2016 10:43
Carpentry Shop	USSS - F1616451 FY17 Misc Services	8/12/2016 10:45
Carpentry Shop	USSS - F1616451 FY17	8/12/2016 10:46
Carpentry Shop	USSS - F1616451 FY17	8/12/2016 10:48
Move Shop		8/12/2016 14:05
Engineering Shop		8/15/2016 8:13
Pest Shop		8/15/2016 13:28
Pest Shop		8/15/2016 15:48
Plumbing Shop		8/16/2016 10:38
Paint Shop, Plumbing Shop,		8/16/2016 10:41
Carpentry Shop	WHO - F1581324 FY17 Misc Services	8/16/2016 15:45

Electrical Shop	NSC - F1589148 FY17 Misc Services	8/16/2016 16:35
Pest Shop		8/16/2016 17:10
Move Shop	WHO - F1581324 FY17 Misc Services	8/16/2016 17:49
Paint Shop		8/17/2016 13:28
Paint Shop		8/17/2016 13:31
Elevator Shop		8/17/2016 15:03
Move Shop		8/18/2016 12:08
Fire Alarm Shop		8/18/2016 12:22

Paint Shop		8/18/2016 14:36
Elevator Shop		8/19/2016 10:56
Engineering Shop		8/19/2016 10:57
Electrical Shop		8/19/2016 11:39
Paint Shop		8/19/2016 16:03
Move Shop	WHO - F1581324 FY17 Misc Services	8/22/2016 10:28
Engineering Shop		8/22/2016 13:42
Pest Shop		8/22/2016 13:52
Carpentry Shop		8/22/2016 13:53

Plumbing Shop		8/22/2016 15:06
Pest Shop		8/22/2016 15:07
Pest Shop		8/22/2016 17:00
Engineering Shop		8/23/2016 11:00
Engineering Shop		8/23/2016 11:00
Carpentry Shop	USSS - F1619843 FY17 Guard Booth Misc Services	8/23/2016 13:06
Engineering Shop		8/23/2016 15:51
Move Shop	WHO - F1581324 FY17 Misc Services	8/23/2016 20:11

Move Shop, Remote Delivery Site (RDS)	WHO - F1581324 FY17 Misc Services	8/24/2016 8:08
Engineering Shop		8/24/2016 10:27
Carpentry Shop		8/24/2016 10:58
Custodial Shop		8/24/2016 11:06
Custodial Shop		8/24/2016 11:07
Elevator Shop		8/24/2016 11:10
Carpentry Shop		8/24/2016 11:31
Electrical Shop		8/24/2016 11:44
Plumbing Shop		8/24/2016 12:39
Engineering Shop		8/24/2016 14:25

Carpentry Shop, Building Manager	WHO - F1581324 FY17 Misc Services	8/24/2016 18:25
Paint Shop		8/25/2016 10:45
Engineering Shop		8/25/2016 11:02
Move Shop	WHO - F1581324 FY17 Misc Services	8/25/2016 11:33
Carpentry Shop	WHO - F1581324 FY17 Misc Services	8/25/2016 14:46

Move Shop		8/25/2016 15:36
Move Shop		8/25/2016 15:39
Carpentry Shop	WHO - F1581324 FY17 Misc Services	8/26/2016 8:17
Engineering Shop		8/26/2016 10:33
Paint Shop	WHO - F1581324 FY17 Misc Services	8/26/2016 12:34
Electrical Shop		8/26/2016 13:26
Paint Shop		8/26/2016 13:49

Paint Shop		8/26/2016 14:26
Plumbing Shop		8/26/2016 15:09
Carpentry Shop	OA - OCLO	8/29/2016 8:01
Electrical Shop		8/29/2016 8:41
Engineering Shop		8/29/2016 15:03
Electrical Shop		8/29/2016 15:14
Electrical Shop		8/30/2016 12:21
Engineering Shop		8/30/2016 12:30
Electrical Shop		8/30/2016 12:39

Electrical Shop		8/30/2016 13:22
Pest Shop		8/30/2016 13:47
Engineering Shop		8/30/2016 14:58
Electrical Shop		8/30/2016 15:00
Engineering Shop		8/31/2016 17:12
Plumbing Shop		9/1/2016 11:16
Engineering Shop		9/1/2016 11:17
Carpentry Shop		9/1/2016 11:18
Electrical Shop		9/1/2016 11:20
Pest Shop		9/1/2016 11:23
Pest Shop		9/1/2016 11:24
Plumbing Shop		9/1/2016 14:37
Electrical Shop		9/2/2016 14:24

Electrical Shop		9/2/2016 14:24
Engineering Shop		9/6/2016 11:53
Paint Shop		9/6/2016 15:45
Plumbing Shop		9/7/2016 9:54
Engineering Shop		9/7/2016 9:59
Electrical Shop		9/7/2016 11:49
Engineering Shop		9/7/2016 12:07
Engineering Shop		9/7/2016 13:34
Move Shop		9/7/2016 14:50
Paint Shop		9/8/2016 15:11
Carpentry Shop		9/8/2016 15:11

Engineering Shop		9/9/2016 9:10
Move Shop		9/9/2016 12:40
Engineering Shop		9/9/2016 14:36
Fire Alarm Shop, Plumbing Shop		9/9/2016 14:59
Engineering Shop		9/9/2016 16:10
Custodial Shop		9/12/2016 7:30
Electrical Shop		9/12/2016 7:32
Paint Shop		9/12/2016 7:34
Electrical Shop		9/12/2016 8:15

Lock Shop		9/12/2016 11:21
Carpentry Shop		9/12/2016 11:23
Engineering Shop		9/12/2016 12:10
Engineering Shop		9/12/2016 15:55
Engineering Shop		9/12/2016 15:56
Paint Shop		9/13/2016 16:12
		9/14/2016 8:24
Move Shop	OA - OCLO	9/14/2016 8:29

Carpentry Shop	WHO - F1581324 FY17 Misc Services	9/14/2016 9:19
Engineering Shop		9/14/2016 11:44
Engineering Shop		9/14/2016 12:41
Move Shop	WHO - F1581324 FY17 Misc Services	9/14/2016 14:02
Carpentry Shop	WHO - F1581324 FY17	9/14/2016 19:51

Paint Shop	WHO - F1581324 FY17 Misc Services	9/15/2016 12:20
Electrical Shop		9/16/2016 9:34
Engineering Shop		9/16/2016 12:28
Engineering Shop		9/16/2016 12:41
Engineering Shop		9/16/2016 12:41
Electrical Shop		9/19/2016 18:43
Move Shop	WHO - F1581324 FY17	9/20/2016 10:03
Engineering Shop		9/20/2016 11:11

Paint Shop		9/20/2016 12:17
Carpentry Shop		9/20/2016 12:18
Paint Shop		9/20/2016 12:19
Custodial Shop		9/20/2016 13:18
Paint Shop		9/20/2016 13:21
Paint Shop		9/21/2016 12:25
Paint Shop		9/21/2016 12:25
Pest Shop		9/21/2016 12:26
Carpentry Shop		9/21/2016 12:31
Paint Shop		9/21/2016 12:50
Engineering Shop		9/21/2016 12:51
Electrical Shop		9/22/2016 9:04
Engineering Shop		9/22/2016 14:03

Electrical Shop		9/23/2016 8:48
Electrical Shop		9/23/2016 10:07
Carpentry Shop		9/23/2016 10:22
Electrical Shop	USSS - F1616451 FY17	9/23/2016 12:25
Engineering Shop		9/23/2016 14:44
Move Shop		9/26/2016 11:04
Custodial Shop		9/26/2016 11:09
Custodial Shop		9/26/2016 11:11
Electrical Shop		9/26/2016 11:24
Electrical Shop		9/26/2016 11:37
Elevator Shop		9/26/2016 11:57

Engineering Shop		9/26/2016 12:02
Engineering Shop		9/26/2016 13:02
Engineering Shop		9/26/2016 13:08
Engineering Shop		9/26/2016 14:13
Engineering Shop		9/26/2016 14:14
Paint Shop		9/26/2016 15:39
Paint Shop		9/26/2016 15:40
Paint Shop		9/26/2016 15:40
Paint Shop		9/26/2016 15:41
Electrical Shop		9/26/2016 15:42
Move Shop	WHMO - F1593671 FY17	9/27/2016 7:11

Move Shop	WHO - F1581324 FY17 Misc Services	9/27/2016 8:43
Elevator Shop		9/27/2016 12:58
Move Shop		9/27/2016 16:12

Electrical Shop, Custodial Shop		9/28/2016 13:14
Engineering Shop		9/29/2016 15:52
Paint Shop		9/29/2016 16:07
Paint Shop		9/29/2016 16:08
Pest Shop		9/29/2016 17:16
Electrical Shop		9/30/2016 8:10
Electrical Shop		9/30/2016 10:09

Engineering Shop		9/30/2016 10:59
Engineering Shop		9/30/2016 11:02
Engineering Shop		9/30/2016 13:16
Carpentry Shop		9/30/2016 15:58
Pest Shop		10/3/2016 16:00
Pest Shop		10/3/2016 16:01
Engineering Shop		10/3/2016 17:25
Plumbing Shop		10/4/2016 11:22
Engineering Shop		10/4/2016 15:52
Plumbing Shop		10/4/2016 15:57

Custodial Shop		10/5/2016 9:28
Custodial Shop		10/5/2016 9:28
Engineering Shop		10/6/2016 12:11
Engineering Shop		10/6/2016 12:11
Engineering Shop		10/6/2016 12:13
Plumbing Shop		10/6/2016 12:20
Carpentry Shop	NSC - F1589148 FY17 Misc Services	10/6/2016 14:40
Carpentry Shop	NSC - F1589148 FY17 Misc Services	10/6/2016 17:28
Paint Shop		10/7/2016 11:32

Carpentry Shop		10/7/2016 14:18
Carpentry Shop, Lock Shop	USSS - F1619843 FY17	10/7/2016 14:57
Paint Shop		10/7/2016 16:01
Paint Shop		10/7/2016 16:02
Paint Shop		10/7/2016 16:02
Move Shop		10/11/2016 11:09
Carpentry Shop	NSC - F1589148 FY17 Misc Services	10/11/2016 19:14
Paint Shop		10/12/2016 7:52
Paint Shop		10/12/2016 7:54
Custodial Shop		10/12/2016 8:00
Custodial Shop		10/12/2016 8:03

Custodial Shop		10/12/2016 8:06
Custodial Shop		10/12/2016 8:08
Custodial Shop		10/12/2016 8:11
Custodial Shop		10/12/2016 8:12
Custodial Shop		10/12/2016 8:13
Custodial Shop		10/12/2016 8:14
Paint Shop		10/12/2016 8:26
Custodial Shop		10/12/2016 8:34
Electrical Shop		10/12/2016 8:34
Custodial Shop		10/12/2016 8:36

Custodial Shop		10/12/2016 8:37
Custodial Shop		10/12/2016 8:38
Carpentry Shop		10/12/2016 8:39
Custodial Shop		10/12/2016 8:41
Carpentry Shop		10/12/2016 8:42
Custodial Shop		10/12/2016 8:42
Paint Shop		10/12/2016 8:43
Carpentry Shop		10/12/2016 8:44
Paint Shop		10/12/2016 8:47
Electrical Shop		10/12/2016 8:49
Paint Shop		10/12/2016 8:50

Paint Shop		10/12/2016 8:51
Move Shop		10/12/2016 9:03
Electrical Shop, Elevator Shop		10/12/2016 9:05
Custodial Shop		10/12/2016 9:09
Custodial Shop		10/12/2016 9:10
Custodial Shop		10/12/2016 9:13
Custodial Shop		10/12/2016 9:14
Custodial Shop		10/12/2016 9:14
Custodial Shop		10/12/2016 9:15
Paint Shop		10/12/2016 9:18

Paint Shop		10/12/2016 11:43
Move Shop		10/12/2016 12:51
Paint Shop		10/12/2016 12:53
Pest Shop		10/12/2016 12:53
Carpentry Shop		10/12/2016 12:58
Custodial Shop		10/12/2016 13:12
Custodial Shop		10/12/2016 13:14
Paint Shop		10/12/2016 13:15
Custodial Shop		10/12/2016 13:15
Carpentry Shop		10/12/2016 13:16
Paint Shop		10/12/2016 13:17

Custodial Shop		10/12/2016 13:18
Custodial Shop		10/12/2016 13:19
Custodial Shop		10/12/2016 13:20
Custodial Shop		10/12/2016 13:21
Custodial Shop		10/12/2016 13:22
Electrical Shop		10/12/2016 13:23
Custodial Shop		10/12/2016 13:24
Custodial Shop		10/12/2016 13:28
Custodial Shop		10/12/2016 13:47
Custodial Shop		10/12/2016 13:48
Custodial Shop		10/12/2016 13:49
Custodial Shop		10/12/2016 13:52
Lock Shop		10/13/2016 9:43

Electrical Shop		10/13/2016 9:54
Electrical Shop		10/13/2016 10:06
Engineering Shop		10/13/2016 11:18
Elevator Shop		10/13/2016 11:35

Carpentry Shop	WHO - F1581324 FY17 Misc Services	10/13/2016 16:05
Elevator Shop		10/14/2016 9:29
Plumbing Shop		10/14/2016 12:18
Engineering Shop		10/14/2016 12:21
Plumbing Shop		10/14/2016 14:01
Building Manager		10/14/2016 15:59

Paint Shop		10/17/2016 12:09
Electrical Shop		10/17/2016 12:11
Engineering Shop		10/17/2016 12:12
Pest Shop		10/17/2016 12:13
Paint Shop		10/17/2016 12:14
Electrical Shop		10/17/2016 13:24
Engineering Shop		10/17/2016 13:56

Move Shop		10/17/2016 13:59
Electrical Shop		10/18/2016 15:14
Pest Shop		10/19/2016 13:50
Plumbing Shop		10/19/2016 14:11

Building Manager, Project Estimator		10/20/2016 7:13
Electrical Shop		10/20/2016 10:35
Engineering Shop		10/20/2016 10:46
Engineering Shop		10/21/2016 9:39
Paint Shop		10/21/2016 10:20

Custodial Shop		10/21/2016 10:24
Custodial Shop		10/21/2016 10:26
Carpentry Shop		10/21/2016 10:30
Move Shop		10/21/2016 10:43
Electrical Shop		10/21/2016 10:46

Project Estimator		10/24/2016 9:04
-------------------	--	-----------------

Move Shop	WHO - F1581324 FY17 Misc Services	10/24/2016 12:25
Plumbing Shop		10/24/2016 12:44
Electrical Shop		10/26/2016 11:02
Engineering Shop		10/26/2016 12:59
Engineering Shop		10/26/2016 17:51
Engineering Shop		10/27/2016 13:07
Electrical Shop		10/27/2016 17:28
Carpentry Shop	OA - F1587687 FY17 Misc Services, OA/OCLO	10/28/2016 8:43

Move Shop	WHO - F1581324 FY17 Misc Services	10/28/2016 9:57
Paint Shop		10/28/2016 10:13
Paint Shop		10/28/2016 10:22
Electrical Shop		10/28/2016 10:27
Engineering Shop		10/28/2016 13:27
Carpentry Shop		10/28/2016 17:35
Move Shop	WHO	10/31/2016 14:28
Paint Shop		10/31/2016 15:04

Carpentry Shop	NSC - F1589148 FY17 Misc Services	11/1/2016 11:20
Engineering Shop		11/1/2016 12:49
Engineering Shop		11/1/2016 13:19
Paint Shop		11/1/2016 16:13
Lock Shop		11/2/2016 10:15
Paint Shop		11/2/2016 15:16
Project Estimator	NSC - F1616561 FY17 Miscellaneous Services for White House Situation Support Staff (WHSSS)	11/3/2016 18:41
Electrical Shop		11/4/2016 9:27
Lock Shop		11/4/2016 9:28
Paint Shop		11/4/2016 9:30

Plumbing Shop		11/4/2016 10:29
Lock Shop		11/5/2016 6:40
Electrical Shop		11/7/2016 10:06
Electrical Shop		11/7/2016 10:07
Move Shop		11/7/2016 10:09
Engineering Shop		11/7/2016 10:19
Carpentry Shop	NSC - F1589148 FY17 Misc Services	11/8/2016 14:08
Move Shop		11/8/2016 15:14
Paint Shop		11/8/2016 15:31
Carpentry Shop, Building Manager	WHO - F1581324 FY17 Misc Services	11/8/2016 17:41

Move Shop	WHO - F1581324 FY17 Misc Services	11/9/2016 10:23
Engineering Shop		11/9/2016 14:43
Engineering Shop		11/9/2016 14:46
Engineering Shop		11/10/2016 8:23
Engineering Shop		11/10/2016 8:23
Move Shop	WHO - F1581324 FY17 Misc Services	11/10/2016 9:34
Engineering Shop		11/10/2016 14:30
Engineering Shop		11/14/2016 13:20

Paint Shop		11/16/2016 13:33
Plumbing Shop		11/16/2016 13:33
Engineering Shop		11/16/2016 13:56
Move Shop		11/16/2016 15:15
Paint Shop		11/17/2016 10:11
Electrical Shop		11/17/2016 10:16
Plumbing Shop		11/17/2016 10:20
Move Shop		11/17/2016 10:26
Engineering Shop		11/18/2016 7:53
Engineering Shop		11/18/2016 7:54
Carpentry Shop, Paint Shop		11/18/2016 11:08

Electrical Shop		11/21/2016 9:31
Electrical Shop		11/21/2016 9:37
Electrical Shop		11/21/2016 9:39
Custodial Shop		11/21/2016 9:46
Engineering Shop		11/21/2016 11:00
Move Shop		11/21/2016 11:59
Paint Shop		11/21/2016 12:38
Paint Shop		11/21/2016 12:39
Paint Shop		11/21/2016 12:39
Engineering Shop		11/21/2016 12:41
Carpentry Shop		11/22/2016 10:31
Electrical Shop		11/22/2016 10:34
Elevator Shop		11/23/2016 10:27

Move Shop		11/23/2016 10:33
Move Shop		11/23/2016 12:11
Paint Shop		11/23/2016 15:48
Pest Shop		11/28/2016 8:05
Engineering Shop		11/28/2016 13:53
Plumbing Shop		11/28/2016 13:54
Move Shop		11/28/2016 15:13
Engineering Shop		11/28/2016 16:46
Move Shop		11/29/2016 8:48
Engineering Shop		11/29/2016 11:15
Paint Shop		11/29/2016 11:16

Carpentry Shop		11/29/2016 13:02
Carpentry Shop		11/30/2016 8:31
Carpentry Shop		11/30/2016 8:39
Plumbing Shop		11/30/2016 9:13

Engineering Shop		11/30/2016 11:20
Carpentry Shop		11/30/2016 12:45
Move Shop	WHO - F1581324 FY17 Misc Services	11/30/2016 13:35
Move Shop	WHO - F1581324 FY17 Misc Services	11/30/2016 14:52

Move Shop	WHO - F1581324 FY17 Misc Services	11/30/2016 23:26
Electrical Shop		12/1/2016 10:38
Plumbing Shop		12/1/2016 10:44
Paint Shop		12/1/2016 10:44
Engineering Shop		12/1/2016 15:04
Engineering Shop		12/2/2016 17:01
Electrical Shop	NSC - F1616561 FY17 Miscellaneous Services for	12/3/2016 8:12
Electrical Shop		12/5/2016 9:10
Move Shop		12/5/2016 12:40
Engineering Shop		12/5/2016 12:41

Paint Shop		12/5/2016 12:53
Plumbing Shop		12/5/2016 12:53
Paint Shop		12/5/2016 12:56
Plumbing Shop		12/5/2016 12:57
Electrical Shop		12/5/2016 14:13
Engineering Shop		12/5/2016 14:17
Electrical Shop		12/5/2016 15:36
Paint Shop		12/5/2016 15:43
Carpentry Shop	OA - F1587687 FY17 Misc Services, OA/OCLO	12/6/2016 9:55
Lock Shop		12/6/2016 10:33
Carpentry Shop		12/6/2016 10:33

Engineering Shop		12/6/2016 13:47
Electrical Shop		12/6/2016 16:21
Elevator Shop		12/7/2016 10:50
Plumbing Shop		12/7/2016 10:55
Custodial Shop		12/7/2016 11:29
Move Shop		12/7/2016 11:40
Custodial Shop		12/7/2016 13:17
Custodial Shop		12/7/2016 13:19
Carpentry Shop		12/7/2016 13:22
Plumbing Shop		12/8/2016 10:37

Move Shop	WHO - F1581324 FY17 Misc Services	12/8/2016 13:34
Plumbing Shop		12/8/2016 16:21
Custodial Shop		12/9/2016 13:31
Custodial Shop		12/9/2016 13:38
Elevator Shop		12/12/2016 13:57
Move Shop		12/12/2016 14:04

Engineering Shop		12/12/2016 14:11
Engineering Shop		12/12/2016 14:33
Electrical Shop, Custodial Shop		12/13/2016 9:12
Electrical Shop, Custodial Shop		12/13/2016 9:13
Paint Shop		12/13/2016 10:01
Elevator Shop		12/13/2016 10:04
Plumbing Shop		12/13/2016 14:48
Carpentry Shop, Move Shop	WHO - F1581324 FY17 Misc Services	12/13/2016 18:27

Remote Delivery Site (RDS)	WHO - F1581324 FY17 Misc Services	12/14/2016 10:12
Carpentry Shop	OA - F1587687 FY17 Misc Services, OA/OCLO	12/14/2016 13:23
Electrical Shop		12/14/2016 14:56
Engineering Shop		12/14/2016 17:23
Engineering Shop		12/14/2016 17:23
Move Shop	WHO - F1581324 FY17 Misc Services	12/15/2016 8:47
Carpentry Shop		12/15/2016 9:08

Carpentry Shop		12/15/2016 9:44
Lock Shop	USSS - F1619843 FY17 Guard Booth	12/15/2016 11:05
Engineering Shop		12/16/2016 9:29
Carpentry Shop		12/16/2016 9:33
Move Shop		12/16/2016 10:34
Plumbing Shop		12/18/2016 8:09
Carpentry Shop, Elevator Shop		12/19/2016 11:23
Move Shop	WHO - F1581324 FY17 Misc Services	12/19/2016 14:37
Engineering Shop		12/19/2016 15:02

Engineering Shop		12/19/2016 15:03
Custodial Shop		12/20/2016 7:41
Paint Shop		12/20/2016 7:45
Building Manager		12/20/2016 8:11
Custodial Shop		12/20/2016 9:24
Custodial Shop		12/20/2016 9:25
Engineering Shop		12/20/2016 9:50
Paint Shop		12/20/2016 9:59

Carpentry Shop		12/20/2016 13:02
Paint Shop		12/20/2016 13:18
Paint Shop		12/20/2016 13:20
Paint Shop		12/20/2016 13:23
Carpentry Shop		12/20/2016 13:50
Carpentry Shop	OA - F1587687 FY17 Misc Services, OA/OCLO	12/21/2016 10:22
Engineering Shop		12/21/2016 13:20
Electrical Shop		12/22/2016 9:07
Move Shop		12/23/2016 11:40

Electrical Shop		12/23/2016 11:43
Electrical Shop		12/27/2016 16:50
Engineering Shop		12/29/2016 7:19
Move Shop	WHO - F1581324 FY17 Misc Services	12/29/2016 14:29
Elevator Shop		12/29/2016 14:32
Engineering Shop		12/31/2016 7:40
Engineering Shop		12/31/2016 7:41
Electrical Shop		1/3/2017 6:31
Electrical Shop		1/3/2017 8:08

Electrical Shop		1/3/2017 8:12
Electrical Shop		1/3/2017 8:15
Electrical Shop		1/3/2017 8:18
Electrical Shop		1/3/2017 8:19
		1/3/2017 13:31
Custodial Shop		1/3/2017 14:13
Custodial Shop		1/3/2017 14:14
Electrical Shop		1/3/2017 14:16

Move Shop		1/3/2017 14:21
Move Shop	WHO - F1581324 FY17 Misc Services	1/5/2017 11:45
Electrical Shop		1/5/2017 12:34
Custodial Shop		1/5/2017 12:41
Engineering Shop		1/6/2017 11:29
Lock Shop		1/6/2017 11:32
Engineering Shop		1/6/2017 15:12
Engineering Shop		1/6/2017 15:12
Engineering Shop		1/6/2017 15:12
Engineering Shop		1/6/2017 15:13

Custodial Shop		1/6/2017 15:23
Paint Shop		1/6/2017 15:25
Plumbing Shop		1/6/2017 15:25
Electrical Shop		1/6/2017 17:32
Engineering Shop		1/6/2017 17:33
Carpentry Shop		1/6/2017 17:33

Move Shop	WHO - F1581324 FY17 Misc Services	1/8/2017 16:02
Engineering Shop	USSS - F1619843 FY17 Guard Booth Misc Services	1/9/2017 12:25
Elevator Shop	USSS - F1619843 FY17 Guard Booth	1/9/2017 12:27
Lock Shop	USSS - F1619843 FY17 Guard Booth	1/9/2017 12:36
Engineering Shop		1/9/2017 13:10
Move Shop		1/10/2017 10:49
Electrical Shop		1/11/2017 15:56

Paint Shop		1/11/2017 15:56
Pest Shop		1/11/2017 15:58
Plumbing Shop		1/12/2017 11:59
Electrical Shop		1/12/2017 17:45
Move Shop	OA - F1587687 FY17 Misc Services, OA/OCLO	1/13/2017 10:35
Move Shop	OA - F1612730 FY17 Misc Transition	1/13/2017 10:44
Engineering Shop		1/13/2017 15:51
Building Manager	NSC - F1616561 FY17 Miscellaneous Services for	1/14/2017 13:31
Paint Shop		1/17/2017 16:47

Building Manager, Project Estimator	USSS - F1619843 FY17 Guard Booth Misc Services	1/17/2017 16:50
Move Shop	WHO - F1581324 FY17	1/18/2017 10:57
Move Shop	OA - F1612730 FY17 Misc Transition	1/18/2017 12:20
Move Shop	OA - F1612730 FY17 Misc Transition	1/18/2017 12:44
Engineering Shop		1/18/2017 14:20
Engineering Shop		1/18/2017 15:12
Electrical Shop		1/20/2017 15:44
Carpentry Shop	OA - F1587687 FY17 Misc Services, OA/OCLO	1/23/2017 8:48

Engineering Shop		1/23/2017 12:03
Plumbing Shop		1/23/2017 12:05
Paint Shop		1/23/2017 12:12
Engineering Shop		1/25/2017 10:33
Carpentry Shop	NSC - F1589148 FY17 Misc Services	1/25/2017 11:36
Engineering Shop		1/25/2017 13:40
Move Shop, Project Estimator	OA - F1612730 FY17 Misc	1/25/2017 14:46
Move Shop		1/25/2017 19:07
Move Shop		1/26/2017 9:31

Custodial Shop		1/26/2017 9:49
Engineering Shop		1/26/2017 9:59
Engineering Shop		1/26/2017 11:38
Electrical Shop		1/27/2017 7:51
Engineering Shop	USSS - F1619843 FY17 Guard Booth Misc Services	1/27/2017 10:35
Move Shop	OA - F1612730 FY17 Misc Transition	1/27/2017 15:30

Engineering Shop		1/27/2017 16:02
Engineering Shop		1/28/2017 11:11
Move Shop	WHO - F1581324 FY17	1/28/2017 12:40
Plumbing Shop		1/30/2017 9:24
Electrical Shop		1/30/2017 9:27
Custodial Shop		1/30/2017 9:31
Custodial Shop		1/30/2017 9:44
Engineering Shop		1/30/2017 13:42
Carpentry Shop	OA - F1612730 FY17 Misc Transition	1/30/2017 14:22
Move Shop, Project Estimator	OA - F1612730 FY17 Misc Transition	1/30/2017 14:24
Engineering Shop		1/30/2017 15:31

Plumbing Shop		1/30/2017 16:54
Electrical Shop		1/30/2017 16:55
Carpentry Shop	OA - F1612730 FY17 Misc Transition	1/31/2017 11:13
Elevator Shop, Engineering Shop	OA - F1612730 FY17 Misc Transition	1/31/2017 11:23
Carpentry Shop	OA - F1612730 FY17 Misc Transition	1/31/2017 11:42
Carpentry Shop	OA - F1612730 FY17 Misc Transition	1/31/2017 13:18

Move Shop	OA - F1612730 FY17 Misc Transition	1/31/2017 13:25
Move Shop	OA - F1612730 FY17 Misc	1/31/2017 13:39
Carpentry Shop, Move Shop	OA - F1612730 FY17 Misc Transition	1/31/2017 14:18
Carpentry Shop	OA - F1612730 FY17 Misc Transition	1/31/2017 14:32
Electrical Shop	OA - F1612730 FY17 Misc Transition	1/31/2017 14:33
Paint Shop	OA - F1612730 FY17 Misc Transition	1/31/2017 14:34
Carpentry Shop	OA - F1612730 FY17 Misc Transition	1/31/2017 14:39
Lock Shop	NSC - F1589148 FY17 Misc Services	1/31/2017 14:55
Move Shop		1/31/2017 15:46
Engineering Shop		2/1/2017 12:01

Electrical Shop		2/1/2017 12:03
Engineering Shop		2/1/2017 13:26
Engineering Shop		2/1/2017 17:26
Engineering Shop		2/1/2017 17:27
Pest Shop		2/1/2017 17:36
Carpentry Shop	NSC - F1589148 FY17 Misc Services	2/1/2017 17:56
Move Shop	OA - F1612730 FY17 Misc Transition	2/2/2017 8:54
Carpentry Shop	OA - F1612730 FY17 Misc Transition	2/2/2017 8:55
Custodial Shop		2/2/2017 11:48
Move Shop		2/2/2017 12:36
Electrical Shop		2/2/2017 12:37
Engineering Shop		2/2/2017 15:02
Engineering Shop		2/2/2017 15:02

Engineering Shop		2/2/2017 16:40
Engineering Shop		2/2/2017 16:41
Engineering Shop		2/2/2017 16:42
Engineering Shop		2/2/2017 16:42
Engineering Shop		2/2/2017 16:42
Carpentry Shop, Paint Shop		2/3/2017 11:22
Engineering Shop		2/3/2017 16:31
Engineering Shop		2/3/2017 16:31
Building Manager	OA - F1612730 FY17 Misc	2/5/2017 12:25
Electrical Shop	OA - F1612730 FY17 Misc Transition	2/6/2017 9:13
Engineering Shop		2/6/2017 11:03
Engineering Shop		2/6/2017 11:19

Move Shop		2/6/2017 11:27
Engineering Shop		2/6/2017 13:58
Move Shop	OA - F1612730 FY17 Misc Transition	2/6/2017 13:59
Engineering Shop		2/6/2017 13:59
Carpentry Shop	NSC - F1589148 FY17 Misc Services	2/6/2017 15:45
Carpentry Shop		2/7/2017 9:01
Electrical Shop	OA - F1612730 FY17 Misc	2/7/2017 9:39
Paint Shop	OA - F1612730 FY17 Misc Transition	2/7/2017 9:40
Carpentry Shop	OA - F1612730 FY17 Misc Transition	2/7/2017 9:43

Move Shop	OA - F1612730 FY17 Misc Transition	2/7/2017 10:41
Electrical Shop		2/7/2017 10:54
Paint Shop		2/7/2017 15:38
Move Shop		2/7/2017 15:39
Custodial Shop		2/7/2017 15:40
Building Manager		2/7/2017 15:41
Engineering Shop		2/7/2017 17:41
Paint Shop		2/8/2017 6:50

Electrical Shop		2/8/2017 8:13
Carpentry Shop	OA - F1612730 FY17 Misc Transition	2/8/2017 9:40
Paint Shop		2/8/2017 10:23
Carpentry Shop		2/8/2017 13:26
Carpentry Shop, Move Shop	WHO - F1581324 FY17 Misc Services	2/8/2017 14:37
Move Shop		2/8/2017 15:42
Pest Shop, Engineering Shop		2/8/2017 15:44
Engineering Shop		2/8/2017 16:37

Carpentry Shop	OA - F1612730 FY17 Misc Transition	2/9/2017 7:04
Electrical Shop	WHMO	2/9/2017 11:18
Carpentry Shop	WHO - F1581324 FY17 Misc Services	2/9/2017 14:42
Carpentry Shop	NSC - F1589148 FY17 Misc Services	2/9/2017 17:06

Plumbing Shop		2/9/2017 17:45
Electrical Shop		2/10/2017 10:58
Carpentry Shop	WHMO	2/10/2017 13:10

Plumbing Shop	WHMO	2/10/2017 13:11
---------------	------	-----------------

Engineering Shop	WHMO	2/10/2017 13:12
------------------	------	-----------------

Fire Alarm Shop	WHMO	2/10/2017 13:15
-----------------	------	-----------------

Paint Shop	WHMO	2/10/2017 13:17
Engineering Shop		2/10/2017 13:29
Electrical Shop		2/13/2017 7:41
Move Shop	WHO - F1581324 FY17	2/13/2017 8:51
Engineering Shop		2/13/2017 14:03
Move Shop	OVP - F1584389 FY17	2/13/2017 15:25

Move Shop		2/13/2017 17:43
Carpentry Shop	OA - F1612730 FY17 Misc Transition	2/14/2017 6:30
Move Shop	OA - F1612730 FY17 Misc Transition	2/14/2017 11:02
Pest Shop		2/14/2017 11:05
Move Shop	WHO - F1581324 FY17 Misc Services	2/14/2017 11:47
Carpentry Shop	WHO - F1581324 FY17	2/14/2017 16:23

Move Shop		2/15/2017 8:03
Move Shop	OA - F1587687 FY17 Misc Services,	2/15/2017 8:08
Pest Shop		2/15/2017 8:17
Electrical Shop		2/15/2017 8:19
Electrical Shop	OA - F1612730 FY17 Misc Transition	2/15/2017 9:01
Paint Shop	OA - F1612730 FY17 Misc Transition	2/15/2017 9:04
Paint Shop	NSC - F1616561 FY17 Miscellaneous Services for White House Situation Support Staff (WHSSS)	2/15/2017 9:51

Carpentry Shop		2/15/2017 10:59
Move Shop	OA - F1612730 FY17 Misc Transition	2/15/2017 12:59
Electrical Shop	OA - F1612730 FY17 Misc Transition	2/15/2017 13:08
Move Shop	OA - F1587687 FY17 Misc Services, OA/OCLO	2/16/2017 9:39
Move Shop		2/16/2017 9:53
Move Shop	WHO - F1581324 FY17	2/16/2017 9:58
Electrical Shop		2/16/2017 10:20
Paint Shop		2/16/2017 10:23
Plumbing Shop		2/16/2017 13:19
Paint Shop		2/16/2017 14:36

Plumbing Shop		2/16/2017 17:04
Electrical Shop	WHO - F1581324 FY17 Misc Services	2/17/2017 8:54
Engineering Shop		2/17/2017 11:11
Carpentry Shop	OA - F1612730 FY17 Misc Transition	2/17/2017 11:19
Electrical Shop, Paint Shop		2/17/2017 13:58
Electrical Shop	USSS - F1619843 FY17 Guard Booth Misc Services	2/21/2017 12:12
Move Shop	OA - F1612730 FY17 Misc Transition	2/21/2017 12:35
Move Shop	OA - F1612730 FY17 Misc Transition	2/21/2017 12:38

Carpentry Shop		2/21/2017 13:20
Engineering Shop		2/21/2017 14:23
Carpentry Shop		2/21/2017 14:42
Electrical Shop		2/21/2017 15:00
Electrical Shop		2/21/2017 16:00
Carpentry Shop		2/21/2017 16:01
Carpentry Shop		2/21/2017 17:22
Paint Shop		2/22/2017 6:31
Lock Shop		2/22/2017 11:00
Electrical Shop		2/22/2017 11:11
Carpentry Shop		2/22/2017 14:43
Move Shop	OA - F1612730 FY17 Misc Transition	2/23/2017 6:53

Engineering Shop		2/23/2017 10:51
Carpentry Shop	WHO - F1581324 FY17	2/23/2017 16:31
Electrical Shop		2/23/2017 17:09
Lock Shop	WHO - F1581324 FY17	2/23/2017 17:47
Carpentry Shop	WHO - F1581324 FY17 Misc Services	2/24/2017 8:31
Carpentry Shop	OA - F1612730 FY17 Misc	2/24/2017 12:06
Move Shop	OA - F1612730 FY17 Misc	2/24/2017 12:12
Carpentry Shop		2/24/2017 12:15
Carpentry Shop	OA - F1612730 FY17 Misc	2/24/2017 12:51

Carpentry Shop	WHO - F1581324 FY17	2/24/2017 13:34
Electrical Shop		2/24/2017 16:06
Electrical Shop		2/27/2017 9:15
Electrical Shop		2/27/2017 9:41
Engineering Shop		2/27/2017 9:45
Plumbing Shop		2/27/2017 9:52
Move Shop		2/27/2017 9:55
Paint Shop		2/27/2017 10:36
Paint Shop		2/27/2017 10:37
Engineering Shop		2/27/2017 10:37
Carpentry Shop	WHO - F1581324 FY17	2/27/2017 11:02
Electrical Shop	OA - F1612730 FY17 Misc Transition	2/28/2017 9:57

Project Estimator		2/28/2017 10:34
Custodial Shop		2/28/2017 10:45
Electrical Shop	WHO - F1581324 FY17 Misc Services	2/28/2017 10:51
Lock Shop		2/28/2017 12:40
Move Shop	WHO - F1581324 FY17 Misc Services	2/28/2017 16:57

Carpentry Shop	OA - F1612730 FY17 Misc Transition	3/1/2017 8:44
Electrical Shop	WHO - F1581324 FY17 Misc Services	3/1/2017 13:07
Engineering Shop		3/1/2017 13:36
Engineering Shop		3/1/2017 14:11
Engineering Shop		3/1/2017 14:14

Electrical Shop		3/2/2017 10:54
Custodial Shop		3/2/2017 12:08
Move Shop		3/2/2017 15:56
Move Shop		3/2/2017 16:01
Engineering Shop		3/2/2017 16:03
Engineering Shop		3/2/2017 16:04
Carpentry Shop	NSC - F1589148 FY17 Misc Services	3/5/2017 21:10
Carpentry Shop	OA - F1612730 FY17 Misc	3/6/2017 10:19
Move Shop	OA - F1612730 FY17 Misc Transition	3/6/2017 10:21
Electrical Shop	OA - F1612730 FY17 Misc	3/6/2017 10:23

Paint Shop	OA - F1612730 FY17 Misc Transition	3/6/2017 10:25
Project Estimator	OA - F1612730 FY17 Misc	3/6/2017 11:31
Engineering Shop	OA - F1612730 FY17 Misc Transition	3/6/2017 11:36
Fire Alarm Shop		3/6/2017 11:36
Carpentry Shop		3/6/2017 11:46
Carpentry Shop		3/6/2017 13:07
Move Shop		3/6/2017 13:26

Carpentry Shop	OA - F1612730 FY17 Misc Transition	3/6/2017 13:41
Custodial Shop		3/6/2017 14:02
Electrical Shop		3/6/2017 15:28
Move Shop		3/6/2017 16:10
Electrical Shop		3/7/2017 9:26
Move Shop		3/7/2017 9:35
Electrical Shop		3/7/2017 12:21

Move Shop	OA - F1592601 FY17 Misc Services, Safes	3/7/2017 14:23
Paint Shop		3/7/2017 16:05
Electrical Shop		3/7/2017 16:05
Electrical Shop, Paint Shop		3/7/2017 16:06

Carpentry Shop, Paint Shop	WHO - F1581324 FY17 Misc Services	3/7/2017 16:16
Carpentry Shop	WHO - F1581324 FY17 Misc Services	3/7/2017 17:33
Carpentry Shop		3/8/2017 9:11
Move Shop		3/8/2017 9:48
Pest Shop		3/8/2017 11:06
Engineering Shop		3/8/2017 11:35
Move Shop	OA - F1612730 FY17 Misc Transition	3/8/2017 13:14

Move Shop, Remote Delivery Site (RDS)		3/8/2017 14:09
Engineering Shop		3/8/2017 14:15
Electrical Shop		3/8/2017 14:16
Move Shop		3/8/2017 14:58
Plumbing Shop		3/8/2017 15:59
Carpentry Shop	OVP - F1584389 FY17 Misc Services	3/8/2017 17:28
Carpentry Shop	WHO - F1581324 FY17 Misc Services	3/9/2017 9:38
Elevator Shop		3/9/2017 12:09

Electrical Shop		3/9/2017 13:23
Carpentry Shop	WHO - F1581324 FY17 Misc Services	3/9/2017 13:51
Engineering Shop		3/9/2017 14:55
Move Shop		3/9/2017 16:20
Elevator Shop, Lock Shop		3/9/2017 17:52

Move Shop	OA - F1612730 FY17 Misc Transition	3/10/2017 10:46
Carpentry Shop		3/10/2017 11:23
Elevator Shop		3/10/2017 11:25
Carpentry Shop	OA - F1612730 FY17 Misc Transition	3/10/2017 11:29
Engineering Shop		3/10/2017 13:10
Electrical Shop		3/10/2017 13:54

Carpentry Shop	OA - F1612730 FY17 Misc Transition	3/13/2017 7:26
Carpentry Shop	WHO - F1581324 FY17 Misc Services	3/13/2017 9:05
Move Shop		3/13/2017 10:12
Carpentry Shop	OVP - F1584389 FY17 Misc Services	3/13/2017 10:14
Electrical Shop	OVP - F1584389 FY17 Misc Services	3/13/2017 10:15
Electrical Shop		3/13/2017 11:28
Plumbing Shop		3/13/2017 11:46
Carpentry Shop		3/13/2017 11:50

Carpentry Shop	WHO - F1581324 FY17 Misc Services	3/13/2017 14:22
Pest Shop		3/13/2017 15:16
Engineering Shop		3/13/2017 15:17
Engineering Shop		3/13/2017 15:17
Carpentry Shop	WHO - F1581324 FY17	3/13/2017 17:50
Move Shop	OA - F1587687 FY17 Misc	3/14/2017 11:41
Pest Shop		3/14/2017 13:42
Electrical Shop		3/14/2017 14:04
Move Shop		3/14/2017 17:48
Carpentry Shop	WHO - F1581324 FY17 Misc Services	3/14/2017 18:15

Move Shop	OA - F1612730 FY17 Misc Transition	3/14/2017 18:17
Project Estimator	OA - F1612730 FY17 Misc Transition	3/15/2017 7:26
Carpentry Shop		3/15/2017 10:37
Carpentry Shop	WHO - F1581324 FY17 Misc Services	3/15/2017 15:13
Engineering Shop		3/15/2017 15:30
Engineering Shop		3/15/2017 17:20
Carpentry Shop	OVP - F1584389 FY17 Misc Services	3/15/2017 18:27

Move Shop	OA - F1612730 FY17 Misc Transition	3/16/2017 6:52
Move Shop	OA - F1612730 FY17 Misc Transition	3/16/2017 10:50
Carpentry Shop	OA - F1612730 FY17 Misc Transition	3/16/2017 10:52
Move Shop	OA - F1612730 FY17 Misc Transition	3/16/2017 11:00
Engineering Shop		3/16/2017 12:56
Pest Shop		3/16/2017 13:06

Move Shop		3/16/2017 13:50
Carpentry Shop	NSC - F1589148 FY17 Misc Services	3/16/2017 14:33
Fire Alarm Shop		3/16/2017 14:49
Engineering Shop		3/16/2017 14:54
Electrical Shop		3/16/2017 15:31
Move Shop		3/16/2017 15:56
Carpentry Shop	WHO - F1581324 FY17 Misc Services	3/17/2017 10:30
Carpentry Shop	OA - F1587687 FY17 Misc Services, OA/OCLO	3/17/2017 11:06
Engineering Shop		3/17/2017 11:59

Engineering Shop		3/17/2017 12:56
Engineering Shop		3/17/2017 13:37
Building Manager	NSC - F1589148 FY17 Misc Services	3/18/2017 16:25
Project Estimator		3/20/2017 10:25
Paint Shop		3/20/2017 12:18
Engineering Shop		3/20/2017 12:25
Carpentry Shop	WHO - F1581324 FY17	3/20/2017 13:18
Plumbing Shop		3/20/2017 15:10

Paint Shop		3/20/2017 16:56
Move Shop		3/21/2017 13:06
Move Shop	OA - F1612730 FY17 Misc Transition	3/21/2017 13:12
Engineering Shop		3/21/2017 13:27
Carpentry Shop	NSC - F1589148 FY17	3/21/2017 15:59

Electrical Shop	WHO - F1581324 FY17 Misc Services	3/21/2017 16:09
Carpentry Shop	OA - F1612730 FY17 Misc Transition	3/22/2017 10:57
Electrical Shop	OA - F1612730 FY17 Misc Transition	3/22/2017 11:00
Engineering Shop		3/22/2017 12:34

Plumbing Shop		3/22/2017 14:47
Paint Shop		3/22/2017 15:45
Electrical Shop		3/22/2017 15:46
Engineering Shop		3/23/2017 10:38
Move Shop		3/23/2017 11:32
Carpentry Shop	WHO - F1581324 FY17	3/23/2017 12:23
Move Shop		3/23/2017 12:33
Paint Shop		3/23/2017 15:05

Engineering Shop		3/23/2017 16:50
Move Shop	OA - F1612730 FY17 Misc	3/24/2017 6:22
Carpentry Shop	OA - F1612730 FY17 Misc	3/24/2017 7:56
Move Shop		3/24/2017 7:59
Paint Shop		3/24/2017 9:36
Carpentry Shop		3/24/2017 10:25
Plumbing Shop		3/24/2017 11:01
Engineering Shop		3/24/2017 11:18
Paint Shop	WHO - F1581324 FY17	3/24/2017 11:24
Engineering Shop		3/24/2017 12:25
Carpentry Shop	NSC - F1589148 FY17 Misc Services	3/24/2017 13:10

Engineering Shop		3/24/2017 14:34
Elevator Shop		3/24/2017 14:34
Paint Shop		3/27/2017 8:26

Plumbing Shop		3/27/2017 9:06
Carpentry Shop		3/27/2017 10:04
Carpentry Shop		3/27/2017 10:05
Plumbing Shop		3/27/2017 10:08
Move Shop		3/27/2017 10:10
Electrical Shop		3/27/2017 11:46
Plumbing Shop		3/27/2017 13:50
Engineering Shop		3/27/2017 14:17
Electrical Shop		3/28/2017 9:24
Carpentry Shop	WHO - F1581324 FY17	3/28/2017 11:41
Paint Shop		3/28/2017 12:11
Carpentry Shop		3/28/2017 12:11

Paint Shop		3/28/2017 14:01
Electrical Shop		3/29/2017 8:56
Electrical Shop		3/29/2017 9:35
Carpentry Shop	WHO - F1581324 FY17	3/29/2017 9:35
Carpentry Shop	WHO - F1581324 FY17	3/29/2017 10:01
Carpentry Shop	WHO - F1581324 FY17	3/29/2017 16:21
Move Shop	OA - F1587687 FY17 Misc	3/30/2017 7:57
Carpentry Shop, Building Manager	OA - F1612730 FY17 Misc Transition	3/30/2017 13:34

Electrical Shop	USSS - F1619843 FY17 Guard Booth Misc Services	3/30/2017 17:29
Electrical Shop	USSS - F1619843 FY17	3/30/2017 17:33
Building Manager	USSS - F1619843 FY17 Guard Booth	3/30/2017 17:34
Electrical Shop	USSS - F1619843 FY17	3/30/2017 17:34
Elevator Shop	USSS - F1619843 FY17	3/30/2017 17:36
Building Manager, Project Estimator	OA - F1587687 FY17 Misc Services, OA/OCLO	3/31/2017 8:18
Electrical Shop	USSS - F1619843 FY17	3/31/2017 12:02
Carpentry Shop	NSC - F1589148 FY17 Misc Services	3/31/2017 12:33

Paint Shop		3/31/2017 17:06
Building Manager	OA - F1612730 FY17 Misc	4/3/2017 8:06
Carpentry Shop	WHO - F1581324 FY17 Misc Services	4/3/2017 10:36
Carpentry Shop	OA - F1587687 FY17 Misc Services,	4/3/2017 10:43
Move Shop		4/3/2017 12:01
Engineering Shop		4/3/2017 13:39
Plumbing Shop		4/3/2017 13:40
Electrical Shop		4/4/2017 8:21
Building Manager, Project Estimator	USSS - F1619843 FY17 Guard Booth	4/4/2017 12:51
Lock Shop	USSS - F1619843 FY17 Guard Booth	4/4/2017 12:52
Building Manager, Project Estimator	USSS - F1619843 FY17 Guard Booth Misc Services	4/4/2017 12:56

Lock Shop	USSS - F1619843 FY17	4/4/2017 12:57
Move Shop	WHO - F1581324 FY17 Misc Services	4/4/2017 15:39